



REVIEW OF THE PROJECT ACTIVITY

La Grecia Cogeneration Project (1056)

Considering that the DOE and the project participant failed to substantiate that the project activity meets the applicability conditions of scenario 14 of ACM0006 version 4, in particular that the project activity would not result in an increase in the thermal firing capacity, the Board could not register this activity.
