



**CDM: Response form for request for clarification on
Approved Methodologies
(version 01.1)**

<i>Date of Meth Panel meeting:</i>	25 - 29 August 2008
<i>Title and number of request for clarification</i>	Treatment of installing experimental wind turbine in a registered CDM wind project - ACM0002 Ver. 6 AM_CLA_0106

Summary of the query:

Please use the space below to summarize the request for clarification on the related approved methodologies.

This request is for guidance regarding Project 0537: Liaoning Kangping 24.65 MW Wind farm Project, which was registered on October 13, 2006 with ACM0002 version 6.

Following registration, an additional experimental wind turbine has been installed. The electricity generated by this experimental wind turbine will be transmitted through the same facility as the registered CDM project 0537 and therefore the monitoring plan in the registered PDD will not be applicable. Before a revision of the monitoring plan is submitted, guidance is sought if the suggested approach is acceptable.

Under the suggested approach:

- Net electricity generated by the experimental turbine will be monitored by a dedicated on-site meter, recorded as EGe;
- The same parameter EGy as mentioned in the registered PDD section D.2.1.3 will still be monitored, but will be recorded as EG'y;
- Electricity supplied to the grid by the project, which will be used to calculate emissions reductions, shall be calculated as $EGy = EG'y - EGe$.

Recommendation by the Meth Panel:

Please use the space below to provide amendments /changes (in your expert view, if necessary).

The Meth Panel clarifies that the proposed approach for determining the net electricity generated by the registered project activity is acceptable.

Answer to authors of the request for clarification by the Meth Panel :

Please use the space below to provide an answer to the authors of the above query

The Meth Panel clarifies that the proposed approach for determining the net electricity generated by the registered project activity is acceptable.


The Meth Panel reminds the DOE and the PPs that there is an existing procedure for the revision of a monitoring plan, which involves consideration of the request by the secretariat in consultation with the Chair of the Meth Panel and therefore these revisions do not require previous submission of a request for clarification on the application of the approved methodology.



Signature of Meth Panel Chair

Date: 21/07/2008

(Akihiro Kuroki)



Signature of Meth Panel Vice-Chair

Date: 21/07/2008

(Philip Gwage)

Information to be completed by the secretariat

F-CDM-AM	AM_CLA_0106
Name of the authors of the query:	SGS
Date when the form was received at UNFCCC secretariat	21 July 2008
Date of transmission to the EB	21 July 2008
Date of posting in the UNFCCC CDM web site	21 July 2008