

CDM-SSCWG46-A02

Draft Small-scale Methodology

AMS-III.BB.: Electrification of communities through grid extension or construction of new mini-grids

Version 02.0

Sectoral scope(s): 02



DRAFT



United Nations
Framework Convention on
Climate Change

COVER NOTE

1. Procedural background

1. The methodology AMS-III.BB is applicable to project activities involving electrification of a community of consumers through either extension of a grid (national, regional or mini-grid) or construction of new mini-grid. The methodology was first approved at the sixty-seventh meeting of the Board in 11 May 2012.
2. The draft revision of the methodology AMS-III.BB. was prepared by the Small-Scale Working Group (SSC WG) to simplify metering requirements in response to the request for revision SSC_714.

2. Purpose

3. The draft revision of the methodology proposed in this document aims to:
 - (a) Simplify the monitoring procedures for consumers under grid extensions (e.g. using prepaid electricity purchase devices).

3. Impacts

4. The draft revision of the methodology provides more flexibility and simplification for the monitoring. The proposed revision will facilitate the implementation of clean development mechanism (CDM) project activities and component project activities (CPAs) supplying electricity to consumers who, prior to project implementation, were not connected to a national/regional grid and were supplied by a high-carbon-intensive mini-grid or stand-alone power generators. The project activities and CPAs covered under this methodology are very relevant for the least developed countries (LDCs) and other regions that are underrepresented in the CDM.

4. Subsequent work and timelines

5. The methodology is recommended by the SSC WG for consideration by the Board at its eighty-first meeting. No further work is envisaged.

5. Recommendations to the Board

6. The SSC WG recommended that the Board approve the draft revision to AMS-III.BB.

TABLE OF CONTENTS	Page
1. INTRODUCTION	4
2. SCOPE, APPLICABILITY, AND ENTRY INTO FORCE	4
2.1. Scope and applicability	4
2.2. Entry into force.....	6
3. NORMATIVE REFERENCES.....	6
4. DEFINITIONS	7
5. BASELINE METHODOLOGY	7
5.1. Project boundary.....	7
5.2. Baseline emissions	7
5.3. Leakage	12
5.4. Project activity emissions.....	13
5.5. Emission reduction.....	14
6. MONITORING METHODOLOGY	14
6.1. Parameters monitored	14
6.2. Project activity under a programme of activities.....	18

1. Introduction

1. The following table describes the key elements of the methodology.

Table 1. Methodology key elements

Typical project(s)	The project activity supplies electricity to consumers who prior to project implementation were not connected to a national/regional grid and were supplied by a high-carbon-intensive mini-grid or stand-alone power generators. Also fuel-based lighting systems used before the project implementation is displaced by the project activity
Type of GHG emissions mitigation action	Displacement of more-GHG-intensive output. Low-carbon-intensive grid/mini-grid electricity displaces high-carbon-intensive electricity or lighting services

2. Scope, applicability, and entry into force

2.1. Scope and applicability

2. This methodology is applicable to project activities involving electrification of a community of consumers¹ through either:
- Extension of a grid (national, regional or mini-grid);² or
 - Construction of new mini-grid.
3. Such project activities will displace fossil fuel use, such as in fuel-based lighting systems and stand-alone power generators.
4. Electricity consumers may include households, commercial facilities such as shops, public services/buildings and small, medium and micro enterprises (SMMEs). Applications may include lighting (interior, public street lighting), electrical appliances such as refrigerators, agricultural water pumps.
5. At least 75 per cent (by number) of the project consumers shall be households.
6. This methodology is applicable in situations where consumers that were not connected to a national/regional grid prior to project implementation are supplied with electricity from the project activity. It is also applicable to situations where a fraction of consumers that are supplied with electricity from a mini-grid prior to the implementation of the project are now supplied with electricity from the project activity (i.e. moving from carbon intensive mini-grid to less carbon intensive regional/national or mini grid).

¹ Consumers have a single electrical connection to a grid.

² For the purpose of this methodology, a mini-grid is defined as a small-scale power system with a total capacity not exceeding 15 MW (i.e. the sum of installed capacities of all generators connected to the mini-grid is equal to or less than 15 MW) which is not connected to a national or a regional grid.

7. This methodology is applicable for project activities associated with national grids, regional grids or mini-grids that utilize either fossil fuels or fossil fuels and renewable energy in the electricity generation system.
8. Project activities for electrification of a community through the installation of stand-alone renewable electricity generation systems or through the extension/construction of renewable based mini-grid systems shall explore “AMS-I.L.: Electrification of rural communities using renewable energy”.
9. This methodology is not applicable to portable systems, such as portable electricity generating systems.
10. **In this methodology** new consumers are those who did not have supply of electricity prior to project implementation. Existing consumers are those who were supplied electricity from the mini-grid system prior to project implementation. The new consumers **will be are** designated as either households (Type I consumers) or non-households (Type II consumers). **This methodology requires** metering of electricity consumption of each Type II consumers. **as well as** Each Type I consumer expected to consume more than 1000 kWh per year **shall also be metered**. **Prepaid devices for purchase of electricity is considered equivalent to metering under this methodology**. Type I consumers whose consumption is individually required to be metered are designated as Type I-M and Type I consumers whose consumption is not required to be individually metered are designated as Type I-NM.
11. This methodology is applicable where the amount of project electricity delivered to consumers can be determined **(e.g. through the use of meters that continuously measure electricity delivered by the project activity to consumers or through prepaid devices that enable purchase of electricity by the user)**. Specifically:
 - (a) A master-meter **shoulda#** be implemented as part of the project activity to measure the gross electricity sent out to all connected consumers (both existing and new consumers) from the main distribution system. **However, when consumption of the project consumers is determined through metering or prepaid devices, summation of individual metered consumptions will provide the data for the overall consumption and no master meter is required;**
 - (b) A **Ssub-master-meters** **shoulda#** be implemented as part of the project **activity** to measure the gross electricity sent out to **existing and/or new** consumers who are **not metered individually (e.g. consumers who were supplied electricity with an existing mini-grid prior to project implementation)**. Such sub-master-meters will measure total electricity supply to these existing **and/or new** consumers (e.g. metering at substation). **Sub-master-meter is not required if:**
 - (i) **The project activity includes only metered consumers (i.e. Type I-M and Type II consumers); or**
 - (ii) **A master meter is implemented as in paragraph 11(a) above and consumption of each of the non-metered consumer (new and/or existing) is determined through a sample based survey (e.g. stratified random sampling);**
 - (c) Consumption of specific consumers as identified under paragraph **14** below shall be individually metered.

12. An ex ante census of project energy consumers that will be supplied with electricity from the project will be carried out to document the physical location of each consumer and the anticipated connected load and usage hours of each consumer. Optionally the anticipated load for individual households may be established based on the type of connection or payment arrangement provided (e.g. load limited, fee for service based connection).
13. For household consumers not metered (Type I-NM), consumption is calculated as specified below:
 - (a) A master-meter is implemented as described in paragraph 11(a); and
 - (b) A sub master-meter is implemented as per paragraph 11(b) and its reading is divided by the number of connected consumers; or
 - (c) A sample survey (e.g. stratified random sampling) is undertaken as per paragraph 11(b) to determine the average consumption or tiers/classes of average consumptions.
14. For household consumers metered (type I-M) and non-household consumers (Type II), consumption is measured using one of the options below:
 - (a) Option 1: Measurement is undertaken with standard electricity meters at all consumer locations;
 - (b) Option 2: Billing records from pre-paid connections are used to determine the electricity purchased. Specifically:
 - (i) A record of the electricity purchased by each project activity consumer is maintained;
 - (ii) The total electricity consumed for each consumer is the summation of the pre-paid electricity purchased during the monitoring period, excluding the last purchase during the monitoring period but including the last purchase of the previous monitoring period. The total electricity delivered is the summation of the electricity purchased by consumers under the project activity.³
15. Measures are limited to those that result in emission reductions of less than or equal to 60 kt CO₂ equivalent annually.

2.2. Entry into force

16. The date of entry into force is the date of the publication of the EB 81 meeting report on 28 November 2014.

3. Normative references

17. Project participants shall apply the “General guidelines for SSC CDM methodologies”, information on additionality (attachment A to appendix B) provided at:

³ The electricity consumption supported by the last payment in the monitoring period is rolled over to the subsequent monitoring period to ensure an accurate estimation of consumption during the period.

<<http://cdm.unfccc.int/methodologies/SSCmethodologies/approved.html>> mutatis mutan dis.

18. This methodology also refers to the latest approved versions of the following methodologies, guidelines and tools:

- (a) “AMS-I.D.: Grid connected renewable electricity generation”;
- (b) “AMS-I.L.: Electrification of rural communities using renewable energy”;
- (c) “AMS-I.F.: Renewable electricity generation for captive use and mini-grid”;
- (d) “AM0045: Grid connection of isolated electricity systems”;
- (e) “AM0104: Interconnection of electricity grids in countries with economic merit order dispatch”;
- (f) “Tool to calculate the emission factor for an electricity system”;
- (g) “General Guidelines for SSC CDM methodologies”;
- (h) “Standard on sampling and surveys for CDM project activities and PoAs”.

4. Definitions

19. The definitions contained in the Glossary of CDM terms shall apply.

5. Baseline methodology

5.1. Project boundary

20. For project activities involving national or regional grids, the spatial extent of the project boundary includes all power plants within the host country physically connected through transmission and distribution lines to the national or regional grid⁴ which is being extended through the project activity. For project activities involving mini-grids, the spatial extent of the project boundary includes all power plants connected through transmission and/or distribution lines to the mini-grid which is being built or extended through the project activity. The spatial extent of the project boundary also includes the physical sites of the end-use consumers served by the project activity.

5.2. Baseline emissions

21. Baseline emissions are the sum of emissions associated with new consumers (~~Type I non-metered, Type I metered and Type II consumers~~) and where applicable existing consumers, calculated as follows:

$$BE_y = BE_{T1NM,y} + BE_{T1M,y} + BE_{T2,y} + BE_{exist,y} \quad \text{Equation (1)}$$

⁴ Refer to the most recent version of the “Tool to calculate the emission factor for an electricity system” for the definition of electricity system.

Where:

BE_y = Baseline emissions in year y (t CO₂)

$BE_{T1NM,y}$ = Baseline emissions for Type I-NM consumers in year y (t CO₂)

$BE_{T1M,y}$ = Baseline emissions for Type I-M consumers in year y (t CO₂)

$BE_{T2,y}$ = Baseline emissions for Type II consumers in year y (t CO₂)

Baseline emissions of existing consumers, i.e. baseline emissions from displacement of electricity from an existing mini-grid (t CO₂)

$BE_{exist,y}$ = $BE_{exist,y} = 0$, if there are no existing consumers or if the existing consumers are excluded from the project boundary (see footnote 3 for the definition of existing consumers)

22. Baseline emissions of existing consumers are calculated as:

$$BE_{exist,y} = ED_{exist,y} \times EF_{mgrid} \quad \text{Equation (2)}$$

Where:

$ED_{exist,y}$ = Total electricity delivered to existing $N_{exist,y}$ as measured with the use of sub-master meter mentioned in paragraph 8(b)-consumers (MWh)

EF_{mgrid} = Baseline emissions factor for the mini-grid (t CO₂/MWh)
For a mini-grid system where all generators use exclusively fuel oil and/or diesel fuel, emission factor can be determined per the procedure provided in "AMS-I.F.: Renewable electricity generation for captive use and mini-grid".
For all other mini-grids it shall be calculated as the weighted average emissions for the current generation mix following the procedure provided in "AMS-I.D.: Grid connected renewable electricity generation"

23. Total electricity delivered to existing consumers $ED_{exist,y}$ is determined using one of the options below:

(a) As the summation of metered consumption of individual consumers;

(b) Using sub-master meters;

(c) Determined using sample based surveys (e.g. stratified random sampling) when the master meter as per paragraph 11(a) is implemented.

24. Where option (a) or (c)⁵ of paragraph 23 is used:

⁵ Consumption of each tier/class of consumers may be separately determined suitably adapting the equation 2.

$$ED_{exist,y} = \sum_{x=1}^{N_{exist,y}} EC_{exist,x,y} \quad \text{Equation (3)}$$

Where:

$ED_{exist,y}$ = Total electricity delivered to $N_{exist,y}$ consumers (MWh)

$EC_{exist,x,y}$ = Annual electricity consumption of existing consumer x in year y (MWh)

x = Existing consumer ($x = 1, 2, 3, \dots$)

$N_{exist,y}$ = Number of existing consumers receiving electricity from the project activity in year y

25. Where option (b) of paragraph 23 is used:

$$ED_{exist,y} = (EC_{smm_exist,y}) \times (1 - TL_p) \quad \text{Equation (4)}$$

Where:

$EC_{smm_exist,y}$ = Sub-master meter reading of total gross electricity delivered to all existing consumers in year y (MWh)

TL_p = Transmission and distribution losses within the project area (%), with 10 per cent as a default value

26. Baseline emissions of Type II consumers, $BE_{T2,y}$ are calculated as:

$$BE_{T2,y} = \sum_{i=1}^{N_y} EC_{T2,i,y} \times EF_{CO2,T2} \quad \text{Equation (5)}$$

Where:

$BE_{T2,y}$ = Baseline emissions for Type II consumers in year y (t CO₂)

$EC_{T2,i,y}$ = Metered annual electricity consumption of Type II consumer i in year y (MWh)

$EF_{CO2,T2}$ = 1.0 (t CO₂/MWh)

N_y = Number of Type II consumers in year y

i = Type II consumer ($i = 1, 2, 3, \dots$)

27. Baseline emissions of Type I-M consumers, $BE_{T1M,y}$ are calculated as:

$$BE_{T1M,y} = \sum_{j=1}^{M_y} EC_{T1M,j,y} \times EF_{CO2,T1M} \quad \text{Equation (6)}$$

Where:

$BE_{T1M,y}$ = Baseline emissions for Type I-M consumers in year y (t CO₂)

$EC_{T1M,j,y}$ = Annual electricity consumption of Type I-M consumer j in year y (MWh)

$EF_{CO_2,T1M}$ =

1. If $EC_{T1M,j,y}$ is equal to or less than 0.055 MWh/y, then use a default value of 6.8 (t CO₂/MWh);
2. If $EC_{T1M,j,y}$ is less than or equal to 0.250 MWh/y but greater than 0.055 MWh/y, then:
 - (a) For the portion up to and including 0.055 MWh/y, use a default value of 6.8 (t CO₂/MWh);
 - (b) For the portion greater than 0.055 MWh/y, use a default value of 1.3 (t CO₂/MWh);
3. If $EC_{T1M,j,y}$ is greater than 0.250 MWh/y but less than or equal to 0.500 MWh/y, then:
 - (a) For the portion up to and including 0.055 MWh/y use a default value of 6.8 (t CO₂/MWh);
 - (b) For the portion greater than 0.055 MWh/y and less than 0.25 MWh/y use a default value of 1.3 (t CO₂/MWh); and
 - (c) For the portion greater than 0.25 MWh/y use a default value of 1.0 (t CO₂/MWh);
4. If $EC_{T1M,j,y}$ is greater than 0.500 MWh/y then use a default value of 1.0 (t CO₂/MWh) for the entire portion (i.e. default values of 1.3 (t CO₂/MWh) or 6.8 (t CO₂/MWh) are not eligible for any of the portions)

M_y = Number of Type I-M consumers in year y

j = Type I-M consumer ($j = 1, 2, 3, \dots$)

28. For Type I-NM consumers, Baseline emissions of Type I-NM consumers ($BE_{T1NM,y}$) are calculated as a function of total electricity consumed by all the Type I-NM consumers and a baseline emission factor chosen based on the average annual electricity consumption of all Type I-NM consumers:

$$BE_{T1NM,y} = (EC_{tot_T1NM,y}) \times EF_{CO_2,T1NM} \quad \text{Equation (7)}$$

Where:

$EC_{tot_T1NM,y}$ = Total electricity delivered to the community of all Type I-NM consumers, net of transmission and distribution losses (MWh)

$BE_{T1NM,y}$ = Baseline emissions for Type I-NM consumers in year y (t CO₂)

- (a) When a sample survey is undertaken as per paragraph 13(c) to determine the consumption:

$$EC_{tot_T1NM,y} = \sum_{k=1}^{NM_y} EC_{T1NM,k,y} \quad \text{Equation (8)}$$

Where:

$EC_{T1NM,k,y}$ = Annual electricity consumption of Type I-NM consumer k in year y (MWh)

NM_y = Number of Type I-NM consumers in year y

k = Type I-NM consumer ($k = 1, 2, 3, \dots$)

(b) When sub-master meter is used as per paragraph 13(b) to determine the consumption:

$$EC_{tot_T1NM,y} = (EC_{smm_T1NM,y}) \times (1 - TL_p) \quad \text{Equation (9)}$$

Where:

$EC_{smm_T1NM,y}$ = Sub-master meter reading of total gross electricity delivered to all type I-NM consumers in year y (MWh)

$$EC_{T1M,y} = \left(\sum_j^{M_y} EC_{T1M,j,y} \right) \div M_y \quad \text{Equation (10)}$$

(c) When consumption (i.e. total electricity delivered to all Type I-NM consumers $EC_{tot_T1NM,y}$) is calculated as the difference between master meter reading and sum of all other meter readings:

$$EC_{tot_T1NM,y} = [(ED_{tot,y} - ED_{exist,y}) \times (1 - TL_p)] - \sum_i^{N_y} EC_{T2,i,y} - \sum_j^{M_y} EC_{T1M,j,y} \quad \text{Equation (10)}$$

29. When option 28(b) and 28(c) are used:

$$EC_{T1NM,y} = \frac{(EC_{tot_T1NM,y})}{NM_y} \quad \text{Equation (11)}$$

Where:

- $EC_{T1NM,y}$ = Average annual electricity consumption of all Type I-NM consumers in year y (MWh)
- $EC_{T1M,y}$ = Average annual electricity consumption of all Type I-M consumers in year y (MWh)
- $EC_{T1M,j,y}$ = Annual electricity consumption of Type I-M consumer j in year y (MWh)
- N_y = Number of Type II consumers in year y
- NM_y = Number of Type I-NM consumers in year y
- M_y = Number of Type I-M consumers in year y
- $EF_{CO2,T1NM}$ =
- (a) If $EC_{T1NM,y}$ is equal to or less than 0.055 MWh/y, then use a default value of 6.8 (tCO₂/MWh);
 - (b) If $EC_{T1NM,y}$ is less than or equal to 0.250 MWh/y but greater than 0.055 MWh/y, then:
 - (i) For the portion up to and including 0.055 MWh/y, use a default value of 6.8 (tCO₂/MWh);
 - (ii) For the portion greater than 0.055 MWh/y, use a default value of 1.3 (tCO₂/MWh);
 - (c) If $EC_{T1NM,y}$ is greater than 0.250 MWh/y but less than or equal to 0.500 MWh/y, then:
 - (i) For the portion up to and including 0.055 MWh/y use a default value of 6.8 (t CO₂/MWh);
 - (ii) For the portion greater than 0.055 MWh/y and less than 0.25 MWh/y use a default value of 1.3 (t CO₂/MWh);
 - (iii) For the portion greater than 0.25 MWh/y use a default value of 1.0 (t CO₂/MWh);
 - (d) If $EC_{T1NM,y}$ is greater than 0.500 MWh/y, then use a default value of 1.0 (t CO₂/MWh) for the entire portion, i.e. default values of 1.3 (t CO₂/MWh) or 6.8 (tCO₂/MWh) are not eligible for any of the portions
- $ED_{tot,y}$ = Total electricity delivered to the community of all Type I, Type II new and existing consumers (MWh) as measured with the use of master meter as mentioned in paragraph 8(a)9.
- $ED_{exist,y}$ = Total electricity delivered to existing consumers ($N_{exist,y}$) as measured with the use of sub-master meter mentioned in paragraph 8(a.iib)9 (MWh), if there are any existing consumers included in the project activity.

30. $ED_{tot,y}$ is determined by measurement at the master meter as in equation (10) above.

31. Alternatively when $ED_{tot,y}$ is determined as the sum of metered consumption of all consumers as per paragraph 11(a) the below equation shall be used:

$$ED_{tot,y} = ED_{exist,y} + \sum_j^{M_y} EC_{T1M,j,y} + (EC_{tot_T1NM,y}) + \sum_i^{N_y} EC_{T2,i,y} \quad \text{Equation (12)}$$

Where:

$ED_{tot,y}$ = Total electricity delivered to new and existing consumers (MWh)

$ED_{exist,y}$ = Total electricity delivered to existing consumers (MWh), if there are any existing consumers included in the project activity

$EC_{T1M,j,y}$ = Annual electricity consumption of Type I-M consumer j in year y (MWh)

M_y = Number of Type I-M consumers in year y

$\frac{EC_{T1NM,y}}{NM_y}$ = Estimated average annual electricity consumption of Type I-NM consumers in year y (MWh)

NM_y = Number of Type I-NM consumers in year y

$EC_{T2,i,y}$ = Annual electricity consumption of Type II consumer i in year y (MWh)

N_y = Number of Type II consumers in year y

5.3. Leakage

32. Leakage on account of construction of new transmission/distribution lines (e.g. carbon stock loss due to deforestation) shall be calculated using the method indicated in baseline and monitoring methodology “AM0045: “Grid connection of isolated electricity systems” or “AM0104: Interconnection of electricity grids in countries with economic merit order dispatch”. If the estimated leakage is within 5 per cent of the estimated emission reductions of the project, then this leakage source may be neglected, otherwise the leakage shall be deducted from the emissions reductions.
33. If any energy generating equipment (e.g. for a mini-grid) is transferred from another activity, leakage is to be considered.

5.4. Project activity emissions

34. Project emissions are emissions associated with the generation of electricity supplied to the project activity end use facilities.

$$PE_y = \frac{(ED_{tot,y} \times EF_{grid,CO2,y})}{(1 - TL_{grid})} \quad \text{Equation (13)}$$

Where:

PE_y	=	Project emissions from electricity generation in year y (t CO ₂)
$ED_{tot,y}$	=	Total electricity delivered to the community of all Type I, Type II- all new and existing consumers -as measured with the use of master meter as mentioned in paragraph 8(a), (MWh)
$EF_{grid,CO_2,y}$	=	Emissions factor for the project electricity system in year y (t CO ₂ /MWh) If the project activity involves connection to an existing national or regional grid the emissions factor is determined by ranking all the power units in the national or regional grid in the decreasing order of GHG intensity. The emissions factor is the weighted average emissions factor of the top 10 per cent most GHG intensive plants in the grid. ⁶ The emissions factors of the plants shall be calculated based on default plant efficiency provided in the “Tool to calculate the emission factor for an electricity system”. If the project activity involves connection to an existing mini-grid or construction of new mini-grid the emissions factor is determined as either: (a) for a mini-grid system where all generators use exclusively fuel oil and/or diesel fuel per the procedure for such mini-grids provided in AMS-I.F; or (b) for all other mini-grids per the weighted average emissions for the current generation mix following the procedure provided in AMS-I.D
TL_{grid}	=	Transmission and distribution losses in the project electricity system supplying the project activity (%), with 10 per cent as the default value

5.5. Emission reduction

35. Emission reductions (ER_y) are calculated as follows:

$$ER_y = BE_y - PE_y - LE_y \quad \text{Equation (14)}$$

6. Monitoring methodology

6.1. Parameters monitored

Data / Parameter table 1.

Data / Parameter:	$ED_{tot,y}$
Data unit:	MWh/y
Description:	Electricity delivered to consumers from the grid/mini-grid system

⁶ If the grid associated with the project imports electricity from other countries the emission factor shall be the higher among the following two: (i) the weighted average emissions factor of the top 10 per cent most GHG intensive plants in the grid of the host country; and (ii) the weighted average emissions factor of the top 10 per cent most GHG intensive plants in the grid of the exporting country.

Source of data:	-
Measurement procedures (if any):	Measurements are undertaken either using master meters or the summation of metered consumption of all consumers is used. If the master meter options is used, the measurement should be taken at the nearest pre-existing substation from which the electrification project is supplied
Monitoring frequency:	Continuous monitoring, hourly measurement and at least monthly recording
QA/QC procedures:	-
Any comment:	-

Data / Parameter table 2.

Data / Parameter:	$EC_{T2,i,y}$
Data unit:	MWh/y
Description:	Electricity metered at Type II consumer <i>i</i>
Source of data:	-
Measurement procedures (if any):	Measurements are undertaken using electricity meters at each of the Type II facilities Option 1: Standard electricity meters (a) Measurements are undertaken using electricity meters at each of the facilities Option 2: Pre-paid devices (a) Sum all recorded purchases during a monitoring period as indicated in paragraph 14
Monitoring frequency:	Continuous monitoring, hourly measurement and at least monthly recording Option 1: Standard electricity meters (a) Continuous monitoring, hourly measurement and at least monthly recording Option 2: Pre-paid devices (a) All purchases throughout the monitoring period will be recorded
QA/QC procedures:	-
Any comment:	-

Data / Parameter table 3.

Data / Parameter:	$EC_{T1M,j,y}$
Data unit:	MWh/y
Description:	Electricity metered at Type I-M consumer <i>j</i> , expected to consume more than 1000 kWh/y identified under paragraph 9
Source of data:	-

Measurement procedures (if any):	Measurements are undertaken using electricity meters at each of the facilities Option 1: Standard electricity meters (a) Measurements are undertaken using electricity meters at each of the facilities Option 2: Pre-paid devices (a) Sum all recorded purchases during a monitoring period as indicated in paragraph 14
Monitoring frequency:	Continuous monitoring, hourly measurement and at least monthly recording Option 1: Standard electricity meters (a) Continuous monitoring, hourly measurement and at least monthly recording Option 2: Pre-paid devices (a) All purchases throughout the monitoring period will be recorded
QA/QC procedures:	-
Any comment:	-

Data / Parameter table 4.

Data / Parameter:	$ED_{exist,y}$
Data unit:	MWh _y
Description:	Total electricity delivered in year y to the existing consumers
Source of data:	-
Measurement procedures (if any):	If all existing consumers are metered then individual consumptions are summed up. Otherwise, measurements are undertaken using sub-master-meters. The measurement should be taken at the nearest pre-existing substation from which the electrification project is supplied. When master meter is implemented then sample based survey (e.g. stratified random sampling) may be undertaken
Monitoring frequency:	Continuous monitoring, hourly measurement and at least monthly recording
QA/QC procedures:	-
Any comment:	-

Data / Parameter table 5.

Data / Parameter:	$EC_{exist,x,y}$
Data unit:	MWh _y
Description:	Annual electricity consumption of existing consumer x
Source of data:	
Measurement procedures (if any):	Where existing consumers are metered, refer to metering options in Data / Parameter table 2 and 3. When master meter is implemented then sample based survey (e.g. stratified random sampling) may be undertaken

Monitoring frequency:	Where existing consumers are metered, then as per the options in Data / Parameter table 2 and 3
QA/QC procedures:	-
Any comment:	-

Data / Parameter table 6.

Data / Parameter:	$EC_{smm_exist,y}$
Data unit:	MWh
Description:	Sub-master meter reading of total gross electricity delivered to all existing consumers in year y (MWh)
Source of data:	-
Measurement procedures (if any):	As per option (b) of paragraph 23 a sub-master meter may be used
Monitoring frequency:	Continuous monitoring, hourly measurement and at least monthly recording
QA/QC procedures:	-
Any comment:	-

Data / Parameter table 7.

Data / Parameter:	$EC_{T1NM,k,y}$
Data unit:	MWh
Description:	Annual electricity consumption of Type I-NM consumer k in year y (MWh)
Source of data:	-
Measurement procedures (if any):	As per paragraph 13(c) and 28(a), a sample based survey (e.g. stratified random sampling) may be undertaken
Monitoring frequency:	-
QA/QC procedures:	-
Any comment:	-

Data / Parameter table 8.

Data / Parameter:	$EC_{smm_T1NM,y}$
Data unit:	MWh
Description:	Sub-master meter reading of total gross electricity delivered to all type I-NM consumers in year y
Source of data:	-
Measurement procedures (if any):	As per paragraph 13(b) and 28(b), a sub-master meter may be used

Monitoring frequency:	Continuous monitoring, hourly measurement and at least monthly recording
QA/QC procedures:	-
Any comment:	-

Data / Parameter table 9.

Data / Parameter:	<i>Proportion of N_y, NM_y $N_{exist,y}$ and M_y having access to grid</i>
Data unit:	-
Description:	Check for continued access to electricity
Source of data:	-
Measurement procedures (if any):	Annual/biennial check that grid connections are still working, done for a statistically significant sample of consumers. Where project participant has regular billing processes, these records may be used in place of on-site checks. Use 90/10 and 95/10 precision for annual and biennial checks, respectively
Monitoring frequency:	Annual/biennial
QA/QC procedures:	-
Any comment:	-

36. The applicable requirements specified in the “General Guidelines for SSC CDM methodologies” and the “Standard on sampling and surveys for CDM project activities and PoAs” are also an integral part of the monitoring guidelines specified below and therefore shall be referred to by the project participant.

6.2. Project activity under a programme of activities

37. The methodology is applicable to a programme of activities, no additional leakage estimations are necessary other than that indicated under leakage section above.

CDM-SSCWG46-A02

Draft Small-scale Methodology: AMS-III.BB.: Electrification of communities through grid extension or construction of new mini-grids

Version 02.0

Sectoral scope(s): 02

Document information

<i>Version</i>	<i>Date</i>	<i>Description</i>
02.0	7 November 2014	SSC WG 46, Annex 2 To be considered by the Board at EB 81. Revision to simplify the monitoring procedures for consumers under grid extensions (e.g. using prepaid electricity purchase devices) in response to the request for revision SSC_714.
01.0	11 May 2012	EB 67, Annex 17 Initial adoption.

Decision Class: Regulatory

Document Type: Standard

Business Function: Methodology

Keywords: electric power transmission, energy efficiency, simplified methodologies, type (iii) projects

DRAFT