

**Annex 32****Registration****Scope of the review on
“Yunnan Dayingjiang Meng’e Hydro Power Station” (2073)**

1. The Board agreed to undertake a review of the project activity “Yunnan Dayingjiang Meng’e Hydro Power Station” (2073).
2. The Board agreed that the scope of the review relating to issues associated with validation requirements shall cover a review to assess the additionality of the project activity through an assessment of the assumed electricity supply to the grid in the investment analysis, as it has not been demonstrated that the coefficient of effective electricity (0.85) and the transmission loss (16%) are accurate assumptions in the context of this project activity or how the DOE has validated these values.
