

**Annex 43****Registration****Scope of the review on
“Sichuan Liangtan Hydropower Station Second Phase Project” (2410)**

1. The Board agreed to undertake a review of the project activity “Sichuan Liangtan Hydropower Station Second Phase Project” (2410).
2. The Board agreed that the scope of the review relating to issues associated with validation requirements shall cover a review of the additionality of the project activity, through an assessment of the investment analysis, in particular:
 - (a) How the theoretical annual gross power generation has been calculated i.e., what values were assumed for the net water head and generation efficiency;
 - (b) Why the project activity will have lower operating hours than that of the existing plant and the five plants in the common practice analysis;
 - (c) The suitability of the gap between the theoretical annual power generation and the effective electricity supplied to the grid in the context of the project activity; and
 - (d) Why a salvage value after 20 years of operation is not considered.

- - - -

Project 2410	EB 48, Annex 43, 17 July 2009	Decision Class: Ruling Document Type: Scope of Review Business Function: Registration
-----------------	----------------------------------	--