

**Annex 23****Registration****Scope of the review on  
“Jilin Liaoyuan 50MW Level Biomass Cogeneration Project” (2563)**

1. The Board agreed to undertake a review of a project activity “Jilin Liaoyuan 50MW Level Biomass Cogeneration Project” (2563).
2. The Board agreed that the scope of the review relating to issues associated with validation requirements shall cover a review to determine the baseline of the project activity through an assessment of the baseline fuel as:
  - (a) It is uncertain that the heat in absence of the project activity would have come from coal and what quantity of heat will be displaced;
  - (b) The project boundary does not cover the end users of heat located offsite;
  - (c) The heat/ thermal energy is measured at the generation end but not at the user/ consumer end; and
  - (d) The overall impact of all the above uncertainties (baseline fuel and quantity, project boundary not including the end users and heat not being monitored at the user end) will impact the ability of the project activity to achieve real, measurable and additional emission reductions and there is a risk that emission reductions cannot be monitored or calculated.

-----

Project 2563	EB 51, Annex 23, 04 December 2009	<b>Decision Class:</b> Ruling <b>Document Type:</b> Scope of Review <b>Business Function:</b> Registration
-----------------	--------------------------------------	--