



Indicative simplified baseline and monitoring methodologies  
for selected small-scale CDM project activity categories

**TYPE I - RENEWABLE ENERGY PROJECTS**

Project participants shall apply the general guidance to the small-scale CDM methodologies, information on additionality (attachment A to appendix B) and general guidance on leakage in biomass project activities (attachment C to appendix B) provided at <http://cdm.unfccc.int/methodologies/SSCmethodologies/approved.html> > *mutatis mutandis*.

**I.D. Grid connected renewable electricity generation****Technology/measure**

1. This category comprises renewable energy generation units, such as photovoltaic, hydro, tidal/wave, wind, geothermal and renewable biomass that supply electricity to and/or displace electricity from an electricity distribution system that is or would have been supplied by at least one fossil fuel fired generating unit that supply electricity to a national or a regional grid. Project activities that displace electricity from an electricity distribution system that is or would have been supplied by at least one fossil fuel fired generating unit shall apply AMS I.F.

2. This methodology is applicable to project activities that (a) install a new power plant at a site where there was no renewable energy power plant operating prior to the implementation of the project activity (Greenfield plant); (b) involve a capacity addition<sup>1</sup>; (c) involve a retrofit<sup>2</sup> of (an) existing plant(s); or (d) involve a replacement<sup>3</sup> of (an) existing plant(s).

3. Hydro power plants with reservoirs that satisfy at least one of the following conditions are eligible to apply this methodology:

- The project activity is implemented in an existing reservoir with no change in the volume of reservoir;
- The project activity is implemented in an existing reservoir, where the volume of reservoir is increased and the power density of the project activity, as per definitions given in the Project Emissions section, is greater than 4 W/m<sup>2</sup>;
- The project activity results in new reservoirs and the power density of the power plant, as per definitions given in the Project Emissions section, is greater than 4 W/m<sup>2</sup>.

<sup>1</sup> A capacity addition is an increase in the installed power generation capacity of an existing power plant through: (i) the installation of a new power plant besides the existing power plant/units, or (ii) the installation of new power units, additional to the existing power plant/units. The existing power plant/units continue to operate after the implementation of the project activity.

<sup>2</sup> Retrofit (or Rehabilitation or Refurbishment). It involves an investment to repair or modify an existing power plant/unit, with the purpose to increase the efficiency, performance or power generation capacity of the plant, without adding new power plants or units, or to resume the operation of closed (mothballed) power plants. A retrofit restores the installed power generation capacity to or above its original level. Retrofits shall only include measures that involve capital investments and not regular maintenance or housekeeping measures.

<sup>3</sup> Replacement. It involves investment in a new power plant or unit that replaces one or several existing unit(s) at the existing power plant. The installed capacity of the new plant or unit is equal to or higher than the plant or unit that was replaced.



## Indicative simplified baseline and monitoring methodologies for selected small-scale CDM project activity categories

### I.D. Grid connected renewable electricity generation (cont)

4. In the case of biomass power plants, no other biomass types than biomass residues<sup>4</sup> are to be used in the project plant.
5. If the new unit added has both renewable and non-renewable components (e.g., a wind/diesel unit), the eligibility limit of 15 MW for a small-scale CDM project activity applies only to the renewable component. If the new unit added co-fires fossil fuel<sup>5</sup>, the capacity of the entire unit shall not exceed the limit of 15 MW.
6. Combined heat and power (co-generation) systems are not eligible under this category.
7. In the case of project activities that involve the addition of renewable energy generation units at an existing renewable power generation facility, the added capacity of the units added by the project should be lower than 15 MW and should be physically distinct<sup>6</sup> from the existing units.
8. ~~Project activities that involve seek to the retrofits replacements of modify an existing facility for renewable energy generation are included in this category.~~ In the case of retrofit or replacement, to qualify as a small-scale project, the total output of the modified or retrofitted or replacement unit shall not exceed the limit of 15 MW.

#### Boundary

9. The physical, geographical site of the renewable generation source delineates the project boundary.

#### Baseline

10. For a system where all generators use exclusively fuel oil and/or diesel fuel, the baseline emissions is the annual kWh generated by the renewable unit times an emission factor for a modern diesel generating unit of the relevant capacity operating at optimal load as given in Table I.D.1

---

<sup>4</sup> Biomass residues are defined as biomass that is a by-product, residue or waste stream from agriculture, forestry and related industries. This shall not include municipal waste or other wastes that contain fossilized and/or non-biodegradable material (however, small fractions of inert inorganic material like soil or sands may be included).

<sup>5</sup> A co-fired system uses both fossil and renewable fuels.

<sup>6</sup> Physically distinct units are those that are capable of generating electricity without the operation of existing units, and that do not directly affect the mechanical, thermal, or electrical characteristics of the existing facility. For example, the addition of a steam turbine to an existing combustion turbine to create a combined cycle unit would not be considered “physically distinct”.

Indicative simplified baseline and monitoring methodologies  
for selected small-scale CDM project activity categories

## I.D. Grid connected renewable electricity generation (cont)

Table I.D.1

Emission Factors for diesel generator systems (in kg CO<sub>2</sub>e/kWh\*) for three different levels of load factors\*\*

Cases:	Mini-grid with 24 hour service	i) Mini-grid with temporary service (4-6 hr/day) ii) Productive applications iii) Water pumps	Mini-grid with storage
Load factors [%]	25%	50%	100%
<15 kW	2.4	1.4	1.2
>=15 <35 kW	1.9	1.3	1.1
>=35 <135 kW	1.3	1.0	1.0
>=135 <200 kW	0.9	0.8	0.8
> 200 kW***	0.8	0.8	0.8

\*A conversion factor of 3.2 kg CO<sub>2</sub> per kg of diesel has been used (following revised 1996 IPCC Guidelines for National Greenhouse Gas Inventories)

\*\*Values are derived from fuel curves in the online manual of RETScreen International's PV 2000 model, downloadable from <http://retscreen.net/>

\*\*\*Default values

10. If the project activity is the installation of a new grid-connected renewable power plant/unit, the baseline scenario is the electricity delivered to the grid by the project activity that otherwise would have been generated by the operation of grid-connected power plants and by the addition of new generation sources.

11. The baseline emissions are the product of electrical energy baseline  $EG_{BL,y}$  expressed in kWh of electricity produced by the renewable generating unit multiplied by the grid emission factor.

$$BE_y = EG_{BL,y} * EF_{CO_2,grid,y} \quad (1)$$

Where:

$BE_y$  Baseline Emissions in year y (t CO<sub>2</sub>)

$EG_{BL,y}$  Energy baseline in year y; kWh

Quantity of net electricity supplied to the grid as a result of the implementation of the CDM project activity in year y (MWh)

$EF_{CO_2,grid,y}$  CO<sub>2</sub> emission factor of the grid in year y (t CO<sub>2</sub>/MWh)



Indicative simplified baseline and monitoring methodologies  
for selected small-scale CDM project activity categories

*I.D. Grid connected renewable electricity generation (cont)*

---

12. The Emission Factor can be calculated in a transparent and conservative manner as follows:

- (a) A combined margin (CM), consisting of the combination of operating margin (OM) and build margin (BM) according to the procedures prescribed in the ‘Tool to calculate the Emission Factor for an electricity system’.

OR

- (b) The weighted average emissions (in t CO<sub>2</sub>/MWh) of the current generation mix. The data of the year in which project generation occurs must be used.

Calculations shall be based on data from an official source (where available)<sup>7</sup> and made publicly available.

13. In the case of landfill gas, waste gas, wastewater treatment and agro-industries projects, recovered methane emissions are eligible under a relevant Type III category. If the recovered methane is used for electricity generation for supply to a grid then the baseline shall be calculated in accordance with paragraphs below else use other applicable type I methodologies such as AMS-IA or AMS-IF. If the recovered methane is used for heat generation or cogeneration it is eligible under category I.C

14. For project activities that involve seek to retrofits or modify-replacements of an existing facility for renewable energy generation the baseline scenario is the following: continuing operation of the existing plant. The methodology uses historical electricity generation data to determine the electricity generation of the existing plant in the baseline scenario, assuming that the historical situation observed prior to the implementation of the project activity would continue. In the absence of the CDM project activity, the existing facility would continue to provide electricity to the grid  $EG_{BL,retrofit,y}$  at historical average levels  $EG_{historical,y}$  until the time at which the

---

<sup>7</sup> Plant Emission Factors used for the calculation of Emission Factors should be obtained in the following priority:

1. *Acquired directly* from the dispatch center or power producers, if available; or
2. *Calculated*, if data on fuel type, fuel Emission Factor, fuel input and power output can be obtained for each plant;  
If confidential data available from the relevant host Party authority are used, the calculation carried out by the project participants shall be verified by the DOE and the CDM-PDD may only show the resultant carbon Emission Factor and the corresponding list of plants;
3. *Calculated*, as above, but using estimates such as: default IPCC values from the 2006 IPCC Guidelines for National GHG Inventories for net calorific values and carbon Emission Factors for fuels instead of plant-specific values technology provider’s name plate power plant efficiency or the anticipated energy efficiency documented in official sources (instead of calculating it from fuel consumption and power output). This is likely to be a conservative estimate, because under actual operating conditions plants usually have lower efficiencies and higher emissions than name plate performance would imply; conservative estimates of power plant efficiencies, based on expert judgments on the basis of the plant’s technology, size and commissioning date; or
4. *Calculated*, for the simple OM and the average OM, using aggregated generation and fuel consumption data, in cases where more disaggregated data is not available.

### Indicative simplified baseline and monitoring methodologies for selected small-scale CDM project activity categories

#### I.D. Grid connected renewable electricity generation (cont)

electrical generation facility would be likely to be replaced or retrofitted in the absence of the CDM project activity ( $DATE_{BaselineRetrofit}$ ). From that point of time onwards, the baseline scenario is assumed to correspond to the project activity, and baseline electricity production is assumed to equal the project's net electricity production ( $EG_{PJ,retrofit,y}$ ), and no emission reductions are assumed to occur.

15. **Retrofit/capacity addition of hydro, solar, wind, geothermal, wave and tidal plants:** In the specific case of retrofit /capacity addition in hydro, solar, wind, geothermal, wave and tidal plants where power generation can vary significantly from year to year, due to natural variations in the availability of the renewable source (e.g., varying rainfall, wind speed or solar radiation), the use of few historical years to establish the baseline electricity generation can therefore involve a significant uncertainty. The methodology addresses this uncertainty by adjusting the historical electricity generation by its standard deviation. This ensures that the baseline electricity generation is established in a conservative manner and that the calculated emission reductions are attributable to the project activity. Without this adjustment, the calculated emission reductions could mainly depend on the natural variability observed during the historical period rather than the effects of the project activity. The baseline emissions ( $BE_{retrofit,CO_2,y}$ ) are thus calculated as follows:

$$BE_{retrofit,CO_2,y} = [EG_{BL,retrofit,y}] * EF_{CO_2} \quad (2)$$

Where:

$$EG_{BL,retrofit,y} = EG_{PJ, facility,y} - (EG_{historical} + \sigma_{historical}) \quad (3)$$

$$EG_{BL,retrofit,y} = 0 \text{ on / after } DATE_{BaselineRetrofit}$$

$EG_{BL,retrofit,y}$

Quantity of net electricity generation that is supplied to the grid as a result of the implementation of the CDM project activity in year  $y$  (MWh/yr)

$EG_{PJ, facility,y}$

Quantity of net electricity generation supplied by the project plant/unit to the grid in year  $y$  (MWh)

$EG_{historical}$

Annual average historical net electricity generation by the existing renewable energy plant that was operated at the project site prior to the implementation of the project activity (MWh)

Average of historical net electrical energy levels delivered by the existing facility, spanning all data from the most recent available year (or month, week or other time period) to the time at which the facility was constructed, retrofit, or modified in a manner that significantly affected output (i.e., by 5% or more) (MWh)

A minimum of 5 years (60 months) (excluding abnormal years) of historical generation data is required in the case of hydro facilities and for other facilities



Indicative simplified baseline and monitoring methodologies  
for selected small-scale CDM project activity categories

I.D. Grid connected renewable electricity generation (cont)

a minimum of 3 years (36 months) data is required.

In the case that 5 years of historical data are not available - e.g., due to recent retrofits or exceptional circumstances<sup>8</sup> - a new methodology or methodology revision shall be proposed.

$\sigma_{\text{historical}}$  Standard deviation of the annual average historical net electricity generation by the existing renewable energy plant that was operated at the project site prior to the implementation of the project activity (MWh)

$DATE_{\text{BaselineRetrofit}}$  Point in time when the existing equipment would need to be replaced in the absence of the project activity (date)

In the case of wind, solar, wave or tidal power plants, it is assumed that the addition of new capacity or retrofitting of existing unit to increase capacity does not significantly affect the electricity generated by existing plant(s) or unit(s). In this case, the electricity produced by the added power plant(s) or unit(s) could be directly metered and used to determine  $EG_{BL,y}$ , provided that the electricity produced by the added power plant(s) or unit(s) addition is separately metered. Project activities for capacity addition in hydro or geothermal shall use equation 3 replacing subscript 'retrofit' with 'capacity addition'.

**16. Retrofit of renewable energy units not covered in paragraph 15 i.e. units other than hydro, solar, wind, geothermal, wave and tidal plants:**

Baseline emissions are calculated as:

$$BE_{\text{retrofit},CO_2,y} = (EG_{PJ,\text{retrofit},y} - EG_{BL,\text{retrofit},y}) * EF_{CO_2} \quad (4)$$

Where,

$$EG_{BL,\text{retrofit},y} = \text{MAX}(EG_{\text{historical},y}, EG_{\text{estimated},y}) \text{ until } DATE_{\text{BaselineRetrofit}} \quad (5)$$

$$EG_{BL,\text{retrofit},y} = 0 \text{ on / after } DATE_{\text{BaselineRetrofit}} \quad (6)$$

Where:

$BE_{\text{retrofit},CO_2,y}$  The baseline emissions in year y (t CO<sub>2</sub>)

$EG_{PJ,\text{retrofit},y}$  Net electricity supplied by the plant/unit to the grid in year y (MWh)

$EG_{BL,\text{retrofit},y}$  Electricity that would have been supplied by the plant/unit to the grid in the absence of the project activity in year y (MWh)

$EG_{\text{historical}}$  Annual average historical net electricity generation delivered to the grid by the existing renewable energy plant that was operated at the project site prior

<sup>8</sup> Data for periods affected by unusual circumstances such as natural disasters, conflicts, and transmission constraints shall be excluded.



**Indicative simplified baseline and monitoring methodologies  
for selected small-scale CDM project activity categories**

*I.D. Grid connected renewable electricity generation (cont)*

to the implementation of the project activity (MWh)

Average of historical net electrical energy levels delivered by the existing facility, spanning all data from the most recent available year (or month, week or other time period) to the time at which the facility was constructed, retrofit, or modified in a manner that significantly affected output (i.e., by 5% or more) (MWh)

A minimum of 3 years of data is required. In the case that 3 years of historical data are not available<sup>9</sup> - e.g., due to recent retrofits or exceptional circumstances - a new methodology or methodology revision shall be proposed

$EG_{estimated,y}$

Estimated net electrical energy that would have been produced by the existing units under the observed availability of the renewable resource in year  $y$  (MWh)

$DATE_{BaselineRetrofit}$

Point in time when the existing equipment would need to be replaced in the absence of the project activity (date)

17. The requirements concerning demonstration of the remaining lifetime of the replaced equipment shall be met as described in the general guidelines to SSC methodologies<sup>10</sup>. If the remaining lifetime of the affected systems increases due to the project activity, the crediting period shall be limited to the estimated remaining lifetime, i.e., the time when the affected systems would have been replaced in the absence of the project activity.

18. **Capacity addition with renewable energy units not covered in paragraph 15 and 16 i.e. units other than solar, wind, geothermal, wave and tidal plants:** For project activities that involve the addition of renewable energy generation units at an existing renewable power generation facility, where the existing and new units share the use of common and limited renewable resources (e.g. biomass residues), the potential for the project activity to reduce the amount of renewable resource available to, and thus electricity generation by, existing units must be considered in the determination of Baseline Emissions, project emissions, and/or leakage, as relevant.

The baseline scenario is the existing facility that would continue to supply electricity to the grid at historical levels, until the time at which the generation facility would likely be replaced or retrofitted ( $DATE_{BaselineRetrofit}$ ). From that point of time onwards, the baseline scenario is assumed to correspond to the project activity, and no emission reductions are assumed to occur.

<sup>9</sup> Data for periods affected by unusual circumstances such as natural disasters, conflicts, and transmission constraints shall be excluded.

<sup>10</sup> Refer to: “General guidance to Indicative simplified baseline and monitoring methodologies for selected small-scale CDM project activity categories”.  
<[http://cdm.unfccc.int/Reference/Guidclarif/ssc/methSSC\\_guid06\\_v12.pdf](http://cdm.unfccc.int/Reference/Guidclarif/ssc/methSSC_guid06_v12.pdf)>.



Indicative simplified baseline and monitoring methodologies  
for selected small-scale CDM project activity categories

*I.D. Grid connected renewable electricity generation (cont)*

The energy baseline corresponds to the net increase in electricity production associated with the project should be calculated as follows:

The baseline emissions ( $BE_{add,CO_2,y}$ ) are calculated as:

$$BE_{add,CO_2,y} = (EG_{PJ,add,y} - EG_{BL,existing,y}) * EF_{CO_2} \quad (7)$$

Where:

$EG_{PJ,add,y}$	The total net actual electrical energy produced and supplied to a grid in year $y$ by all units, existing and new project units; (MWh)
$EG_{BL,existing,y}$	The estimated net electrical energy that would have been produced and supplied to a grid by existing units (installed before the project activity) in year $y$ in the absence of the project activity, (MWh)

Where :

$$EG_{BL,existing,y} = MAX(EG_{actual,y}, EG_{estimated,y}) \text{ until } DATE_{BaselineRetrofit} \quad (8)$$

and

$$EG_{BL,existing,y} = 0 ; \text{ on/after } DATE_{BaselineRetrofit}$$

Where:

$EG_{actual,y}$	The actual, measured net electrical energy produced and supplied to the grid by the existing units in year $y$ (MWh)
-----------------	--

If the existing units shut down, are derated, or otherwise become limited in production, the project activity should not get credit for generating electricity from the same renewable resources that would have otherwise been used by the existing units (or their replacements). Therefore, the equation for  $EG_{BL,existing,y}$  still holds, and the value for  $EG_{estimated,y}$  should continue to be estimated assuming the capacity and operating parameters are the same as that at the time of the start of the project activity.

### Project emissions

19. For most renewable energy project activities,  $PE_y = 0$ . However, for the following categories of project activities, project emissions have to be considered following the procedure described in the most recent version of ACM0002.

- Emissions related to the operation of geothermal power plants (e.g. non-condensable gases, electricity/fossil fuel consumption)
- Emissions from water reservoirs of hydro power plants





Indicative simplified baseline and monitoring methodologies  
for selected small-scale CDM project activity categories

*I.D. Grid connected renewable electricity generation (cont)*

---

**Leakage**

20. If the energy generating equipment is transferred from another activity, leakage is to be considered.

**Emission reductions**

21. Emission reductions are calculated as follows:

$$ER_y = BE_y - PE_y - LE_y \quad (13)$$

Where:

$ER_y$  Emission reductions in year  $y$  (t CO<sub>2</sub>/y)

$BE_y$  Baseline Emissions in year  $y$  (t CO<sub>2</sub>/y)

$PE_y$  Project emissions in year  $y$  (t CO<sub>2</sub>/y)

$LE_y$  Leakage emissions in year  $y$  (t CO<sub>2</sub>/y)

Indicative simplified baseline and monitoring methodologies  
for selected small-scale CDM project activity categories

## Monitoring

22. Relevant parameters shall be monitored as indicated in the table below

No	Parameter	Description	Unit	Monitoring/recording Frequency	Measurement Methods and Procedures
1	$EF_{CO_2,y}$	CO <sub>2</sub> emission factor of the grid electricity in year y	t CO <sub>2</sub> e/kWh		As described in paragraph 12 of this methodology.
2		CO <sub>2</sub> emission factor of fossil fuel type i	tCO <sub>2</sub> e/MJ	As per the “Tool to calculate project or leakage CO <sub>2</sub> emissions from fossil fuel combustion”	As per the “Tool to calculate project or leakage CO <sub>2</sub> emissions from fossil fuel combustion”
3		Net calorific value of fossil fuel type i o	MJ per unit volume or mass unit	As per the “Tool to calculate project or leakage CO <sub>2</sub> emissions from fossil fuel combustion”	As per the “Tool to calculate project or leakage CO <sub>2</sub> emissions from fossil fuel combustion”
4		Quantity of fossil fuel consumed in year y	Mass or volume unit/y	As per the “Tool to calculate project or leakage CO <sub>2</sub> emissions from fossil fuel combustion”	As per the “Tool to calculate project or leakage CO <sub>2</sub> emissions from fossil fuel combustion” .
5	$EG_{facility,y}$ $EG_{actual,y}$ $EG_{add,y}$	Quantity of net electricity supplied to the grid in year y	MWh/y	Continuous monitoring, hourly measurement and at least monthly recording	Measurements are undertaken using energy meters. Calibration should be undertaken as prescribed in the relevant paragraph of General Guidelines to SSC Methodologies: If applicable, measurement results shall be cross checked with records for sold/purchased electricity (e.g., invoices/receipts).

Indicative simplified baseline and monitoring methodologies  
for selected small-scale CDM project activity categories

## I.D. Grid connected renewable electricity generation (cont)

					The net electricity export/supplied to a grid is the difference between the measured quantities of the grid electricity export and the import. If applicable, cross check net electricity supplied to a grid as gross energy generation in the project activity power plant minus the auxiliary/station electricity consumption, technical losses and electricity import from the grid to the project power plant measured at the grid interface/connection used for billing purposes
6		Quantity of biomass consumed in year y	Ton/y	Continuously or estimate using annual energy/mass balance	Use mass or volume based measurements. Adjust for the moisture content in order to determine the quantity of dry biomass. Crosscheck the measurements with an annual energy/mass balance that is based on purchased quantities and stock.  For projects consuming biomass and fossil fuel to produce electricity, a specific energy-fuel consumption <sup>11</sup> of each type of fuel (biomass or fossil) to be used should be specified <i>ex ante</i> . The consumption of each type of fuel (biomass or fossil) shall be monitored.  If fossil fuel is used, the electricity generation metered should be adjusted by deducting the electricity generation from fossil fuels using the specific energy-fuel consumption and the quantity of fossil fuel consumed.

<sup>11</sup> Specific fuel consumption is the fuel consumption per unit of electricity generated (e.g., tonnes of bagasse per MWh). Specific energy consumption is the fuel consumption (in energy basis) per unit of electricity generated (e.g., TJ of bagasse energy per MWh output)

Indicative simplified baseline and monitoring methodologies  
for selected small-scale CDM project activity categories

## I.D. Grid connected renewable electricity generation (cont)

					The amount of electricity generated using biomass fuels calculated then shall be compared with the amount of electricity generated calculated using specific <b>energy fuel</b> consumption and amount of each type of biomass fuel used. The lower of the two values should be used to calculate emission reductions.
7		Moisture content of the biomass residues	% water	The moisture content of biomass of homogeneous quality shall be monitored at least on a monthly basis.  The weighted average should be calculated for each monitoring period and used in the calculations	On-site measurements  In case of dry biomass, monitoring of this parameter is not necessary.
8		Net calorific value of biomass residue type <i>k</i>	GJ/mass or volume unit	Annually	Measurement in laboratories according to relevant national/international standards. Measure the NCV based on dry biomass. Check the consistency of the measurements by comparing the measurement results with measurements from previous years, relevant data sources (e.g. values in the literature, values used in the national GHG inventory) and default values by the IPCC. If the measurement results differ significantly from previous measurements or other relevant data sources, conduct additional measurements.



Indicative simplified baseline and monitoring methodologies  
for selected small-scale CDM project activity categories

I.D. Grid connected renewable electricity generation (cont)

9	$\sigma_{\text{historical}}$	Standard deviation of the annual average historical net electricity generation delivered to the grid by the existing renewable energy plant that was operated at the project site prior to the implementation of the project activity	MWh/yr		Calculated from data used to establish $EG_{\text{historical}}$ Parameter to be calculated as the standard deviation of the annual generation data used to calculate $EG_{\text{historical}}$ for retrofit or replacement project activities
10 Parameters relevant to reservoir based hydro and geothermal plants not included in this table shall be monitored following the most recent version of ACM0002					



**Indicative simplified baseline and monitoring methodologies  
for selected small-scale CDM project activity categories**

*I.D. Grid connected renewable electricity generation (cont)*

**Project activity under a programme of activities**

The following conditions apply for use of this methodology in a project activity under a programme of activities:

23. In the specific case of biomass project activities the applicability of the methodology is limited to either project activities that use biomass residues only or biomass from dedicated plantations complying with the applicability conditions of AM0042.

24. In the specific case of biomass project activities the determination of leakage shall be done following the general guidance for leakage in small-scale biomass project activities (attachment C of appendix B<sup>12</sup> of simplified modalities and procedures for small-scale clean development mechanism project activities; decision 4/CMP.1) or following the procedures included in the leakage section of AM0042.

25. In case the project activity involves the replacement of equipment, and the leakage from the use of the replaced equipment in another activity is neglected because the replaced equipment is scrapped, an independent monitoring of scrapping of replaced equipment needs to be implemented. The monitoring should include a check if the number of project activity equipment distributed by the project and the number of scrapped equipment correspond with each other. For this purpose scrapped equipment should be stored until such correspondence has been checked. The scrapping of replaced equipment should be documented and independently verified.

- - - - -

**History of the document\***

Version	Date	Nature of revision(s)
16	EB xx, Annex # dd mm 2010	To distinguish the project activities solely supplying renewable electricity to a grid from activities displacing electricity from a grid. The parameters to be monitored including the frequency and QA/QC procedures are also included.
15	EB 50, Annex 29 16 October 2009	To include the procedures to calculate project emissions for hydropower with reservoirs as specified in Annex 5 of EB 23.
14	EB 48, Annex 23 17 July 2009	To include more guidance on: the monitoring of electricity generated; calculation of project emissions for geothermal project activities; and editorial changes.
13	EB 36, Annex 26 14 December 2007	To refer directly to the "tool to calculate the emission factor for an electricity system" for reasons of clarity.
12	EB 33, Annex 23 27 July 2007	To allow for their application under a programme of activities (PoA), where the limit of the entire PoA exceeds the limit for small-scale CDM project activities.
11	EB 31, Annex 21 04 May 2007	To include guidance on monitoring of biomass project activities. All small-scale biomass project activities applying AMS-I.D. (firing only biomass or firing biomass and fossil fuel) are required to monitor the biomass and any fossil fuel used.

<sup>12</sup> Available on <<http://cdm.unfccc.int/methodologies/SSCmethodologies/approved.html>>.



**Indicative simplified baseline and monitoring methodologies  
for selected small-scale CDM project activity categories**

*I.D. Grid connected renewable electricity generation (cont)*

10	EB 28, Annex 22 23 December 2006	The proposed revision includes guidance on consideration of capacity limit and on estimation of baseline/project/leakage emissions in the case of project activities that involve the addition of renewable energy generation units at an existing renewable power generation facility.
09	EB 25, Annex 29 28 July 2006	An amendment to the procedure for estimating the combined margin emission factor of AMS-I.D, making it thereby consistent with ACM0002.
08	EB 23, Annex 32 24 February 2006	To (i) include provisions for retrofit and renewable energy capacity additions as eligible activities; (ii) provide clarification for baseline calculations under Category I.D; and (iii) provide clarification on the applicability of Category I.A as against Category I.D.
<b>Decision Class:</b> Regulatory <b>Document Type:</b> Standard <b>Business Function:</b> Methodology		

\* This document, together with the 'General Guidance' and all other approved SSC methodologies, was part of a single document entitled: Appendix B of the Simplified Modalities and Procedures for Small-Scale CDM project activities until version 07.

Appendix B of the Simplified Modalities and Procedures for Small-Scale CDM project activities contained both the General Guidance and Approved Methodologies until version 07. After version 07 the document was divided into separate documents: 'General Guidance' and separate approved small-scale methodologies (AMS).		
Version	Date	Nature of revision
07	EB 22, Para. 59 25 November 2005	References to "non-renewable biomass" in Appendix B deleted.
06	EB 21, Annex 22 20 September 2005	Guidance on consideration of non-renewable biomass in Type I methodologies, thermal equivalence of Type II GWhe limits included.
05	EB 18, Annex 6 25 February 2005	Guidance on 'capacity addition' and 'cofiring' in Type I methodologies and monitoring of methane in AMS-III.D included.
04	EB 16, Annex 2 22 October 2004	AMS-II.F was adopted, leakage due to equipment transfer was included in all Type I and Type II methodologies.
03	EB 14, Annex 2 30 June 2004	New methodology AMS-III.E was adopted.
02	EB 12, Annex 2 28 November 2003	Definition of build margin included in AMS-I.D, minor revisions to AMS-I.A, AMS-III.D, AMS-II.E.
01	EB 7, Annex 6 21 January 2003	Initial adoption. The Board at its seventh meeting noted the adoption by the Conference of the Parties (COP), by its decision 21/CP.8, of simplified modalities and procedures for small-scale CDM project activities (SSC M&P).
<b>Decision Class:</b> Regulatory <b>Document Type:</b> Standard <b>Business Function:</b> Methodology		