

Sl.No.	HTSC.No.	No.of WTGs	Test Certificate Date	Customer Name	Total No. Of WTGs
1	745	7	7/12/2006	Ashok Leyland	<b>20</b>
2	746	4	7/12/2006	Ashok Leyland	
3	747	6	7/12/2006	Ashok Leyland	
4	748	3	7/12/2006	Ashok Leyland	
5	916	2	7/12/2006	Saint Gobain Glass Ltd	<b>17</b>
6	948	4	7/12/2006	Saint Gobain Glass Ltd	
7	949	4	7/12/2006	Saint Gobain Glass Ltd	
8	985	6	7/12/2006	Saint Gobain Glass Ltd	
9	1018	1	7/12/2006	Saint Gobain Glass Ltd	
10	1019	4	7/12/2006	Lotte India Corp.Ltd	<b>6</b>
11	1083	2	7/12/2006	Lotte India Corp.Ltd	
12	1021	4	7/12/2006	India Piston Ltd	<b>27</b>
13	1084	4	7/12/2006	India Piston Ltd	
14	1085	1	7/12/2006	India Piston Ltd	
15	1240	1	5/12/2006	India Piston Ltd	
16	1241	1	5/12/2006	india Piston Ltd	
17	1242	2	5/12/2006	India Piston Ltd	
18	1243	6	5/12/2006	India Piston Ltd	
19	1326	1	5/12/2006	India Piston Ltd	
20	1327	7	5/12/2006	India Piston Ltd	
<b>Total</b>					

TAMIL NADU ELECTRICITY BOARD

From	To
Assistant Executive Engineer, Meter and Relay Test, Wind Farm Project, WEDC, Udumalpet.	M/s. Ashok Leyland, Corporate Office : Post Bag 5073, 19, Rajaji Salai, Chennai - 600 001.

---


Lr.No. AEE / MRT / WF / Udt / F Test Results / D.No. 784 / 06 Dt : 11. / 12. / 06

Sir,

Sub : Electricity WEDC - Private party Meter Tested at MRT/Lab/Udt for effecting new wind farm HT service - reg.

Ref : 1. Your Letter No. dt 4.12.06.

With reference to the above, the copy of the test certificate for the energy meter tested at MRT / Lab/ Udumalpet for effecting new Wind farm HT service are enclosed herewith. The meter details are furnished in the Annexure.

  
Assistant Executive Engineer,  
Meter and Relay Test,  
Wind Farm Project, WEDC,  
Udumalpet.

## TAMIL NADU ELECTRICITY BOARD

From	To
Assistant Executive Engineer, Meter and Relay Test, Wind Farm Project, WEDC, Udumalpet.	M/s. India Pistons Ltd., Hozur Gardens, Sembiam, Chennai – 600 001.


Lr.No. AEE / MRT / WF / Udt / F Test Results / D.No.787 /06 Dt : 11.12.06

Sir,

Sub : Electricity WEDC – Private party Meter Tested at MRT/Lab/Udt for effecting new wind farm HT service – reg.

Ref: 1. Your Letter No. dt 4.12.06.

With reference to the above, the copy of the test certificate for the energy meter tested at MRT / Lab/ Udumalpet for effecting new Wind farm HT service are enclosed herewith. The meter details are furnished in the Annexure.

  
Assistant Executive Engineer,  
Meter and Relay Test,  
Wind Farm Project, WEDC,  
Udumalpet.

## TAMIL NADU ELECTRICITY BOARD

From

Assistant Executive Engineer,  
Meter and Relay Test,  
Wind Farm Project, WEDC,  
Udumalpet.

To

M/s. Lotte India Corporation Ltd.,  
'Dare House', 234, N.S.C. Bose Road,  
Parrys Corner,  
Chennai - 600 001.


Lr.No. AEE / MRT / WF / Udt / F Test Results / D.No. 786/06 Dt : 11. 12. /06

Sir,

Sub : Electricity WEDC - Private party Meter Tested at MRT/Lab/Udt for  
effecting new wind farm HT service - reg.

Ref: 1. Your Letter No. dt 4.12.06.

With reference to the above, the copy of the test certificate for the energy  
meter tested at MRT / Lab/ Udumalpet for effecting new Wind farm HT service are  
enclosed herewith. The meter details are furnished in the Annexure.

  
Assistant Executive Engineer,  
Meter and Relay Test,  
Wind Farm Project, WEDC,  
Udumalpet.

TAMIL NADU ELECTRICITY BOARD

From

Assistant Executive Engineer,  
Meter and Relay Test,  
Wind Farm Project, WEDC,  
Udumalpet.

To

M/s. Saint – Gobian Glass India Ltd,  
Plot No. A-1, SIPCOT Industrial Park,  
Sriperumbudur – 602 105,  
Kanchipuram District.


Lr.No. AEE / MRT / WF / Udt / F Test Results / D.No.785/06 Dt : 11. / 9. / 06

Sir,

Sub : Electricity WEDC – Private party Meter Tested at MRT/Lab/Udt for effecting new wind farm HT service – reg.

Ref: 1. Your Letter No. dt 4.12.06.

With reference to the above, the copy of the test certificate for the energy meter tested at MRT / Lab/ Udumalpet for effecting new Wind farm HT service are enclosed herewith. The meter details are furnished in the Annexure.

  
Assistant Executive Engineer,  
Meter and Relay Test,  
Wind Farm Project, WEDC,  
Udumalpet.

TAMILNADU ELECTRICITY BOARD

From  
Assistant Executive Engineer,  
Meter And Relay tests,  
Udumalpet Electricity Distribution Circle,  
Udumalpet.

To  
Assistant Executive Engineer,  
Meter and Relay Tests,  
Wind Energy Development Circle,  
Udumalpet.

Lr.NoAEE/MRT/UDT/F -TEST RESULTS/D469/06, dt 07.12.2006

Sir,


Sub: Electricity -UEDC-Meter test Results submission -Reg

Ref: Lr.No:AEE/MRT/WFP/UDT/F TEST RESULTS/D775/06 DT 05.12.06

\*\*\*\*\*

With reference to above, I herewith enclose the Meter test results for the following windfarm services, for further action.

1. M/S Ashok Leyland
2. M/S Saint Gobain Glass India Ltd.
3. M/S Lotte India Corporation Ltd.
4. M/S India piston Ltd


  
Assistant Executive Engineer,  
Meter and Relay Tests,  
UEDC / Udumalpet.

Encl:- 4 Sheets.




ANNEXURE  
TEST CERTIFICATE

SL. NO.	WF HTSC NO.	NAME OF CONSUMER	METER MAKE	SERIAL NO.	CLASS	DATE OF COMMISSIONING	TEST RESULT METER FOUND SATISFACTION / DEFECTIVE
1.	745	ASHOK LEYLAND LTD	ELSTER	04691459	0.5	30.03.2005	Satisfactory
2.	746	ASHOK LEYLAND LTD	ELSTER	04691460	0.5	31.03.2005	Satisfactory
3.	747	ASHOK LEYLAND LTD	ELSTER	04691461	0.5	31.03.2005	Satisfactory
4.	748	ASHOK LEYLAND LTD	ELSTER	04691462	0.5	31.03.2005	Satisfactory

  
21/12/06  
ASSISTANT COMMISSIONER  
Deputy  
Housing & Urban Development

**ANNEXURE  
TEST CERTIFICATE**

SL. NO.	WF HTSC NO.	NAME OF CONSUMER	METER MAKE	SERIAL NO.	CLASS	DATE OF COMMISSIONING	TEST RESULT METER FOUND SATISFACTION / DEFECTIVE
1.	916	SAINT GOBAIN GLASS LTD	ELSTER	04720082	0.5	09.09.2005	Satisfactory
2.	948	SAINT GOBAIN GLASS LTD	ELSTER	04720034	0.5	22.09.2005	Satisfactory
3.	949	SAINT GOBAIN GLASS LTD	ELSTER	04720019	0.5	22.09.2005	Satisfactory
4.	985	SAINT GOBAIN GLASS LTD	ELSTER	04721971	0.5	29.09.2005	Satisfactory
5.	1018	SAINT GOBAIN GLASS LTD	ELSTER	04721968	0.5	30.09.2005	Satisfactory

  
ASSISTANT  
2112 106

Udeta  
10000000-042 126.




ANNEXURE  
TEST CERTIFICATE

SL. NO.	WF HTSC NO.	NAME OF CONSUMER	METER MAKE	SERIAL NO.	CLASS	DATE OF COMMISSIONING	TEST RESULT: METER FOUND SATISFACTION / DEFECTIVE
1.	1021	INDIA PISTON	ELSTER	04720026	0.5	30.09.05	Satisfactory
2.	1084	INDIA PISTON	ELSTER	04725678	0.5	07.02.06	Satisfactory
3.	1085	INDIA PISTON	ELSTER	02373916	0.5	07.02.06	Satisfactory

*[Handwritten Signature]*  
Date: 21/12/11  
[Faint Stamp]

ANNEXURE  
TEST CERTIFICATE

SL. NO.	WF HTSC NO.	NAME OF CONSUMER	METER MAKE	SERIAL NO.	CLASS	DATE OF COMMISSIONING	TEST RESULT METER FOUND SATISFACTION / DEFECTIVE
1.	1019	LOTTE INDIA CORPORATION LTD	ELSTER	04721969	0.5	30.09.2005	Satisfactory
2.	1083	LOTTE INDIA CORPORATION LTD	ELSTER	04725697	0.5	07.02.2006	Satisfactory

  
31/12/06

Udara  
31/12/06

**TAMIL NADU ELECTRICITY BOARD**

From

To

**Er.V.BALAN, B.E.,**  
The Assistant Executive Engineer,  
Meter and Relay Test,  
Wind Farm Project, WEDC,  
Udumalpet.

India Pistons Ltd.,  
Huzur Gardens,  
Sembiam,  
Chennai – 600 011.  
India.

Lr. No. : AEE / MRT / WFP / Udt / F Test Results / D.No : 716 / 06 / Dt : 5.12.06


Sir,

Sub : Electricity WEDC – Private party Meter Tested at MRT / WFP / Udt – for effecting new Wind Farm HT Services. Meter tested at MRT / Lab / WFP / Udt – Test Certificate issued at the party request – reg.

Ref : Your Letter No.

With reference to the above, 6 nos. Energy meter were tested on various dates at **MRT / WFP / Udt**. The test results are found satisfactory. The Meter details and service details are furnished in the annexure.

Yours faithfully,


  
Assistant Executive Engineer,  
Meter and Relay Test,  
Wind Farm Project / WEDC,  
Udumalpet.

ANNEXURE

## TEST CERTIFICATE

SL. NO.	WF HTSC NO.	NAME OF CONSUMER	SF NO.	VILLAGE	DATE OF COMMISSIONING	METER MAKE	SERIAL NO.	TYPE	CLASS	METER TESTED	METER FOUND SATISFACTION / DEFECTIVE
1.	1240	INDIA PISTON CHENNAI	138/B1	PONNERI	31.03.2006	ELSTER	04726652	ALPHA JL	0.5	29.03.06	Satisfactory
2.	1241	INDIA PISTON CHENNAI	141/A1	PONNERI	31.03.2006	ELSTER	04726643	ALPHA JL	0.5	29.03.06	- do -
3.	1242	INDIA PISTON CHENNAI	182/1	THANTHONI	31.03.2006	ELSTER	04726642	ALPHA JL	0.5	29.03.06	- do -
4.	1243	INDIA PISTON CHENNAI	182/4	THANTHONI	31.03.2006	ELSTER	04726640	ALPHA JL	0.5	29.03.06	- do -
5.	1326	INDIA PISTON CHENNAI	18/3	PONNERI	30.09.2006	ELSTER	04863675	ALPHA JL	0.5	28.09.06	- do -
6.	1327	INDIA PISTON CHENNAI	138/B1	PONNERI	30.09.2006	ELSTER	04722000	ALPHA D+	0.5	28.09.06	- do -

Note : 6 Nos. meters were tested at MRT / Lab / WFP / Udumalpet for effecting New Wind Farm HT Services.

  
 ASSISTANT EXECUTIVE ENGINEER  
 Meter And Relay Test,  
 Wind Energy Development Circle,  
 Tamilnadu Electricity Board,  
 UDUMALPET - 642 154