



Mr. Hans Jürgen Stehr Chair, CDM Executive
Board
UNFCCC Secretariat
CDMinfo@unfccc.int

May 31st 2007

Re Request for review of the request for issuance for the CDM project activity “56.25 MW bundled wind energy projects in Tirunelveli and Coimbatore districts in Tamilnadu, India” (Ref. no. 0471)

Dear Mr. Stehr,

SGS has been informed that the request for issuance for the CDM project activity “56.25 MW bundled wind energy projects in Tirunelveli and Coimbatore districts in Tamilnadu, India” (Ref. no. 0471) is under consideration for review because three requests for review have been received from members of the Board.

The requests for review are based on the same reason outlined below. SGS would like to provide an initial response to the issues raised by the request for review:

Request 1, 2 and 3:

The monitoring plan requires that “All the meters shall be calibrated every year with reference to a portable standard meter.” Neither the monitoring report nor the verification report indicates that this requirement has been met.

SGS Response to the Comments:

The electricity meters installed at the site are owned and maintained by Tamilnadu Electricity Board (TNEB) and are calibrated by them annually. This was checked during site visit and it was found satisfactory that the electricity export meters installed at respective High Tension Service Connection (HTSC) points at both the sites were calibrated. The details of calibration for both the sites were furnished and attached as Annex 1 (Calibration Certificate for Tirunelveli) and Annex 2 (Calibration Certificate for Coimbatore). This is also mentioned in the revised verification report which is added as Annex 3 and Monitoring report added as Annex 4 herewith.

Inadvertently this was not mentioned in the earlier version of the verification report, however due check was done during site visit according to SGS verification checklist which is used as an internal report only.

We feel that the clarification requirement has been taken into account. We do however apologize as this was not mentioned in the earlier version of the verification report.

Sanjeev Kumar will be the contact person for the review process and is available to address questions from the Board during the consideration of the review in case the Executive Board wishes.



Yours sincerely

Irma Lubrecht
Technical Reviewer
Irma.lubrecht@sgs.com
T: +31 181 693293
M: +31 651 851777

Sanjeev Kumar
Lead Auditor
Sanjeev.kumar@sgs.com
T: +91 124 2399990
M: +91 98717 94628

Encl:

Annex 1: Calibration Certificate for Tirunelveli
Annex 2: Calibration Certificate for Coimbatore
Annex 3: Verification Report
Annex 4: Monitoring Report version 4