

Sheet-I

TRANSMISSION CORPORATION OF ANDHRA PRADESH LIMITED

Joint energy meter readings taken on 31/3/2007,

at 33/11KV Kesineneipalli sub-station

(A) Generation of M/S Agri Gold project limited. (4.0MW)

from 22/03/2007 to 31/03/2007 at 24:00hrs

DATE	MWH	MVAH	MVARH		MD(MVA)	REMARKS
			LAG	LEAD		
31/03/2007 (at 24:00hrs)	100039.60	102500.50	18480.50	1000.20	5.350	Energy meter SI No TNB 00813 (Main meter)
22/03/2007	99635.40	102092.40	18438.00	996.30	5.480	
Difference	404.2	408.1	42.5			
M.F	1000	1000	1000			
Generation	404200	408100	42500			
	KWH	KVAH	KVARH			

(B) Consumption of Joint energy meter readings taken on 31/3/2007,

from 22/03/2007 to 31/03/2007 at 24:00hrs

DATE	MWH	MVAH	MVARH		MD(MVA)	REMARKS
			LAG	LEAD		
31/03/2007 (at 24:00hrs)	1256.90	1425.9	545.5	183.7	0.7800	Energy meter SI No TNB 00813 (Main)
22/03/2007	1237.80	1400.9	530.8	183.4	0.8200	
DIFFERENCE	19.1	25	14.7			
M.F	1000	1000	1000			
Consumption	19100	25000	14700			
	KWH	KVAH	KVARH			

For AGRI GOLD PROJECTS LTD.

Executive Vice Chairman

DIVISIONAL ENGINEER
T.L.S.S. A.P. TRANSCO
ONGOLE