

01-Feb-07

1 X 24 MW COGENERATION PLANT GSML-Sameerwadi

DAILY PRODUCTION REPORT

TIME	GENMW	NETGEN	EXPORT	FIC101	F1202	F1400	F1401	F1402	FIC500	F1501	FIC502	F1505	F1205
	SUM	NET	TOTAL	SUM	SUM	SUM	SUM	SUM	SUM	SUM	SUM	SUM	SUM
LOAD	ACTUAL	GENERATION	EXPORT	FW FLOW	MAIN	M/S FLOW	LP STEAM	HP STEAM	CEP MIN	CST TO	CONDENSATE	HOTWELL	SPRAY
	MW	ON	MW	CONTROLL	FROM	TO	FLOW	FLOW	CONTROL	DEERATO	FROM SUGAR	MAKE UP	WATER
				ER	BOILER	TURBINE	TPH	TPH	TPH	R FLOW	TPH	FLOW	FLOW
5:00	23.6	21.69	16.4	126.141	122.1	119.4	59.09	3.58	46.6	68.16	54.0	0.0	8.5
6:00	23.6	21.69	16.4	125.867	121.8	119.1	57.89	3.37	47.6	63.66	53.9	0.0	8.6
7:00	23.6	21.66	16.4	126.453	121.3	118.6	56.29	3.37	47.9	67.23	53.7	0.0	8.7
8:00	23.6	21.69	16.3	125.367	120.6	117.9	55.09	3.37	48.5	64.03	53.7	0.0	10.1
9:00	23.6	21.72	16.2	124.629	121.4	118.3	57.43	3.34	47.4	63.95	54.2	0.0	8.9
10:00	23.6	21.72	16.2	124.961	121.7	118.4	58.56	2.98	47.4	63.88	54.4	0.0	8.7
11:00	23.7	21.60	16.1	126.035	122.6	119.2	57.05	5.35	47.5	66.51	54.2	0.0	8.6
12:00	23.8	21.83	16.4	125.184	121.9	118.5	55.16	5.29	48.7	64.68	52.7	0.0	8.4
13:00	23.4	21.52	16.1	124.438	121.2	117.5	56.82	5.45	46.5	64.06	51.0	0.0	7.8
14:00	23.5	21.63	16.1	124.480	122.1	118.3	57.66	5.65	46.3	64.09	54.5	0.0	7.7
15:00	23.6	21.72	16.1	126.359	123.2	119.2	59.68	5.88	45.5	64.53	52.8	0.0	7.7
16:00	23.3	21.46	16.4	119.836	116.6	112.2	40.16	5.85	54.7	53.58	27.9	0.0	5.6
17:00	22.5	20.45	16.5	109.920	107.8	103.8	26.38	5.79	59.6	36.62	0.0	0.0	4.0
18:00	23.1	21.26	16.0	115.754	113.5	109.5	32.61	6.14	56.8	43.43	27.0	0.0	5.5
19:00	23.7	21.74	16.2	126.609	122.5	119.0	56.89	5.95	46.6	68.25	54.4	0.0	8.3
20:00	23.5	21.63	16.1	126.422	122.2	118.6	58.66	5.82	44.9	68.08	56.0	0.0	9.6
21:00	23.6	21.69	16.1	125.340	122.2	118.8	57.56	5.82	46.2	66.70	55.4	0.0	8.8
22:00	23.6	21.69	16.0	125.718	122.3	119.0	57.85	5.91	46.0	67.49	55.1	0.0	8.7
23:00	23.7	21.77	16.2	125.992	122.4	119.2	56.41	5.79	47.4	64.18	54.0	0.0	8.5
0:00	23.8	21.89	16.3	126.320	122.5	119.6	56.20	5.79	47.8	65.45	53.1	0.0	8.7
1:00	23.7	21.80	16.3	125.926	122.5	119.5	55.73	5.79	48.1	65.64	53.5	0.0	8.7
2:00	23.7	21.80	16.2	127.762	123.6	120.6	59.78	5.81	45.7	69.02	52.8	0.0	9.0
3:00	23.7	21.80	16.3	126.039	122.8	119.7	56.29	5.80	47.6	69.05	52.0	0.0	8.7
4:00	23.6	21.66	16.2	126.367	122.6	119.5	57.21	5.82	46.9	66.40	52.9	0.0	8.5
Average	23.5	21.64	16.2	124.497	121.0	117.6	54.23	5.15	48.2	63.27	49.3	0.0	8.2
Total	584.9	519.29	389.4	2987.926	2903.4	2823.2	1301.42	123.61	1157.2	1518.55	1182.0	0.1	196.6
Maximum	23.8	21.9	16.5	127.762	123.6	120.6	59.78	6.14	58.6	69.05	55.4	0.0	10.1
Minimum	22.3	20.5	16.0	109.926	107.8	103.6	25.38	2.98	44.9	36.62	0.0	0.0	4.0
Time(Max)	04:01:10			18:21:10	14:48:15	01:37:13	01:42:07	18:05:03	17:12:03	04:00:13	13:29:03	17:37:17	19:09:16
Time(Min)	16:09:10			16:39:10	16:33:16	16:37:13	17:04:06	09:10:03	06:33:03	15:28:13	15:39:03	04:00:16	17:12:16

1 X 24 MW COGENERATION PLANT GSML-Sameerwadi

08-Jan-07

DAILY PRODUCTION REPORT

TIME	GENMW	NETGEN	EXPORT	FIC101	F1202	F1400	F1401	F1402	FIC500	F1501	FIC502	F1505	F1206
	SUM	SUM	SUM	SUM	SUM	SUM	SUM	SUM	SUM	SUM	SUM	SUM	SUM
LOAD	NET	TOTAL	FW FLOW	MAIN	M S FLOW	LP STEAM	HP STEAM	CEP MIN	CST TO	CONDENSATE	HOTWELL	SPRAY	
ACTUAL	GENERATI	EXPORT	CONTROLL	STEAM	TO	FLOW	FLOW	REC	DEAERAT	FROM SUGAR	MAKE UP	WATER	
	ON		ER	BOILER	TURBINE			CONTROL	OR FLOW		FLOW	FLOW	
		MW	TPH	TPH	TPH	TPH	TPH	TPH	TPH	TPH	TPH	TPH	TPH
5:00	24.1	22.19	16.2	128.242	124.2	122.6	54.66	6.47	46.2	71.47	55.5	0.0	9.4
6:00	24.2	22.22	16.2	127.797	124.2	122.8	54.43	6.48	47.1	65.58	55.0	0.0	9.0
7:00	24.3	22.31	16.3	127.836	124.3	122.9	54.35	6.47	46.9	68.29	58.6	0.0	9.2
8:00	24.3	22.31	16.4	128.219	123.9	122.5	52.99	6.48	47.7	68.09	58.5	0.0	9.1
9:00	24.1	22.19	16.2	129.117	123.6	122.2	54.45	6.49	46.3	70.09	55.1	0.0	9.9
10:00	24.3	22.34	16.2	126.594	123.0	122.0	53.49	6.52	47.0	68.99	54.2	0.0	9.9
11:00	24.3	22.34	16.2	128.938	124.6	123.6	54.69	6.19	47.4	68.71	55.6	0.0	10.4
12:00	23.9	21.96	13.5	125.297	122.4	121.1	53.60	5.61	47.2	65.95	54.2	0.0	9.0
13:00	24.6	22.65	16.3	130.445	126.3	124.8	56.00	5.81	48.0	67.89	56.1	0.0	9.7
14:00	24.3	22.31	16.2	127.383	124.4	122.7	54.62	5.77	47.4	67.56	55.8	0.0	9.2
15:00	24.3	22.37	16.3	128.344	125.0	123.0	55.65	5.80	47.0	69.98	55.6	0.0	9.0
16:00	23.7	21.76	16.4	125.602	123.0	120.2	55.15	5.80	45.3	69.32	52.1	0.0	7.8
17:00	23.6	21.68	16.3	125.555	122.1	119.5	54.88	5.83	44.6	66.71	55.8	0.0	8.2
18:00	23.5	21.71	16.3	125.813	122.1	119.5	54.70	5.91	44.4	69.15	56.5	0.0	9.0
19:00	23.4	21.56	16.3	124.594	121.7	119.4	54.94	5.91	43.6	69.21	55.4	0.0	9.2
20:00	23.8	21.88	16.3	125.656	123.1	121.1	54.39	5.97	45.1	69.34	57.3	0.0	9.4
21:00	23.7	21.76	16.2	125.781	122.6	120.6	55.21	5.97	44.5	67.44	57.0	0.0	9.0
22:00	23.6	21.68	16.1	125.508	122.1	120.2	54.51	6.00	44.4	69.96	56.3	0.0	9.0
23:00	23.4	21.56	16.1	125.289	122.0	120.3	55.03	6.02	44.3	69.85	55.5	0.0	8.5
0:00	23.3	21.48	16.0	125.289	121.4	119.8	53.47	6.02	44.4	65.74	56.0	0.0	9.2
1:00	23.4	21.53	16.0	124.977	121.6	120.3	55.03	6.05	43.9	69.52	54.6	0.0	8.9
2:00	23.7	21.82	16.2	126.563	122.8	121.5	54.44	6.03	45.5	69.67	56.2	0.0	9.1
3:00	23.0	21.85	16.3	126.625	123.3	122.1	55.36	6.05	45.4	69.51	55.5	0.0	9.7
4:00	23.4	21.53	16.2	126.750	122.1	121.1	55.01	6.03	43.9	69.77	55.7	0.0	9.3
Average	23.9	21.95	16.1	126.759	123.2	121.5	54.64	6.07	45.7	68.62	55.8	0.0	9.2
Total	572.6	526.79	386.6	3042.211	2955.7	2916.2	1311.35	145.68	1097.4	1646.82	1339.7	0.0	221.0
Maximum	24.6	22.65	16.4	130.445	126.3	124.8	56.00	6.52	48.0	71.47	58.6	0.0	10.4
Minimum	23.3	21.48	13.5	124.594	121.4	119.4	52.98	5.61	43.6	65.58	52.1	0.0	7.8
Time(Max)	11:50:10	11:50:10	15:46:10	11:50:10	11:50:16	11:50:13	11:50:06	11:50:03	11:50:03	11:50:13	11:50:03	16:01:17	11:50:16
Time(Min)	15:43:10	15:46:10	15:45:17	15:46:10	15:44:13	15:44:13	15:46:06	10:31:03	07:18:03	10:07:13	15:50:03	04:00:17	15:46:16

D20070108REPORT