MAHARASHTRA STATE ELECTRICITY DISTRIBUTION COMPANY LIMITD Testing Division, Satara

Ref. No: EE/TEST/Satara/Tech.) 2041

Date: 11/09/2007

To,

The Executive Engineer M.S.E.D.C.Ltd.

O & M Division, Satara.

Sub: Connection checking in r/o M/s Ellora Times, Dev. No.4064, Loc No. A-23, Vankusawade.

Ref: - M-4 submitted by Dy.EE Windmill Satara vide No. 187 dt. 17.08.2007.

Connection checking of above windmill consumer was carried out by our Testing staff carried out on dt. 03/09/2007 after replacement of meter.

Details of new Meter:

Make	Elster	Pulse / Unit	Kh 1.8 wh/imp	
Sr.No	04890616	Type	Alpha S+	
S.F. For Units	100	S.F.for MD	100	
Volts	33000V/110V	Amps	5A/5A	
Ownership	Consumer	Class	0.2	
Testing No.	4445	Testing Date	20.06.2007	

Final Readings (Make - Duke Arnics, Sr.No. 17401):

	Kwh	RkVAh - G	RkVAh - D	KVAh	HKWh	ICM	ICUM
Import 935873.		138562.1	66206.0	981168.1	939845.0	59.5	2987.9 208.8
Export	xport 2863.0 923.6		4406.3	6532.7	303.5		

d. ha

Remarks:

- A) Connections to the meter were checked & found correct.
- B) Load test of new meter was carried out on load and results were found satisfactory.
- C) The overall Multiplying Factor was confirmed as 2000 units & MD with connected CT & PT as per record. (CTR 100/5A & PTR 33kV/110V)
- D) Readings were observed in H Zone hence meter is replaced.
- E) Data retrival of new meter is enclosed herewith.
- F) Meter may please be shifted in meter room.

Executive Engineer
Testing Division, MSEDCL, Satara.

T and and and and and and			
25. Vankusawade	Make		
\$3000V/310V			
1442			
	23, Vankusawade		

KCUNIT		daya		911	0.004	
		1.02000				Expusy