

Er. Abhay K. Rastogi

B.Sc., B.E. (MECH) ROORKEE, F.I.E.
CHARTERED ENGINEER (F/101830/9)
SURVEYOR & LOSS ASSESSOR (SLA 10722)
Ex. DIRECTOR, BAREILLY CORPN. BANK LTD.
PAN No. AAOPR8786J
S.T.C. No. AAOPR-8786-J-ST

Phone : Resi (0591) 2493449
Off (0591) 6535670
RIM (0591) 3291739
Mobile : 98370-33513
Email ; cool100_202@hotmail.com
A-53, LAJPAT NAGAR,
MORADABAD - 244 001.

Ref. no. 067/CE/1304
Dated 16.10.2006

INSPECTION CERTIFICATE (BOILERS)

Upon the request of Shri Sudhir Verma, Additional General Manager (Projects) of M/s The Dhampur Sugar Mills Ltd., Dhampur, Distt. Bijnor, the undersigned visited the plant on 15.10.06 to inspect the boilers installed in the unit. The boilers were physically examined and necessary records checked for the above said purpose. After completion of the assignment I have to certify as here under :-

1. Date of Inspection : Conducted on 15.10.06 at Dhampur.
2. Name of Owner : The Dhampur Sugar Mills Ltd., Dhampur, Distt. Bijnor.

Details of Boilers:-

<u>S.No.</u>	<u>Description & Specifications</u>	<u>Identification no.</u>	<u>Yr. of Installation</u>
01.	80 TPH, W.P. 64 Kg/sq. cm., Temp. 480 d.c., H.S. 4017 sq. mtr., make Babcock Wilcock	MP-3007	1994-95
02.	50 TPH, W.P. 32 Kg/sq. cm., Temp. 380 d.c., H.S. 917 sq. mtr., make John Thomson	GT-983	1991-92
03.	60 TPH, W.P. 32 Kg/sq. cm., Temp. 460 d.c., H.S. 2568 sq. mtr., make Lipi	AP.633	1992-93
04.	20 TPH, W.P. 32 Kg/sq. cm., Temp. 350 d.c., H.S. 2440 sq. mtr., make Lipi	UP-4676	1989-90
05.	30 TPH, W.P. 21 Kg/sq. cm., Temp. 350 d.c., H.S. 1252 sq. mtr., make Lipi	UP-4320	1986-87




06.	20 TPH, W.P. 16.8 Kg/sq. cm., Temp. 350 d.c., H.S. 1002 sq. mtr., make Babcock Wilcock	UP-3787	1979-80
07.	25 TPH, W.P. 16.8 Kg/sq. cm., Temp. 350 d.c., H.S. 800 sq. mtr., make Lipi	UP-3956	1982-83

Remarks & Observations:-

01. All parts of the above noted boilers have been visually checked and found to be in satisfactory working conditions.
02. The present external condition of the boilers listed above has been found to be good to the extent that expected residual life of the same is approximately 15 years at 8000 operation hours per year
03. I have no direct or indirect interest in any of the machines listed above.
04. This inspection report / certificate is being issued without any prejudice.

Place : Moradabad

Date : 16.10.2006.

Signature 
Name in Block Letters ER. ABHAY K. RASTOGI
Designation Chartered Engineer
Address A-53, Lajpat Nagar, Moradabad
Name and Address of the institution under which chartered
The Institution Of Engineers (India), 8, Gokhle
Road, Calcutta
Ref. No. & date of Corporate Membership F-101830/9
dt.26.02.1993

