

# Er. Abhay K. Rastogi

B.Sc., B.E. (MECH) ROORKEE, F.I.E.  
CHARTERED ENGINEER (F/101830/9)  
SURVEYOR & LOSS ASSESSOR (SLA 10722 )  
Ex. DIRECTOR , BAREILLY CORPN. BANK LTD.  
PAN No. AAOPR8786J  
S.T.C. No. AAOPR-8786-J-ST

Phone : Resi (0591) 2493449  
Off (0591) 6535670  
RIM (0591) 3291739  
Mobile : 98370-33513  
Email ; cool100\_202@hotmail.com  
A-53 , LAJPAT NAGAR,  
MORADABAD - 244 001.

Ref. no. 067/CE/1305

Dated 16.10.2006

## INSPECTION CERTIFICATE (TURBINE)

Upon the request of Shri Sudhir Verma, Additional General Manager ( Projects) of M/s The Dhampur Sugar Mills Ltd., Dhampur, Distt. Bijnor, the undersigned visited the plant on 15.10.06 to inspect the Turbines installed in the unit . The Turbines were physically examined and necessary records checked for the above said purpose. After completion of the assignment I have to certify as here under :-

1. Date of Inspection : Conducted on 15.10.06 at Dhampur.
2. Name of Owner : The Dhampur Sugar Mills Ltd., Dhampur, Distt. Bijnor.

### Details of Turbines:-

<u>S.No.</u>	<u>Description &amp; Specifications</u>	<u>Yr. of Installation</u>
01.	Turbine , 12.5 M.W., Working Pressure 64 Kg/sq. cm., make Siemens	2003-2004
02.	Turbine ,15 M.W., Working Pressure 32 Kg/sq. cm., make Kesel	2003-2004
03.	Turbine, 10 M.W., Working Pressure 22 Kg/sq. cm., make GEC	1995-1996
04.	Turbine ,2.5 M.W., Working Pressure 21 Kg/sq. cm., make Triveni	1990-1991

### Remarks & Observations:-

01. All parts of the above noted Turbines have been visually checked and found to be in satisfactory working conditions.



- 02. The present external condition of the Turbines listed above has been found to be good to the extent that expected residual life of the same is approximately 15 years at 8000 operation hours per year
- 03. I have no direct or indirect interest in any of the machines listed above.
- 04. This inspection report / certificate is being issued without any prejudice.



Signature *Abhay K. Rastogi*

Name in Block Letters ER. ABHAY K. RASTOGI

Designation Chartered Engineer

Address A-53, Lajpat Nagar, Moradabad

Name and Address of the institution under which chartered  
The Institution Of Engineers (India), 8, Gokhle  
Road, Calcutta

Ref. No. & date of Corporate Membership F-101830/9  
dt.26.02.1993

Place : Moradabad

Date : 16.10.2006.

- 01. Turbine, 12.5 M.W., Working make Siemens
- 02. Turbine, 15 M.W., Working Pressure 32 Kg/cm<sup>2</sup>, make Kvaer
- 03. Turbine, 10 M.W., Working Pressure 22 Kg/cm<sup>2</sup>, make GEC
- 04. Turbine, 2.5 M.W., Working Pressure 22 Kg/cm<sup>2</sup>, make Triveni

Remarks & Observations:

01. All parts of the above noted Turbines have been visually checked and found to be in satisfactory working conditions.

