

Never CE 00



SUZLON ENERGY LTD.



December 16, 2005

M/s. Kilburn Chemicals Ltd
A-81, SIDCO Industrial Estate
Southveerapandiapuram
Tuthookudi - 628 008.
Phone No. 0461 2340491 (4 lines)

104, Delta Wing, 1st Floor, Raheja Towers
177, Anna Salai (Mount Road)
Chennai - 600 002, India

P : +91-44-28602345 / 28602349
F : +91-44-28602350
E : chennai@suzlon.com
U : www.suzlon.com

Kind Attn: Mr. M N Krishnan. VP Works.

Doc : ③

Dear Sirs,

We have recd your mail on 15.12.05 only. We regret for not able to visit you on 15.12.05 because our Customer Care person is held up and hence we could able to meet you any how we are meeting you on 20.12.05 with all your required clarifications. We wish to reply as under for your mail dated 15.12.05 on point wise.

1. To deal the Carbon Credit for all our client installations our associate company Synergy Global from New Delhi is handling under the head of Dr. Ajay Mathur, and their contacts details are given below and we also request them to contact you for further action on CDM. We request you to correspond to them directly for better and quicker response.

Mr. Ajay Mathur / Mr. S.Naveen, Manager (Operations)
Senergy Global Pvt. Ltd
D-33, Defence Colony
New Delhi - 110 024.
Tel : 11-2465 5141/2/3
Fax : 11-5163 4201/2465 5144 / Mob : 98185 69933
E-Mail: am@senergyglobal.com / ns@senergyglobal.com

2. We expect your WTG shall be able to connect to our proposed CMS by mid February 2006 which is under construction as per our O&M department.
3. The % age of the machine availability is assured by on annual basis and assure you that the committed figure shall be given to you on annual basis. Hence we request you to not to monitor this on monthly basis.
4. We do agree initially there were setting problem and are now rectified in SCS and now it is functioning as satisfactorily. We already sent you the additional feature of the SCS panels over our earlier supplies.


① of ②

5. Normally any WTG initially might be running with erratic evacuation condition and hence the zero date of the starting period shall be shifted after may be 2/3 months period for the annual generation calculation purpose and we are confident this WTG shall reach the expected annual output at our controller on the given condition.
6. We shall provide the actual monthly generation details of the some other WTG on the same area for a year for your reference purpose.
7. We expect an annual generation shall be 34 lacs units at the WTG controller at 100% grid and an assured 95 % m/c availability with the respect to the wind variable class applicable to the reference wind data.
8. The warranty period for your project was given based on all commercial aspects and is regret to extend the warranty period.
9. The expected annual generation for your proposed next WTG shall be discussed in person during the discussion to be held on 20.12.05.
10. We have already sent you the additional feature of our new panel boards.
11. The substation for you new WTG shall be linked to Keelaveeranam SS.

Trust the above will clarify all your queries.

Thanking you,

Yours faithfully,
for SUZLON ENERGY LIMITED


S. Chandrakasan
Manager – Marketing