

O & M DIVISION, NANDURBAR

EE/NDBR/Tech/Wind/ 0008

Date: 02.01.2006

To,

The Superintending Engineer,

Maharashtra State Electricity Distribution Company Ltd.,

O & M Circle,

Dhule: 424 002.

Subject: Commissioning of 3 X 1250 kW Wind Electric Generators in respect
M/S D. J. Malpani, at Location no. K400, K401 and K412, R. S. No.
 168, 161 and 375, Village: Mandal, Taluka: Nandurbar, District: Nandurbar

Reference:

1. Letter No. AE/NDBR/Tech/Wind/02 dated 02.01.2006
2. Letter No. SE/DHL/T WIND/5789 dated 31.12.2005
3. H. O. Letter No. DIR (O)/Suzlon/26979 dated 19.08.2005
4. H. O. Letter No. Dir (O)/810 dated 22.08.2005

With the reference to above, this is to inform you that 3 X 1250 kW Wind Electric Generators, in respect of **M/S D. J. Malpani, at Location no. K400, K401 and K412 R. S. No. 168, 161 and 375, Village: Mandal, Taluka: Nandurbar, District: Nandurbar** has been commissioned in presence of representative The Superintending Engineer, O & M Circle, Dhule, The Executive Engineer, O & M Division, Nandurbar, The Assistant Engineer, O & M Sub Division, Nandurbar, representative of MEDA and representative of customer.

The details of connection are as under:

| | | |
|---|-------------------|-----------------------------------|
| 1. Wind Turbine Generator: | | Commissioned on 31.12.2005 |
| Village: Mandal, Taluka: Nandurbar, District: Nandurbar | | |
| Location: K -400 | R. S. No.: 168 | No. of WTG: 1x1250 kW |
| Make: Siemens Ltd. | Sr. No.: 64026131 | Output: 300 / 1250 kW |
| Frequency: 50 HZ | Current: 1175 A | Voltage: 690 V |

| | | |
|---|------------------|-----------------------------------|
| 2. Wind Turbine Generator: | | Commissioned on 31.12.2005 |
| Village: Mandal, Taluka: Nandurbar, District: Nandurbar | | |
| Location: K -401 | R. S. No.: 161 | No. of WTG: 1x1250 kW |
| Make: Siemens Ltd. | Sr. No.: 6402636 | Output: 300 / 1250 kW |
| Frequency: 50 HZ | Current: 1175 A | Voltage: 690 V |