

Commissioning Certificate (MSEDCL)

Photocopy

Dhulia (Ph- I), Location No.: K 413

↓ COMPANY LTD.

O & M CIRCLE, DHULE

SE/DHL/Tech/Wind/ No 3 03 7

Date: 17 अक्टूबर 2006

To,
M/s. D. J. Malpani,
Malpani House, I. G. Road,
Sangamnagar-422 605, Dist: Ahamadnagar

Subject: Commissioning of 1 X 1250 kW Wind Electric Generator in respect of
M/S D. J. Malpani, at Location no. K413, R. S. No. 378,
Village: Mandal, Taluka: Nandurbar, District: Nandurbar

Reference:

1. MEDA Letter Reference No. WFP/ D. J. Malpani /7.5MW Ph-II/NP/05-06/6605 dated 30.12.2006
2. Letter No. EE/NDBR/Tech/Wind/1567 dated 15.04.2006
3. Letter No. SE/DHL/T WIND/2150 dated 23.03.2006
4. H. O. Letter No. DIR (O)/MSEDCL/193 dated 03.03.2006
5. H. O. Letter No. DIR (O)/MSEDCL/04613 dated 21.02.2006
6. H. O. Letter No. DIR (O)/Suzlon/26979 dated 19.08.2005
7. H. O. Letter No. Dir (O)/810 dated 22.08.2005

With reference to above, this is to inform you that 33 kV Supply, 1 X 1250 kW Wind Electric Generator & Transformer in respect of M/S D. J. Malpani, at Location no. K413, Village: Mandal, Taluka: Nandurbar, District: Nandurbar has been commissioned on 26.03.2006 in presence of representative of The Superintending Engineer, O & M Circle, Dhule, representative of The Executive Engineer, O & M Division, Nandurbar, representative of The Assistant Engineer, O & M Sub Division, Nandurbar, representative of MEDA and representative of customer.

The details of Wind Electric Generator are as under:

1. Wind Turbine Generator:		
Village: Mandal, Taluka: Nandurbar, District: Nandurbar		
Location: K 413	R. S. No.: 378	No. of WTG: 1x1250 kW
Make: Siemens Ltd.	Sr. No.: 64030343	Output: 300 / 1250 kW
Frequency: 50 HZ	Current: 1175 A	Voltage: 690 V