

Commissioning Certificate & Amendment (MSEDCL)

Photocopies

Dhulia (Ph- II), Location No.: K 118

COMPANY LTD.

O & M CIRCLE, DHULE

SE/DHL/Tech/Wind/ NO 2997

Date: 17 APR 2006

To,
M/s. D. J. Malpani,
Malpani House, I. G. Road,
Sangamnagar-422 605, Dist: Ahamadnagar

Subject: Commissioning of 1 X 1250 kW Wind Electric Generator in respect
of **M/S D. J. Malpani, at Location No. K118, R. S. No. 43,**
Village: Titane, Taluka: Sakri, District: Dhule.

Reference:

1. MEDA Letter Reference No. WFP/ D. J. Malpani /2.25MW Ph-I/05-06/191 dated 24.03.2006
2. Letter No. EE/DHL/Tech/Wind/2113 dated 15.04.2006
3. Letter No. SE/DHL/T WIND/2416 dated 27.03.2006
4. H. O. Letter No. DIR (O)/MSEDCL/193 dated 03.03.2006
5. H. O. Letter No. DIR (O)/MSEDCL/04613 dated 21.02.2006
6. H. O. Letter No. DIR (O)/Suzlon/26979 dated 19.08.2005
7. H. O. Letter No. Dir (O)/810 dated 22.08.2005

With reference to above, this is to inform you that 33 kV Supply, 1 X 1250 kW Wind Electric Generator & Transformer in respect of **M/S D. J. Malpani, at Location No. K118,** Village: Titane, Taluka: Sakri, District: Dhule has been commissioned on 29.03.2006 in presence of representative of The Superintending Engineer, O & M Circle, Dhule, representative of The Executive Engineer, O & M Division, Dhule, representative of The Assistant Engineer, O & M Sub Division, Sakri, representative of MEDA and representative of customer.

The details of Wind Electric Generator are as under:

1. Wind Turbine Generator:		
Village: Khor, Taluka: Sakri, District: Dhule		
Location: K -118	R. S. No.: 43	No. of WTG: 1x1250 kW
Make: Siemens Ltd.	Sr. No.: 64035246	Output: 300 / 1250 kW
Frequency: 50 HZ	Current: 1175 A	Voltage: 690 V