(By submitting	ctivity issuance review form this form, a Party involved (through the designated national n Executive Board member may request that a review is undertaken)	
Designated national authority/Executive Board member submitting this form (Name in print)		
Title of the proposed CDM project activity for which issuance is requested	La Esperanza Hydroelectric Project (0009)	
DOE that requested for issuance and date of request	DNV - 04/06/08	
Please indicate, in accordance with you request review. (Place a cross	paragraphs 65 of the CDM modalities and procedures, for which reason(s) (X) in front of the reason)	
Fraud Malfeasance	eX_ Incompetence	
Please indicate reasons for the request for review and attach any supporting documentation to this request form. (if space is not sufficient please attach further reasons)		
The PDD states that in Phase 1A,	1B and 2 the installed capacities will be 485 kW, 785 kW, and 11.5	
MW, respectively. The DOE verif	ied that the actual nameplate capacities for the respective phases are	
500kW, 900 kW, and 11.5 MW w	hile the monitoring report states that the installed capacities are 500kW,	
1MW, and 12MW. Clarification is	required as to the reason for these changes from the PDD and the	
inconsistencies in the description of	of the capacity.	

02.06.2008

Version	01

Section below to be filled in by UNFCCC secretariat

Date received at UNFCCC secretariat