

 CDM project activity issuance review form <i>(By submitting this form, a Party involved (through the designated national authority) or an Executive Board member may request that a review is undertaken)</i>	
Designated national authority/Executive Board member submitting this form (Name in print)	
Title of the proposed CDM project activity for which issuance is requested	0098 4.5 MW Maujhi Grid-connected SHP in Himachal Pradesh, India
DOE that requested for issuance and date of request	DNV 11.09.2007
Please indicate, in accordance with paragraphs 65 of the CDM modalities and procedures, for which reason(s) you request review. (Place a cross (X) in front of the reason)	
<input type="checkbox"/> <i>Fraud</i> <input type="checkbox"/> <i>Malfeasance</i> <input checked="" type="checkbox"/> <i>Incompetence</i>	
Please indicate reasons for the request for review and attach any supporting documentation to this request form. (if space is not sufficient please attach further reasons)	
<p>1. The verification report contains inconsistent statement regarding the frequency of calibration of the meters: "the calibration of the electricity meters is being done regularly every six months and have been verified by DNV"(page 4) and "calibration process is followed as per defined procedures and carried out annually and the calibration certificates of the instruments used for data monitoring and recording were also verified during the site visit"(page 5). Clarification is required.</p>	
Section below to be filled in by UNFCCC secretariat	
Date received at UNFCCC secretariat	04/10/2007