

TAG No.	F7-6002
---------	---------

[illegible]

Tag No.



Tamil Nadu Newsprint and Papers Limited,

KAGITHAPURAM - 639 136. Karur Dt. Tamilnadu.

INSTRUMENT CALIBRATION RECORD

INST/F-05.

Tag Number : FT-6002 Quality Plan Number : INST/N/64
Make : INCONEL Work Instruction Number : INST/W/106.01
Model : 3069-30W Calibrated Range : 0 - 1200M³hr
Master Instruments : SELF

Input	Output		
Engineering Units %	Expected MA	Actual	
		Before Calibration MA	After Calibration MA
0	4.00	4.00	4.00
25	8.00	8.00	8.00
50	12.00	12.00	12.00
75	16.00	16.00	16.00
100	20.00	20.00	20.00

Old Calibration constants : NA

New Calibration constants : NA

Calibrated on : 9.10.07

Reviewed on : 9.10.07

Calibrated by : D. Rameshndran

Reviewed by : P. Kandan



Tamil Nadu Newsprint and Papers Limited,

KAGITHAPURAM - 639 136. Karur Dt. Tamilnadu.

INSTRUMENT CALIBRATION RECORD

INST/F-05.

Tag Number : FT- 6002 Quality Plan Number : INST/N/64
Make : INCONEL Work Instruction Number : INST/W/106.01
Model : 3069-30W Calibrated Range : 0 - 1200 M²/Hr.
Master Instruments : SELF

Input	Output		
Engineering Units %	Expected MA	Actual	
		Before Calibration MA	After Calibration MA
0	4.0	4.0	4.0
25	8.0	8.0	8.0
50	12.0	12.0	12.0
75	16.0	16.0	16.0
100	20.0	20.0	20.0

Old Calibration constants : NA

New Calibration constants : NA

Calibrated on : 10.4.07

Reviewed on : 10.4.07

Calibrated by : D. Ramani

Reviewed by : P. Kandam



Tamil Nadu Newsprint and Papers Limited,

KAGITHAPURAM - 639 136. Karur Dt. Tamilnadu.

INSTRUMENT CALIBRATION RECORD

INST/F-05.

Tag Number : FT-6002 Quality Plan Number : INST/N-64
Make : INCONEL Work Instruction Number : INST/W/106.01
Model : 3069-30W Calibrated Range : 0 - 1200 M²/hr
Master Instruments : SELF

Input	Output		
Engineering Units %	Expected M.A	Actual	
		Before Calibration M.A	After Calibration M.A
0	4.0	4.0	4.0
25	8.0	8.0	8.0
50	12.0	12.0	12.0
75	16.0	16.0	16.0
100	20.0	20.0	20.0

Old Calibration constants : NA

New Calibration constants : NA

Calibrated on : 29.10.06

Reviewed on : 29.10.06

Calibrated by : D. Ramesh

Reviewed by : P. Kandasamy