

History Card-Field Instruments.

[illegible]

Tag No.



Tamil Nadu Newsprint and Papers Limited,

KAGITHAPURAM - 639 136. Karur Dt. Tamilnadu.

INSTRUMENT CALIBRATION RECORD

INST/F-05.

Tag Number : FT-6009 Quality Plan Number : INST/N-64
Make : TATA HONEY WELL Work Instruction Number : INST/W/34/401
Model : STD-120-EIH-0000 Calibrated Range : 0-1200 MMWC
Master Instruments : SFC - STD 120

Input	Output		
Engineering Units	Expected MA	Actual	
		Before Calibration MA	After Calibration MA
0	4.00	4.00	4.00
25	8.00	8.00	8.00
50	12.00	12.00	12.00
75	16.00	16.00	16.00
100	20.00	20.00	20.00

Old Calibration constants : NA

New Calibration constants : NA

Calibrated on : 9.10.07

Reviewed on : 9.10.07

Calibrated by : D. Ramachandran

Reviewed by : P. Kandasamy



Tamil Nadu Newsprint and Papers Limited,

KAGITHAPURAM - 639 136. Karur Dt. Tamilnadu.

INSTRUMENT CALIBRATION RECORD

INST/F-05.

Tag Number : FT-6009 Quality Plan Number : INST/N/64
Make : TATA HONEY WELL Work Instruction Number : INST/W/3.4 4.01
Model : STD 120-EIH-00000 Calibrated Range : 0-1200 mmwc
Master Instruments : SFC-STD 120

Input	Output		
Engineering Units %	Expected MA	Actual	
		Before Calibration MA	After Calibration MA
0	4.0	4.0	4.0
25	8.0	8.0	8.0
50	12.0	12.0	12.0
75	16.0	16.0	16.0
100	20.0	20.0	20.0

Old Calibration constants : NA

New Calibration constants : NA

Calibrated on : 10.4.07

Calibrated by : D. R. Ramesh

Reviewed on : 10.4.07

Reviewed by : P. R. Ramesh



Tamil Nadu Newsprint and Papers Limited,

KAGITHAPURAM - 639 136. Karur Dt. Tamilnadu.

INSTRUMENT CALIBRATION RECORD

INST/F-05.

Tag Number : FT-6009 Quality Plan Number : INST/N-64
Make : TATA MONEY WELL Work Instruction Number : INST/W/3,4 401
Model : STD 120 - E14 - 0000 Calibrated Range : 0 - 1200 MM WC
Master Instruments : SFC - STD 120

Input	Output		
Engineering Units %	Expected MA	Actual	
		Before Calibration MA	After Calibration MA
0	4.0	4.0	4.0
25	8.0	8.0	8.0
50	12.0	12.0	12.0
75	16.0	16.0	16.0
100	20.0	20.0	20.0

Old Calibration constants : NA

New Calibration constants : NA

Calibrated on : 29.10.06

Reviewed on : 29.10.06

Calibrated by : D. Ramiah

Reviewed by : P. Kandiah