

ANNUAL REPORT OF THE MONITORING PLAN**"CDM Project 0141: ABANICO HYDROELECTRIC PROJECT"**
PERIOD: MARCH 1, 2007-FEBRUARY 29, 2008

| | |
|---|--|
| PROJECT NAME | ABANICO HYDROELECTRIC PROJECT |
| INSTALLED CAPACITY | 37.50 MW |
| PARTICIPANTS | HIDROABANICO S.A.-Operator IBRD-Netherlands Clean Development Mechanism Facility |
| TECHNICAL DESCRIPTION OF THE PROJECT | |
| Project Location | Ecuador |
| Region/Province/City | South America/ Morona Santiago/ northeast of the city of Macas |
| Project Activity | Hydroelectric Power Generation |
| Energy Supply | Renewable Energy |
| Greenhouse gases targeted | CO ₂ |
| Type of activities | Abatement |
| Project Description | <p>Hydroelectric Power Generation connected to the grid. Abanico is a run off river mini hydro-plant, this means that it doesn't have a reservoir, the water intake will be at the edge of the river, it has rubble and sand collecting devices and a cargo tank that is placed at the end of the sand-collecting device connected to tunnel that works under low pressure. At the end of the tunnel a pressure pipe is located and connected to a turbine room, which includes the infrastructure to discharge the turbine water.</p> <p>The project was built in 2 phases the first one for 15MW. In this phase Hidroabanco built all of the civil works for both phases (water intake, rubble and sand collecting devices, cargo tank, tunnel and infrastructure for discharge) and the electromechanical for the first phase (pressure pipe, turbine room for 2 turbines and 2 generators, Hidroabanco substation 1, transmission line of 12Km and Hidroabanco Substation 2 (69KV).</p> <p>The second phase for 22.50MW essentially was for electromechanical works (installation of the 2nd pipe pressure parallel to the first one, commissioning and start up for 3 more turbines and generators, and expansion of the Hidroabanco Substation 1 and 2.</p> <p>The civil works for the second phase includes the expansion of the turbine room and the 2nd infrastructure for discharge. According to the Constructor Progress Report at July 2007 (See Annex 1), the construction of the second</p> |

| | |
|-----------------|--|
| | <p>phase was finished and the activities developed in July 2007 were the commissioning and start up.</p> <p>The commissioning and start up was coordinated with Cenace. Once these activities were finish Cenace authorized to Hidroabanico the Commercial Operation of the second phase from 18:21 of July 18th, 2007 (See Annex 2).</p> |
| Technology used | <p>Five (5) Pelton turbines of 7.5MW-WKV</p> <p>Five (5) Generators-AVK</p> <p>Transmission line, from the turbine room to the Hidroabanico Substation 2 (12Km) located in Macas.</p> |

1. DESCRIPTION OF THE METHODOLOGY USED

The Project uses the "Consolidated baseline methodology for grid-connected electricity generation from renewable resources" UNFCCC/CCNUCC; ACM 0002 / Version 3; Sectoral Scope 01; September 30, 2005.

The baseline emission factor (EF) is calculated as a combined margin (CM) consisting of a convex combination of the operating margin (OM) and the build margin (BM) factor.

- The OM is calculated ex-ante, using the Simple Adjusted OM Method.
- The BM is calculated ex-ante, Option 1, using the most recent projects that produce 20% of the national generation.
- The CM margin is made equal to the simple average of the OM and the BM.
- The CM is multiplied by annual project generation. This is the new baseline emission.

According to the approved methodology used in the registered PDD we obtained the following results:

$$OM = 0.62633 \text{ tCO}_2 / \text{MWh}$$

$$\text{Average Lambda} = 0.0004$$

$$OM = (1-0.0004)*0.62633 = 0.626 \text{ tCO}_2 / \text{MWh}$$

$$BM = 0.607 \text{ tCO}_2 / \text{MWh}$$

$$CM = 0.6165 \text{ tCO}_2 / \text{MWh}$$

2. QUALITY CONTROL (QC) AND QUALITY ASSURANCE (QA) PROCEDURES UNDERTAKEN FOR DATA MONITORED

Monitoring Records:

The registered PDD requires to provide a continuous (hourly) registry of electricity generation both directly from the project as well as from CENACE, the dispatch operator, and to compare both set of data.

HIDROABANICO recorded generation data every 15 minutes from the measurement equipment installed in the substation Hidroabanico No. 2 located in Macas.

The Plant Operator has a daily routine to download the meter data of the day before and

posted in the CENACE commercial webpage and also to CENACE Operations Department. In case that the plant operator identified anomalies with the data posted in the CENACE webpage versus Hidroabanico data he call to CENACE's commercial department to identify and discuss the reason of the possible differences.

CENACE, which is non-profit Private Civil Corporation, is responsible for the dispatch of power plants. Ecuadorian regulations require that all plants supplying energy to the national grid shall be directly dispatched by CENACE. The dispatch is done under criteria aimed at minimizing generation costs. Spot Market prices for power transfers that are not under supply contracts are established by CENACE on the basis of hourly marginal system costs for available capacity and energy.

CENACE downloads the generation data of Abanico Hydroelectric Plant every 15 minutes through a modem connected to a telephone line in the substation Hidroabanico No. 2. CENACE posts daily information of all generators in the webpage www.cenace.org.ec in the link "Información Transaccional del MEM/Medición Comercial". (See Annex 3, File: HA Generation Mar 07-Feb 08.xls).

The Regulatory Agency CONELEC makes publicly available the annual total generation reports by plant in their webpage: www.conelec.gov.ec. The Statistics of the Ecuadorian Electric Sector, using CENACE's information and information of the Power Market Agents, such as HIDROABANICO. However, CONELEC only publishes this consolidated information with a six months delay; hence, consolidated annual report for year 2007 will be available in June 2008.

Calibration of Measurement Equipment:

According with local regulations CENACE calibrates the electrical meters; first, Hidroabanico send the meters to CENACE's offices and their technicians calibrate the equipment then a document is signed between CENACE and HIDROABANICO for each meter. This procedure is for the first time before the commercial operation of the Plant.

To renew the calibration CENACE designate a technician for a site visit and he calibrates the meters at the substation. In Annex 4 will see the CENACE's Official calibration Document.

The meters calibration expired in December 2007, HIDROABANICO request to CENACE the new calibration on December 12th, 2007 (See Annex 5). CENACE expressed that they don't have enough personnel therefore they sent the technician just on February 20th, 2008.

In the Substation Hidroabanico 2 we have installed four meters with the following characteristics:

Brand: MAXSYS 2510

Type: Bidirectional (the measurements is in 2 ways)

Class: Precision 0.2%

The meters fulfill all of the specifications required from CENACE.

Site Audits:

The Operation Manager and the Superintendent make regular site visits to supervise the plant operator actions.

Operation and Maintenance of the Meters:

The Plant Operator based on the Operation and Maintenance Manual and the Maintenance Schedule has all the data for the service sheets, which includes: Maintenance Description of the equipment, causes, date and responsibility signature of the operator.

Of the four metes installed in the Hidroabanico Substation 2, the purpose of the 4th meter is to

be a backup of the principal. When Hidroabanco receive the meters, the 4th meter with serial number 90.222.536 it was not work properly, thus Hidroabanco sent it back to the supplier to repair. Temporarily they sent a meter whit serial number 86.370.178, which was accepted by CENACE.

In 2006 our supplier sent the meter repaired with serial number 90.222.536 and CENACE calibrate it. After that Hidroabanco installed it in the Hidroabanco Substation 2 whit the acceptance by CENACE. That is why CENACE calibrates the 4 meters on February 20th, 2008 without comments.

During the period March 1, 2007-February 29, 2008 there was one maintenance to the meters in July 2007 in order to change the setting of the relation of the current transformers because of the new generation for the second phase.

3. CERs CALCULATION

Period March 1, 2007-February 29, 2008

| Project | Annual MWh |
|----------------|-------------------|
| Abanico | 241,557 |

Combined Margin

| Project | Combined Margin |
|----------------|------------------------------|
| Abanico | 0.6165 tCO ₂ /MWh |

Annual CERs

| Project | Annual MWh*Combined Margin |
|----------------|-----------------------------------|
| Abanico | 148,920 tCO ₂ |

Base on the data shown above, the net annual emission reduction is 148,920 tCO₂ for Phase I and II.

4. SUSTAINABLE DEVELOPMENT MONITORING PLAN

4.1. Environmental Sustainability

Revegetation:

Hidroabanco planted 800 trees during 2006 and 3,700 trees during 2007 near to the diversion of the river and the area of the Power House, and also grass along of the Right Of Way (ROW) of the pipe pressure. The following are the percentages of revegetation by area of the project according to the last environmental monitoring at December 2007:

Diversion of the River: 75%

ROW of the pipe pressure: 60%

Power House and discharge of turbine water: 95%

Transmission Line: 100%

In average the revegetation of the project including grass is 82.50% according to the taken part areas for the construction of the project.

REVEGETATION REPORT

| Tree Name | Numbers of plants planted July 2007 | Numbers of plants dead December 2007 |
|------------------|--|---|
| Poma Rosa | 650 | 298 |
| Sangre de drago | 635 | 250 |
| Pingüe | 745 | 276 |
| Balsa | 150 | 85 |
| Aliso | 896 | 357 |
| Nacedero | 215 | 113 |
| Melastomatáceas | 589 | 321 |
| Cedro | 417 | 82 |
| Eritrina | 121 | 48 |
| Laurel | 44 | 9 |
| Guayacán | 12 | 5 |
| Guabas | 180 | 98 |
| Canelo | 24 | 11 |
| TOTAL | 4278 | 1953 |

According to the survival of the trees planted (as shown in the table above) the revegetation only for trees excluding grass is 45.65%

The following pictures show the project and the progress for the revegetation of it:



Picture 1: Power House



Picture 2: Turbines & Generators (5 Units)



Picture 3: Revegetation of the discharge area.



Picture 4: Revegetation of the Power House Area




Picture 5: Revegetation of the diversion of the river



Picture 6: Revegetation of ROW of the pipe pressure

Erosion Control:

Hidroabanico cleaned the channel of the stream in the area of the exit of the tunnel, towards to the right side of the ROW, accommodating the material inwards of the same one. Once the material has been controlled we constructed the sediment traps, according to the following scheme:



Discharges:



The turbine water is currently discharged through a tailrace pipe and an energy dissipater in the Balaquepe River, according to the hydraulic studies; Hidroabanico to avoid erosion at the outlet in the Balaquepe River executed the following construction works:

Reinforcements and stabilization, using a mixed formula in forms of gabions, concrete, metallic and geo-synthetics elements. This works had been made in order to have a flood protection in several areas.

To avoid the erosion in the Balaquepe River Hidroabanico constructed 42 rapids to stabilized the vulnerable areas dissipating the flow energy.

Currently all of this works are finished and the river now is an excellent site for ecological tourism, such as kayaking as shown in the following pictures





4.2. Socio-Economic Sustainability

In depressed areas, the project stabilizes the national electrical system especially in the Macas zone, allowing the local population to have a more reliable and available electrical system.

Employment:

During the construction period for Phase I Hidroabanico hired approximately 300 workers, and 200 for Phase II, 30% was hired from the local population. The following charts show the number of workers hired:





Permanent Work: For the Operation and Maintenance period 25 local laborers have been hired to keep de roads and drains clean and operative and the maintenance for the equipment.

Purchases from local suppliers

Up to date Hidroabanico has disbursed approximately USD 3.000.000 in Macas and bordering communities for services and locally provided materials such as: lodging, food, bus, trucks, light trucks, gravelly material, doors, windows, rubblework, materials of ironworks, equipment, among others.

Scholarships and internships

As a part of the environmental promotion and educational program Hidroabanico hired 6 students from the University in Macas to impart environmental chats in Jimbitono and 9 de Octubre communities, which includes how to improve the community production systems.

For 2007 Hidroabanico provided 3 scholarships of investigation. They correspond to works in flora, amphibians and mammals with three students of the School of Biology of the Central University of Ecuador. At December 2007 they finished their investigation and HIDROABANICO will publish in 2008 the results in a book.

Community Programs

During 2007 Hidroabanico implemented the following programs with a cost of approximately USD 52.000:

- Chicken Farms production whit Women Association of Proaño.
- Construction of access road to Balaquepe River for the owners of the farms
- Mingas: this is the name of community work for community benefit. Hidroabanico promotes this kind of work.
- Construction of the Public Lighting System for Jimbitono and farms in Balaquepe River.

Additional Benefits

Hidroabanco signed an agreement with the Municipality of Morona to construct the conduction of the turbinated water to Macas as a part of the potable water project, which is the main problem of the city of Macas; also Hidroabanco will provide a treatment water plant. (Following picture). The investment cost for both projects are approximately USD 450.000. Both projects are already finished and received by the Municipality.



Hidroabanco will pay annually through the Municipality of Morona for the period of the concession an amount of USD 80.000 to the nearest community of the project (Jimbitono) in order to develop several programs. HIDROABANICO already paid USD 240.000, which corresponds payments for 2006 to 2008.

One of the main shareholders of Hidroabanco donates 50% of their annual Income Tax to the Municipality of Morona.

5. IMPLEMENTATION OF THE SECOND PHASE (22.50MW)

The implementation of the second phase with a capacity addition of 22.62 MW according to the registered PDD has to be done in January 2008. Although Hidroabanco finished the construction, commission and start up of the plant earlier in July 2007.

The second phase add three new Pelton turbines for a total capacity of 22.50 MW (3 x 7.5 MW), which means that the total capacity of the Abanico Hydroelectric Project is 37.50 MW since in the first phase the installed capacity was 15 MW, consequently the total power output have not been modified and is finally implemented as is stated in the registered PDD.

The commissioning and Start up was fully coordinated with Cenace. Once these activities were finish Cenace authorized the Commercial Operation of the second phase from 18:21 of July 18th, 2007 as can be seen in the official letter in Annex 2.

ANNEX 1
Sipetrol's Progress Report at July 2007



MENSUAL
EPC II + REPOTENCIACION LT Macas – Gualaceo
PROYECTO HIDROELÉCTRICO ABANICO

JULIO 2007



INDICE

1. Resumen Ejecutivo
2. Alcance del Contrato
3. Avances en la Ejecución Del Proyecto
 - 3.1 Curva S (%) de Avance Acumulado
 - 3.2 Curva S (US\$) de Gastos Acumulados.
 - 3.3 Gastos Presupuestados, Gastos Teóricos Segundo Avance, y Gastos Reales
 - 3.4 Diagrama De Gantt del Proyecto con Avances
 - 3.5 Frentes de Trabajo
 - 3.6 Horas – Equipo
 - 3.7 Horas – Hombre
4. Reporte de Producción
5. Fotografías

1. RESUMEN EJECUTIVO

1.1 Frentes de Trabajo


Durante el mes de Julio 2007 de trabajó en los siguientes frentes:

- Frente de Trabajos Civiles río Balaquepe, reconformación y protección
- Pruebas y Comisionado de la Central
- Limpieza General y Desmovilización

1.2 Avance (%).

Al 30 de Julio la obra registra un avance real ponderado del **93.1 %** respecto al **100%** del avance programado y **94%** del avance re-programado debido al desfase de la obra.

La obra no ha llegado al 100% de avance debido a los trabajos que faltan ejecutar en lo que se refiere a Repotenciación de las subestaciones de Limón – Méndez y Gualaceo. Dichos trabajos y su porcentaje de avance se detallan en el Reporte de Producción de julio 2007 (Anexo 2) y en el documento de Pendientes previa Entrega – Recepción del EPC II (Anexo 3).



2. ALCANCE DEL CONTRATO EPC II (SIPETROL S.A.)

Diseño.

Es Parte del Alcance de Sipetrol S.A. los diseños definitivos de Construcción de la segunda etapa de la Central Hidroeléctrica Abanico, en base a los diseños preliminares efectuados por Caminosca S.A.

Para ello Sipetrol S.A. combina auto-gestión con profesionales propios, tercerización de geotecnia de detalle y cálculo de cimentaciones profundas con MGA (Marcelo Asanza), diseños hidráulicos con Caminosca S.A. y diseños estructurales de Casa de Máquinas con Juan Carlos Garcés.

Los diseños eléctricos de Líneas de Transmisión y Subestaciones se ejecuta en un trabajo conjunto con la firma Ingeniería & Diseño de Colombia.

Suministro.

Es parte del Alcance de Sipetrol S.A. la fabricación y suministro de los siguientes elementos:

Válvulas para Tubería de Conducción.

Protección Catódica Tubería.

Consumibles para instalación de Tubería.

Estructura, Cubierta y Paredes de Casa de Máquinas.

Vigas Carrileras Casa de Máquinas.

Cable Trays y Grating Casa de Máquinas.

Cables de Puesta a Tierra para Casa de Máquinas.

Iluminación Interior para extensión de Casa de Máquinas.

Estructuras para SE HA2

Equipos de Patio SE HA2 incluyendo Trafo 69/138.

Paneles de Control SE HA2

Cables y Accesorios SE HA2

Estructuras para SE Limón, Méndez y Gualaceo

Equipos de Patio SE Limón, Méndez y Gualaceo, incluyendo trafos.

Paneles de Control SE Limón, Méndez y Gualaceo

Cables y Accesorios SE Limón, Méndez y Gualaceo.

Accesarios y Conductor para repotenciación de LT HA1 - HA2

Accesarios y Aisladores para repotenciación de LT Macas – Limón.

Hierro para Hormigones.

Agregados para Hormigones.

Cemento / Aditivos de Hormigón.

Lastre.




Construcción

La Construcción de la segunda etapa de la Central Hidroeléctrica Abanico incluye los siguientes rubros principales:

- § Movimiento de Tierras aprox. 100,000 m³.
- § Fundición de Hormigón Armado, aprox. 4,000 m³.
- § Tubería de Presión, 2200 ml, 1.80m diámetro.
- § Casa de Máquinas y Obra de descarga de aguas turbinadas.
- § Obras en el Río Balaquepe.
- § Extensión del Edificio de Casa de Máquinas.
- § Montaje de Equipo Hidromecánico y Mecánico en C. Máquinas
- § Montaje de Equipo Electromecánico en C. Máquinas y SE HA1.
- § Repotenciación Línea de Transmisión HA1-HA2.
- § Repotenciación Línea de Transmisión Macas – Limón.
- § Bahía 138KV en Subestación SE-HA2 (Macas).
- § Subestaciones Limón, Méndez y Gualaceo.
- § Comisionado y Puesta en Marcha.

3. AVANCES EN LA EJECUCIÓN DEL PROYECTO

3.1 Curva S de Avance



3.2 DIAGRAMA DE GANTT DEL PROYECTO CON AVANCES Adjunto como Anexo 1.



3.3 FRENTES DE TRABAJO

Durante el mes de Julio 2007 se trabajó en los siguientes frentes:

Pruebas y Comisionado de la Central

- Comisionado Tableros de control Unidad 3,4,5 (Chequeo de correcto funcionamiento)
- Comisionado Tableros Medio Voltaje (Chequeo de correcto Funcionamiento)
- Comisionado Tableros de servicios auxiliares AC y DC (Chequeo correcto funcionamiento)
- Comisionado Generadores (Pruebas eléctricas)
- Comisionado mecánico (ajuste de tiempo de inyectores y válvula mariposa)
- Comisionado mecánico (Toma de datos para registro de los rodetes de las unidades 3, 4, 5)
- Pruebas transformador.

Río Balaquepe

- Reconformación y Protección de Ribera con gaviones (piedra bola + cemento)

3.4 HORAS – EQUIPO

3.4.1 Equipo Pesado y Equipo Menor Movilizado a Obra.

| Equipo Pesado | Movilización | Desafectación | Desmovilización |
|---|--------------|---------------|-----------------|
| Excavadoras 320 | | | |
| Excavadora 320 L (Ayala) | 4-ene-07 | | En junio 2007 |
| Excavadora 320 CL #1 (Cadme) | 22-ene-07 | | 10-Mar-07 |
| Excavadora 320 BL #2 (Cadme) | 24-ene-07 | | 11-mar-07 |
| Excavadora 320 L (López) | 17-ene-07 | | En junio 2007 |
| Excavadora 320 L (Zavala) | 14-ene-07 | | 2-Mar-07 |
| Excavadora 320 L (T. Molina) | 6-ene-07 | | 7-ene-07 |
| Excavadora 320 L (T. Tufiño) | 30-ene-07 | | 17-May-07 |
| Excavadora 320 L (T. Tufiño) #2 | 2-Feb-07 | | 25-mar-07 |
| Excavadora 320 L (T. Tufiño) #3 | 4-Feb-07 | | 23-Feb-07 |
| Excavadora 320 L (L. Delgado) | 22-mar-07 | | 6-jun-07 |
| Tractores y otros | | | |
| Caterpillar D7 | 19-ene-07 | | 21-Feb-07 |
| Bocat 1700 Thomas | 7-ene-07 | | 14-mar-07 |
| Gallineta | 3-ene-07 | | 24-ene-07 |
| Grúa de llantas cap 60 Tn Mamut | 19-ene-07 | | 27-ene-07 |
| Grúa Link Belt | 21-ene-07 | | 28-Mar-07 |
| Generador | | | |
| Generador Coleman 100 Kva. (Venrental) | 23-ene-07 | | 8-Mar-07 |
| Generador 55 Kva. (Venrental) | 3-Feb-07 | | 9-Mar-07 |
| Generador 80 Kva. planta hormigón | 15-Jul-06 | | 25-May-07 |
| Generador 5 Kva. T. Molina | 11-Feb-07 | | 23-Feb-07 |
| Generador 5250Watts | 2-abr-06 | | 31-May-07 |
| Otros | | | |
| Rodillo liso Caterpillar 12 Tn. | 10-ene-07 | | 15-ene-07 |
| Motoniveladora G 120H | 10-ene-07 | | 15-ene-07 |
| Cargadora YALE 2500 | 8-ene-07 | | 15-ene-07 |
| Grúa Lorain de 40 tn (Corsa) | 10-Feb-07 | | 11-abr-07 |
| Grua GROVE 25 T | 11-abr-07 | | 5-May-07 |
| Equipo de hormigón | | | |
| Bomba de hormigón | 7-ene-07 | | 15-May-07 |
| Planta de hormigón cap 20m3/h | 15-Jul-06 | | 15-May-07 |
| Compresor planta hormigón (silo vertical) | 15-Jul-06 | | 15-May-07 |
| Cigarras para cemento | 6-agosto-06 | | 15-May-07 |
| Silo vertical para cemento | 6-Jul-06 | 15-May-07 | 31-May-07 |
| Vehículos | | | |
| Camionetas 4x4 (dos) | 1-ene-07 | | |

| | | | |
|---------------------------------|-----------|-----------|-----------|
| Camionetas 4x4 (una) | 3-ene-07 | 4-abr-07 | |
| Camionetas 4x4 (una) | 22-ene-07 | 4-abr-07 | |
| Camión 3tn | 23-ene-07 | | 31-May-07 |
| Cama Baja 30 tn. | 5-ene-07 | 8-ene-07 | |
| Bus cap 45 pass (a) Trans Macas | 8-ene-07 | 6-abr-07 | |
| Bus cap 45 pass (b) Trans Sucúa | 23-ene-07 | 31-May-07 | |
| Bus cap 45 pass (c) Urbano | 2-Feb-07 | 25-mar-07 | |
| Volquetas 8m3 | 3-ene-07 | 17-ene-07 | |
| Volquetas 12m3 | 24-ene-07 | 17-ene-07 | |
| Volquetas tipo bañera 20m4 | 13-ene-07 | | 16-ene-07 |

| Equipo Menor | Movilización | Desafectación | Desmovilización |
|--|--------------|---------------|-----------------|
| Soldadoras | | | |
| Soldadora Miller 400 A cod LS 002 | 20-Jul-06 | | 31-May-07 |
| Soldadora Miller 400 A cod LS 003 | 20-Jul-06 | | 24-mar-07 |
| Soldadora Miller 400 A cod LS 004 | 31-Jul-06 | | 31-May-07 |
| Motosoldadora Lincoln LS-006 | 5-ene-07 | | 31-May-07 |
| Motosoldadora Lincoln 400 A LS-010 | 5-ene-07 | | 31-May-07 |
| Motosoldadora Lincoln 400A LS-011 | 5-ene-07 | | 31-May-07 |
| Motosoldadora Lincoln 400A LS-013 | 5-ene-07 | | 31-May-07 |
| Motosoldadora Lincoln 400A Orienco K-25 | 21-ene-07 | | 9-mar-07 |
| Motosoldadora Lincoln 400A López # 26 | 21-ene-07 | | 9-mar-07 |
| Motosoldadora Lincoln 400A Verental # 27 | 21-ene-07 | | 3-Feb-07 |
| Motosoldadora Lincoln 400A Verental # 28 | 21-ene-07 | | 27-ene-07 |
| Motosoldadora Lincoln 400 A Vega # 29 | 28-ene-07 | | 9-Mar-07 |
| Motosoldadora Lincoln 400A Castillo # 30 | 29-ene-07 | | 23-Feb-07 |
| Motosoldadora Lincoln 400A Castillo # 31 | 29-ene-07 | | 9-mar-07 |
| Motosoldadora Lincoln 400A Verental # 32 | 8-Feb-07 | | 23-Feb-07 |
| Motosoldadora Lincoln 250A T Molina | 18-Feb-07 | | 9-mar-07 |
| Equipo oxy corte | 4-Jun-06 | | 31-May-07 |
| Electro soldadoras | | | |
| Electrosold Lincoln SI-005 300A | 20-Jun-06 | | 31-May-07 |
| Electrosold Lincoln SI-007 300A invertec | 20-agosto-06 | | 9-mar-07 |
| Electrosold Lincoln SI-008 300A invertec | 20-agosto-06 | | 9-mar-07 |
| Electrosold Lincoln SI-009 300A invertec | 20-agosto-06 | | 9-mar-07 |
| Electrosold Lincoln SI-012 300A invertec | 2-Feb-07 | 31-mar-07 | 31-May-07 |
| Otros | | | |
| Bomba de agua 4" PB 007 | 3-abr-06 | 20-abr-06 | 31-May-07 |
| Bomba de agua 4" PB 009 | 2-abr-06 | | 31-May-07 |
| Bomba de agua 4" PB 010 | 19-abr-06 | | 31-May-07 |
| Bomba de agua 4" s/n | 6-abr-06 | 17-abr-06 | 31-May-07 |
| Bomba de agua 4" PB 004 | 2-abr-06 | 3-Jun-06 | 31-May-07 |
| Bomba de agua 3" PB 003 | 15-agosto-06 | | 31-May-07 |
| Concretera 1 saco C-001 | 10-abr-06 | | 31-May-07 |
| Concretera 1 saco C-002 | 15-Nov-06 | | 31-May-07 |

| | | | |
|----------------------------|-----------|----------|-----------|
| Plancha compactadora | 2-abr-06 | 3-Jun-06 | 31-May-07 |
| Taladro Hilti | 24-Jun-06 | | 31-May-07 |
| Rodillo compactador manual | 28-Jun-06 | | 31-May-07 |
| Sapo compactador | 2-Jul-06 | | 31-May-07 |
| Contendor bodega 20" | 18-Jul-06 | | 31-May-07 |
| Contendor sanitario #1 | 5-Sep-06 | | 31-May-07 |
| Contendor sanitario #2 | 10-Feb-07 | | 31-May-07 |

3.4.2 Horas-Equipo Presupuestadas vs. Consumidas por Categoría de Equipos

| CATEGORIA | | (A) | (B) | (B/A) % |
|--|--------|---------------------------|--------------------------------------|------------|
| | | horas-equipo estimadas | horas-equipo EPC II 31 Jun '07 | |
| | | EPC II | (B/A) % | |
| A. Tractor empujador de orugas | | | | |
| Caterpillar D6M-LGP o similar | 342 | 373 | 109% | |
| Caterpillar D6H o similar | | 91 | | |
| Caterpillar D7G o similar | | 358 | | |
| B. CARGADORA FRONTAL DE RUEDAS | | | | |
| Bobcat 742 o similar | | 420 | | |
| D. Cargadora Frontal de Ruedas-retroexcavadora | | | | |
| John Deere 410 o similar | | 27 | | |
| E. Motoniveladora | | | | |
| Motoniveladora 126 a 135 HP | | 26 | | |
| G. Equipo de Excavación | | | | |
| Caterpillar 320BL o similar | 5,404 | 11,041 | 204% | |
| Caterpillar 330BL o similar | | 369 | | |
| H. Retroexcavadora (gallinetas), dragas o almejas | | | | |
| Retroexcavadora CAT 416B | 323 | 47 | 14% | |
| I. Equipo de Compactación | | | | |
| Rodillo vibratorio auto propulsado | 34 | 63 | 188% | |
| Rodillo manual | 2,392 | 162 | 7% | |
| Plancha Compactadora | 656 | 222 | 34% | |
| J. Equipo de Levantamiento | | | | |
| Grua hidráulica auto-propulsada 20-40 tons | 837 | 408 | 49% | |
| Grua mecánica de orugas LINK BELT 21-30 tons | | 566 | | |
| Grua mecánica de orugas 61-80 tons | | 342 | | |
| K. EQUIPO PARA TUBERIAS | | | | |
| Tiende-tubos 160 HP o de menor capacidad | 455 | 88 | 19% | |
| L. Equipo de Soldadura | | | | |
| Soldadora 201 a 300 Amp | | 5,135 | | |
| Soldadora 301 a 400 Amp | 13,180 | 7,387 | 56% | |
| Amoladora manual | 7,584 | 9,626 | 127% | |
| Equipo de oxy-corte | 7,584 | 2,972 | 39% | |
| M. Camiones, trailers y otros vehículos | | | | |
| Volqueta de 7-8 m3 | 522 | 268 | 51% | |
| Volqueta 12-14 m3 | 380 | 332 | 87% | |
| Volqueta (Dumper) >14 m3 | | 6 | | |
| Camión de 3.5 tons | 3,452 | 3,375 | 98% | |
| Bus de más de 30 pasajeros | 5,638 | 5,777 | 102% | |
| Camioneta Doble Cabina | 9,381 | 13,526 | 144% | |
| Trailers Cama-Baja 2 Ejes | | 662 | | |
| N. Equipo neumático | | | | |
| Compresores de Aire 601 a 900 CFM | | 20 | | |
| Sapo compactador manual | 474 | 222 | 47% | |
| O. Equipo de fundición de hormigón | | | | |
| Dosificador de Hormigón | 1,500 | 526 | 35% | |
| Silos para Cemento | 1,500 | 7,872 | 525% | |
| Camión Mixer | 1,500 | 266 | 18% | |
| Bomba Hormigon | 1,500 | 511 | 34% | |
| Mezcladoras de hormigón 1 saco | 342 | 271 | 79% | |
| Vibrador de hormigón | | 662 | | |
| P. Bombas y mangueras | | | | |
| Bomba 2" descarga o de menor capacidad | 408 | 979 | 240% | |
| Bomba 3" descarga | 2,235 | 133 | 6% | |
| Bomba 4" descarga | 2,261 | 1,431 | 63% | |
| Q. Generadores eléctricos e iluminación | | | | |
| Generadores 5kW o de menor capacidad | 322 | 798 | 248% | |
| Generadores 21 a 60kW | | 778 | | |
| Generadores 61 a 100kW | | 1,487 | | |
| V. Equipo misceláneo | | | | |
| Amoladora eléctrica | | 9,626 | | |
| Motosierra | | 426 | | |
| W. CONTENEDORES | | | | |
| Contenedor para servicios higiénicos | | 3,828 | | |
| Contenedor para bodega | | 3,808 | | |

| | |
|----------------|---|
| 110.7 % | de h-e consumidas respecto al presupuesto |
| 110.2 % | de dinero consumido en equipos respecto al presupuesto |
| 93.1 % | de avance de obra hasta la fecha |


Horas – Equipo Consumidas en Repotenciación

- En trabajos de Repotenciación se han consumido 10,389 horas – equipo equivalentes a un monto económico de US\$ 130,000.

3.4.3. Gráficos de Horas - Equipo Pesado en los Frentes de Trabajo

| No. | Frentes de trabajo | Hrs-Equipo | % |
|--------------|--|---------------|-------------|
| 1 | Trabajos rio Balaquepe: Proteccion y Puentes | 3,383 | 19.9% |
| 2 | Plataforma S/E Lim—n | 1,262 | 7.4% |
| 3 | Plataforma S/E M`ndez | 597 | 3.5% |
| 4 | Acopio de tuber'a | 593 | 3.5% |
| 5 | Movimientos de suelos Casa de M‡quinas | 376 | 2.2% |
| 6 | Ampliaci—n Row | 945 | 5.5% |
| 7 | Excavaci—n para cimentaci—nes CM | 684 | 4.0% |
| 8 | Hormigones CM | 2,068 | 12.1% |
| 9 | Desfile tuber'a | 662 | 3.9% |
| 10 | Instalaci—n tuber'a | 5,296 | 31.1% |
| 11 | Mantenimiento vial | 72 | 0.4% |
| 12 | S/E Gualaceo | 370 | 2.2% |
| 13 | Montaje Electro - Mec‡nico Casa de M‡quinas | 85 | 0.5% |
| 14 | Obra de Descarga Aguas Turbinadas | 488 | 2.9% |
| 15 | Drenajes de Tuber'a de Presi—n | 153 | 0.9% |
| Total | | 17,034 | 100% |

(No considera equipos de soporte y logística)




3.4.4 Gráficos de Horas-Equipo Pesado (continuación)

EPC II + REPOTENCIACION

| Equipo | Hrs-Equipo | % |
|---------------|-------------------|-------------|
| Excavadoras | 12,742 | 74.8% |
| Tractores | 1,855 | 10.9% |
| Volquetes | 781 | 4.6% |
| Otros | 1,656 | 9.7% |
| Total | 17,034 | 100% |

Porcentaje de horas por clase de Equipo Pesado



*Otros: Rodillo 12 tons, Grúa 25 ton, Grúa de 40 tn, Bocat, Dumpers, Sideboom, gallineta, moto niveladora.

3.5 HORAS – HOMBRE

3.5.1 Horas-Hombre presupuestadas vs. Consumidas por Categoría de Personal



| CATEGORIA CONTROL DE PROYECTO: Mano de Obra | (A) horas-hombre estimadas | (B) horas-hombre EPC II 30junio07 | (B/A) % 112% 53% 194% 28% 289% |
|--|----------------------------------|--|--|
| | EPC II | EPC II | |
| | | % | |
| ALOJAM, ALIMENT, Y LAVAND SUBCONTRATISTAS | 26,137 | 75,478 | |
| ADMINISTRADOR | 2,335 | 2,608 | 112% |
| ADMINISTRADOR BILINGÜE (JCR) | 1,867 | 993 | 53% |
| ALBAÑIL CON HERRAMIENTAS | 23,509 | 45,540 | 194% |
| ANOTADOR DE TIEMPO | 7,540 | 2,112 | 28% |
| ASISTENTE ADMINISTRATIVO | 7,540 | 5,912 | |
| ASISTENTE DE BODEGUERO B | | 1,944 | |
| AYUDANTE DE COCINERO | | 2,376 | |
| AYUDANTE DE MECANICA (AY. GENERAL "B") | | 552 | |
| AYUDANTE DE MONTADOR | 554 | 612 | 110% |
| AYUDANTE DE OPERADOR DE EQUIPO PESADO | 10,947 | 19,128 | 175% |
| AYUDANTE DE SOLDADURA | 14,507 | 26,604 | 183% |
| AYUDANTE DE TUBERO | 3,828 | 2,700 | 71% |
| AYUDANTE GENERAL | 9,334 | 72,036 | 772% |
| BODEGUERO | | 512 | |
| BODEGUERO BILINGÜE | 1,593 | 2,950 | 185% |
| CADENERO | 6,970 | 5,640 | 81% |
| CAMARERO | | 1,568 | |
| CAPATAZ OBRAS CIVILES A | 3,847 | 7,040 | 183% |
| CAPATAZ OBRAS CIVILES B | 2,130 | 5,024 | 236% |
| CARPINTERO A CON HERRAMIENTAS | | 3,128 | |
| CHOFER CAMION | | 984 | |
| COCINERO A | | 2,144 | |
| CUIDADOR DIURNO | | 1,104 | |
| CUIDADOR NOCTURNO | 9,456 | 10,896 | 115% |
| DESPACHADOR DE COMBUSTIBLE | | 1,104 | |
| ELECTRICISTA A CON HERRAMIENTAS | 4,672 | 1,816 | 39% |
| ELECTRICISTA B CON HERRAMIENTAS | | 2,552 | |
| ESMERILADOR A | | 1,620 | |
| FIERRERO | | 3,984 | |
| INGENIERO A | | 1,640 | |
| INGENIERO B | 1,363 | 3,964 | 291% |
| MECANICO A CON HERRAMIENTAS | | 3,448 | |
| PARAMEDICO | | 2,472 | |
| MONTADOR A/I | | 1,816 | |
| OBRERO CON HERRAMIENTAS | 28,096 | 130,668 | 465% |
| OPERADOR A DE EQUIPO PESADO | 2,749 | 3,232 | 118% |
| OPERADOR B DE EQUIPO PESADO | | 832 | |
| SOLDADOR 2da y 3era Categoría | 2,138 | 5,504 | 257% |
| SOLDADOR API CON HERRAMIENTAS | 14,560 | 11,840 | 81% |
| SUPERINTENDENTE (J Acosta) | 546 | 2,200 | 403% |
| SUPERINTENDENTE BILINGÜE (MC) | 2,245 | 1,966 | 88% |
| SUPERVISOR | 6,827 | 8,472 | 124% |
| SUPERVISOR DE Soldadura QA/QC | | 2,112 | |
| SUPERVISOR DE SOLDADURA | 1,555 | 3,680 | 237% |
| SUPERVISOR ELECTRICO (Diego P) | 2,047 | 821 | 40% |
| SUPERVISOR ELECTRICO | | 714 | |
| TOPOGRAFO CON EQUIPO | 5,481 | 2,880 | 53% |
| TUBERO A | 3,854 | 3,424 | 89% |

| | |
|---------|---|
| 176.5 % | de h-h consumidas respecto al presupuesto |
| 131.8 % | de dinero de mano de obra consumido respecto al presupuesto |
| 93.1% | de avance de obra hasta la fecha |

Horas – Hombre Consumidas en Repotenciación

- En trabajos de Repotenciación se han consumido 70,670 horas – hombre equivalentes a un monto económico de US\$ 300,000

3.7.2 Histograma de Personal





3.7.3 Índices de Accidentabilidad

| | |
|-------------------------------------|----------|
| Número de accidentes registrables: | 0 |
| Índice de frecuencia: | 0 |
| Numero de días perdidos por lesión: | 0 |
| Índice de gravedad: | 0 |
| Número de Lesiones: | 0 |

4. REPORTE DE PRODUCCION (Fases activas al 30 Julio 07)

Adjunto como Anexo 2

5. FOTOGRAFÍAS

Ver Álbum de fotos en la siguiente dirección de Internet:

<http://web.mac.com/jsevilla/iWeb/Web%20Page%20JSA/HA%20EPC%20II%20web%20page.html>

ANNEX 2**Commercial Operation of the Second Phase of Abanico Hydroelectric Project**

CENACE 3175
Quito 19 de julio de 2007

[Signature]
RECIBIDO 23 JUL 2007

Economista
HERNÁN FLORES E.
Gerente General
HIDROABANICO
Av. Amazonas N 41 -56 e Isla Floreana , Edificio Amazonas cuarto piso
Quito

De mi consideración:

La Corporación CENACE verificó el cumplimiento de los requisitos establecidos en el numeral 8 de la Regulación CONELEC 006/00, determinando que los equipos e instalaciones de la segunda etapa de la central hidroeléctrica Abanico, no afectan la seguridad y continuidad del suministro de energía eléctrica, y que no existen objeciones para su incorporación al Sistema Nacional Interconectado, con la salvedad que se deberá observar la restricción de no superar una generación total de 30 MW en la central Abanico en las horas de máxima demanda (18:00 – 21:00)

El Consejo Nacional de Electricidad – CONELEC, mediante comunicación DE-07-1372, de 17 de julio de 2007, informa a CENACE que la Empresa HIDROABANICO está habilitada para participar con la ampliación de 15 MW a 37.5 MW en el Mercado Eléctrico Mayorista.

En el sistema de grabación y bitácora del Centro de Control de CENACE, correspondiente al 18 de julio de 2007, se registra lo siguiente: "... 18:21 Disponibles unidades 3, 4 y 5. Ing. Diego Peñaloza de HIDROABANICO informa que las unidades se encuentran disponibles y se inicia la operación comercial. La unidad 3 no ingresa al paralelo ya que en el periodo de 18:00-21:00 se puede generar máximo 30 MW por restricción en el sistema de la EERCSUR."

Con estos antecedentes, y en atención a lo solicitado por la Empresa HIDROABANICO, mediante comunicación HA-07-00034 de 17 de julio de 2007, la Corporación CENACE autoriza la operación comercial del incremento de capacidad adicional de 22.5 MW de la central hidroeléctrica Abanico, desde las 18:21 del 18 de julio de 2007.

Atentamente,

[Signature]
ING. GABRIEL ARGÜELLO RÍOS
Director Ejecutivo

c. c. Presidente del Directorio de CENACE,
Director Ejecutivo de CONELEC
Presidente Ejecutivo de TRANSELECTRIC
Presidente Ejecutivo E.E. Centro Sur

Panamericana Sur Km. 17 1/2 • Teléfonos: (593 2) 2992 001 • Fax: 2992 031
Presidencia del Directorio; 12 de Octubre N24-562 Ed. World Trade Center
Torre A Piso 10 Of 1004 • Telf.: 2523 143 • Fax: 2551 363
Apartado Postal 17-21-1991 • www.cenace.org.ec • Quito - Ecuador



**Translation of the Commercial Operation of the Second Phase of Abanico
Hydroelectric Project**

CENACE 3175
Quito, July 19, 2007

(*STAMP AND RUBRIC
ACKNOWLEDGEMENT OF RECEIPT
JULY 23, 2007*)

Economist

HERNÁN FLORES E.

General Manager

HIDROABANICO

Av. Amazonas N 41-56 e Isla Floreana, Edificio Amazonas, Cuarto Piso

Quito

Dear Sir,

CENACE Corporation verified the fulfillment of the requirements provided in Clause 8 of CONELEC Regulation 006/00, in order to determine if the equipment and facilities of the second stage of Abanico hydroelectric power station do not affect the security and continuous power supply, and if there are not objections for the incorporation of Abanico to the Interconnected National System, with the restriction of not exceeding a total power generation of 30 MW from Abanico power station during the top hours of electric power demand (18h00 – 21h00).

The National Electric Power Council – CONELEC, through the Official Letter DE-07-1372, dated July 17, 2007, informed to CENACE that the Company HIDROABANICO is authorized to increase its power supply participation in the Electric Power Market, from 15MW to 37,5 MW.

In the recording system and files of CENACE Control Center, of July 18, 2007, the following statement was registered: "... 18:21 Available units: 3, 4, and 5. Engineer Diego Peñaloza, of HIDROABANICO, reports that those units are available, as well as

the start-up of the commercial operations. Unit 3 does not enter to operate in parallel, due to the fact that during the time period from 18:00 – 21:00, a maximum power generation of 30 MW was authorized for restriction in the EERCSUR system”.

With the above mentioned antecedents, and in response to the request of the Company HIDROABANICO, through the Official Letter HA-07-00034, dated July 17, 2007, CENACE Corporation authorizes an additional capacity increase to 22.5 MW of generation for the commercial operation of HIDROABANICO power station, from 18:21 of July 18, 2007.

Regards,


(AUTHORIZED SIGNATURE)

ING. GABRIEL ARGÜELLO RÍOS
Executive Director

Copy to: Chairman of the Board of *CENACE*
Executive Director of *CONELEC*
Executive President of *TRANSELECTRIC*
Executive President of *E.E. Centro Sur*

TRANSLATION EXPERT

(LETTER FROM CENACE 3175 – JULY 19, 2007 – 2 PREVIOUS PAGES):



Maria Fernanda Merino Noboa
ID/Passport 1707284871

I HEREBY CERTIFY THAT I AM FLUENT IN BOTH ENGLISH AND SPANISH LANGUAGES AND THAT I HAVE PREPARED THE ATTACHED TRANSLATION FROM THE ORIGINAL IN THE SPANISH LANGUAGE TO THE BEST OF MY KNOWLEDGE AND BELIEF.

I ALSO CERTIFY THAT I AM INCLUDED IN THE LIST OF TRANSLATORS OF THE EMBASSY OF THE UNITED STATES OF AMERICA.

Quito, August 22, 2008



MARÍA FERNANDA MERINO NOBOA
ID/PASSPORT 1707284871

ANNEX 3

In the following table shown the annual generation of Hidroabanico Hydropower Plant for the period March 1, 2007 to February 29, 2008. In the file attached HA Generation Mar 07-Feb 08.xls will find the CENACE's data for every month.


HIDROABANICO HYDROELECTRIC PROJECT 37.50 MW

| HIDROABANICO | Total Energy |
|---------------------|---------------------|
| Month | MWh |
| Mar-07 | 10,443 |
| Apr-07 | 10,049 |
| May-07 | 9,294 |
| Jun-07 | 9,818 |
| Jul-07 | 16,516 |
| Aug-07 | 25,697 |
| Sep-07 | 26,125 |
| Oct-07 | 27,578 |
| Nov-07 | 26,287 |
| Dec-07 | 27,268 |
| Jan-08 | 26,891 |
| Feb-08 | 25,590 |
| TOTAL | 241,557 |

ANNEX 4

| Calibración y Ajuste de Medidores | | | CLB-2008-009 |
|---|--|---|------------------------------|
| DATOS GENERALES | | | |
| Empresa Solicitante: HIDROABANICO_P | Fecha: febrero 20, 2008 | E-MAIL: dpenaloza@hna.com.ec | Número Teléf. 099-495 337 |
| Características de los Equipos de Medición | | | |
| Equipo de Medición a Calibrar Marca: MAXYS Tipo: 2510 # de Serie: 90.222.534 Tensión Nominal (V): 40 -140 Contenido Nominal (A): 5 Kh (Wh/Pulse): 1 Fecha Última Calibración: febrero 20 de 2010 Equipo de Medición Patrón Marca: MTE PRS200.3 # de Serie: 20094 Precisión: 0,02% Certificaciones: ENERGIE MESSTECHIK | | | |
| Tablas de Porcentajes (%) de Error Obtenidos | | | |
| ERROR MÁXIMO PERMITIDO EN TODAS LAS CONDICIONES: ±0,2 % | | | |
| Condición: 10% I nominal | | | |
| Pulsos | 0 Grados | +30 Grados | +60 Grados |
| 1 | 0,122 | 0,180 | 0,022 |
| 2 | 0,032 | 0,154 | 0,089 |
| 3 | 0,099 | 0,135 | 0,072 |
| Promedio | 0,084 | 0,156 | 0,081 |
| Condición: 50% I nominal | | | |
| Pulsos | 0 Grados | +30 Grados | +60 Grados |
| 1 | 0,041 | 0,105 | 0,090 |
| 2 | 0,055 | 0,082 | 0,083 |
| 3 | 0,033 | 0,067 | 0,039 |
| Promedio | 0,043 | 0,085 | 0,071 |
| Condición: 100% I nominal | | | |
| Pulsos | 0 Grados | +30 Grados | +60 Grados |
| 1 | 0,048 | 0,041 | 0,081 |
| 2 | 0,135 | 0,059 | 0,097 |
| 3 | 0,056 | 0,072 | 0,063 |
| Promedio | 0,080 | 0,057 | 0,087 |
| RESULTADOS VÁLIDOS POR DOS AÑOS: EL EQUIPO CALIBRADO SI ESTA DENTRO DEL RANGO DE PRECISIÓN EL EQUIPO CALIBRADO NO FUE PREVIAMENTE AJUSTADO. | | | |
| Aceptación de los Resultados de Calibración | | | |
| POR CENACE:  | POR HIDROABANICO:  | POR EERC SUR:  | |
| Ing. Jorge Oríz | Ing. Diego Peñaloza | Ing. Jorge Vena | |

| | | | | |
|--|---|---|---|-----------------------------|
| FD-06-CLB-01 Calibración y Ajuste de Medidores | | | | CLB-2008-010 |
| DATOS GENERALES | | | | |
| Empresa Solicitante: HIDROABANICO_R | | Fecha: febrero 20, 2008 | E-MAIL: cpenaloza@cenace.com.ec | Número Tel.: 099-495 397 |
| Características de los Equipos de Medición | | | | |
| Equipo de Medición a Calibrar | | | | |
| Marca: MAXYS | Tipo: 2510 | # de Serie: 90.222.536 | Tensión Nominal (V) 40 -140 | |
| Corriente Nominal (A): 5 | Kh (Wh/Pulso): 1 | Fecha Última Calibración: | Fecha Expiración de presente Calibración: febrero 20 de 2010 | |
| Equipo de Medición Patrón | | | | |
| Marca: MTE | # de Serie: 20694 | Precisión: 0,02% | Certificaciones: ENERGIE-MESSTECHNIK | |
| Tablas de Porcentajes (%) de Error Obtenidos | | | | |
| ERROR MÁXIMO PERMITIDO EN TODAS LAS CONDICIONES: +0,2 % | | | | |
| Condición: 10% Nominal | | | | |
| Pulsos | 0 Grados | +30 Grados | +60 Grados | |
| 1 | 0,084 | 0,143 | 0,138 | |
| 2 | 0,042 | 0,096 | 0,100 | |
| 3 | 0,058 | 0,103 | 0,109 | |
| Promedio | 0,061 | 0,114 | 0,115 | |
| Condición: 50% Nominal | | | | |
| Pulsos | 0 Grados | +30 Grados | +60 Grados | |
| 1 | 0,056 | 0,052 | 0,037 | |
| 2 | 0,022 | 0,030 | 0,090 | |
| 3 | 0,034 | 0,083 | 0,068 | |
| Promedio | 0,037 | 0,065 | 0,062 | |
| Condición: 100% Nominal | | | | |
| Pulsos | 0 Grados | +30 Grados | +60 Grados | |
| 1 | 0,004 | 0,013 | 0,018 | |
| 2 | 0,090 | 0,097 | 0,017 | |
| 3 | 0,013 | 0,082 | 0,054 | |
| Promedio | 0,036 | 0,064 | 0,030 | |
| RESULTADOS VALIDOS POR DOS AÑOS. | | | | |
| EL EQUIPO CALIBRADO SI ESTA DENTRO DEL RANGO DE PRECISIÓN | | | | |
| EL EQUIPO CALIBRADO NO FUE PREVIAMENTE AJUSTADO | | | | |
| Aceptación de los Resultados de Calibración | | | | |
| POR CENACE:  Ing. Jorge Ortiz | POR HIDROABANICO:  Ing. Diego Peñaloza | POR SERC SUR:  Ing. Jorge Vélez | | |

| FO-DSI CLB-01 Calibración y Ajuste de Medidores | | | | CLB-2008-011 |
|---|---|----------------------------|---|---|
| DATOS GENERALES | | | | |
| Empresa Solicitante: CENTRO SUR, MENDEZ | | Fecha: febrero 20, 2008 | E-MAIL: Juvera@centrosur.com.es | Número Telf. 099-396447 |
| Características de los Equipos de Medición | | | | |
| Equipo de Medición a Calibrar | | | | |
| Marca: MAXYS | Tipo: 2510 | # de Serie: 90.222.535 | Tensión Nominal (V) 40 -140 | |
| Corriente Nominal (A): 5 | KWh (Wh/Pulso): 1 | Fecha Última Calibración: | | Fecha Expiración de presente Calibración: febrero 20 de 2010 |
| Equipo de Medición Patrón | | | | |
| Marca: MTE | # de Serie: 20694 | Precisión: 0.02% | Certificaciones: ENERGIE-MESSTECHNIK | |
| Tablas de Porcentajes (%) de Error Obtenidos | | | | |
| ERROR MÁXIMO PERMITIDO EN TODAS LAS CONDICIONES: ±0.2 % | | | | |
| Condición: 10% I nominal | | | | |
| Pulsos | 0 Grados | +30 Grados | +60 Grados | |
| 1 | 0.146 | 0.155 | 0.082 | |
| 2 | 0.129 | 0.055 | 0.072 | |
| 3 | 0.085 | 0.101 | 0.126 | |
| Promedio | 0.119 | 0.104 | 0.094 | |
| Condición: 50% I nominal | | | | |
| Pulsos | 0 Grados | +30 Grados | +60 Grados | |
| 1 | 0.078 | 0.129 | 0.110 | |
| 2 | 0.044 | 0.114 | 0.096 | |
| 3 | 0.032 | 0.084 | 0.069 | |
| Promedio | 0.05* | 0.109 | 0.092 | |
| Condición: 100% I nominal | | | | |
| Pulsos | 0 Grados | +30 Grados | +60 Grados | |
| 1 | 0.155 | 0.133 | 0.103 | |
| 2 | 0.157 | 0.083 | 0.081 | |
| 3 | 0.078 | 0.068 | 0.082 | |
| Promedio | 0.130 | 0.106 | 0.089 | |
| RESULTADOS VÁLIDOS POR DOS AÑOS: | | | | |
| EL EQUIPO CALIBRADO SI ESTÁ DENTRO DEL RANGO DE PRECISIÓN | | | | |
| EL EQUIPO CALIBRADO NO FUE PREVIAMENTE AJUSTADO. | | | | |
| Aceptación de los Resultados de Calibración | | | | |
| POR CENACE:  Ing. Jose Ortiz | POR HIDROABANICO:  Ing. Diego Peñaloza | | POR EERC SUR:  Ing. Jose Vera | |

| FO-DSI-CLEJ/01 Calibración y Ajuste de Medidores | | | | CLB-2008-012 |
|--|--|--|----------------------------|--------------|
| DATOS GENERALES | | | | |
| Empresa Solicitante: CENTRO SUR_NACAS | Fecha: febrero 20, 2008 | E-MAIL: Jvera@centrosur.com.ec | Número Telf: 099-396447 | |
| Características de los Equipos de Medición | | | | |
| Equipo de Medición a Calibrar: Marca: MAXYS Tipo: 2510 # de Serie: 90,222,533 Tensión Nominal (V): 40 -140 Corriente Nominal (A): 5 Kh (VWh/Pulso): 1 Fecha Última Calibración: Fecha Expiración de presente Calibración: febrero 20 de 2010 | | | | |
| Equipo de Medición Patrón: Marca: MTE # de Serie: 20694 Precisión: 0,02% Certificaciones: ENERGIE-MESSTECHIK | | | | |
| Tablas de Porcentajes (%) de Error Obtenidos | | | | |
| ERROR MÁXIMO PERMITIDO EN TODAS LAS CONDICIONES: ±0,2 % | | | | |
| Condición: 10% Nominal | | | | |
| Pulsos | 0 Grados | +30 Grados | +60 Grados | |
| 1 | 0,173 | 0,138 | 0,161 | |
| 2 | 0,087 | 0,128 | 0,155 | |
| 3 | 0,098 | 0,138 | 0,102 | |
| Promedio | 0,118 | 0,133 | 0,139 | |
| Condición: 50% Nominal | | | | |
| Pulsos | 0 Grados | +30 Grados | +60 Grados | |
| 1 | 0,152 | 0,108 | 0,132 | |
| 2 | 0,142 | 0,082 | 0,112 | |
| 3 | 0,112 | 0,105 | 0,092 | |
| Promedio | 0,135 | 0,098 | 0,112 | |
| Condición: 100% Nominal | | | | |
| Pulsos | 0 Grados | +30 Grados | +60 Grados | |
| 1 | 0,182 | 0,122 | 0,135 | |
| 2 | 0,188 | 0,137 | 0,116 | |
| 3 | 0,089 | 0,101 | 0,093 | |
| Promedio | 0,138 | 0,120 | 0,115 | |
| RESULTADOS VALIDOS POR DOS AÑOS: EL EQUIPO CALIBRADO SI ESTÁ DENTRO DEL RANGO DE PRECISIÓN EL EQUIPO CALIBRADO NO FUE PREVIAMENTE AJUSTADO. | | | | |
| Aceptación de los Resultados de Calibración | | | | |
| POR: CENACE:  Ing. Jorge Ortiz | POR: HIDROABANICO:  Ing. Diego Pefaloza | POR: EERC SAIC:  Ing. Jorge Vera | | |

TRANSLATION OF THE CERTIFICATES OF CALIBRATION

| FO-DSI-CLB/01 Calibration and Adjustment of Meters | | CLB-2008-009 | |
|---|--|--|--------------|
| GENERAL DATA | | | |
| Requesting Company: HIDROABANICO_P | Date: February 20, 2008 | E-MAIL dpenaloza@gne.com.ec | |
| Phone Number: 099-495 397 | | | |
| Characteristics of Measurement Equipment | | | |
| Measurement Equipment to be Calibrated: | | | |
| Brand Name: MAXYS | Type: 2510 | Series Number: 90.222.534 | |
| Nominal Current (A): 5 | Kh (Wh/Pulse): 1 | Last Calibration Date: (xxx) | |
| Expiry Date of the present Calibration: February 20, 2010 | | | |
| Standard Measuring Equipment: | | | |
| Brand Name: MTE PRS200.3 | Series Number: 20694 | Accuracy: 0.02% | |
| Certifications: ENERGIE-MESSTECHIK | | | |
| Error-Rate (%) Tables | | | |
| TOP ERRORS ALLOWED IN ALL CONDITIONS: $\pm 0.2\%$ | | | |
| Condition: 10% 1 nominal | | | |
| Pulses | 0 Degrees | + 30 Degrees | + 60 Degrees |
| 1 | 0.122 | 0.180 | 0.022 |
| 2 | 0.032 | 0.154 | 0.089 |
| 3 | 0.099 | 0.135 | 0.072 |
| Average | 0.084 | 0.156 | 0.061 |
| Condition: 50% 1 nominal | | | |
| Pulses | 0 Degrees | + 30 Degrees | + 60 Degrees |
| 1 | 0.041 | 0.105 | 0.090 |
| 2 | 0.055 | 0.082 | 0.083 |
| 3 | 0.033 | 0.067 | 0.039 |
| Average | 0.043 | 0.085 | 0.071 |
| Condition: 100% 1 nominal | | | |
| Pulses | 0 Degrees | + 30 Degrees | + 60 Degrees |
| 1 | 0.048 | 0.041 | 0.081 |
| 2 | 0.135 | 0.059 | 0.097 |
| 3 | 0.056 | 0.072 | 0.083 |
| Average | 0.080 | 0.057 | 0.087 |
| RESULTS VALID FOR TWO YEARS: | | | |
| THE CALIBRATED EQUIPMENT IS WITHIN THE ACCURACY RANGE. | | | |
| THE CALIBRATED EQUIPMENT WAS NOT PREVIOUSLY ADJUSTED. | | | |
| Approval of Calibration Results | | | |
| BY CENACE: (AUTHORIZED SIGNATURE) Ing. Jorge Ortiz | BY HIDROABANICO: (AUTHORIZED SIGNATURE) Ing. Diego Peñaloza | BY EERC SUR: (AUTHORIZED SIGNATURE) Ing. Jorge Vera | |

| FO-DSI-CLB/01 Calibration and Adjustment of Meters | | CLB-2008-010 | |
|---|--|--|--|
| GENERAL DATA | | | |
| Requesting Company: HIDROABANICO_P | Date: February 20, 2008 | E-MAIL dpenaloza@gne.com.ec | Phone Number: 099-495 397 |
| Characteristics of Measurement Equipment | | | |
| Measurement Equipment to be Calibrated: | | | |
| Brand Name: MAXYS | Type: 2510 | Series Number: 90.222.536 | Nominal Tension (V): 40 - 140 |
| Nominal Current (A): 5 | Kh (Wh/Pulse): 1 | Last Calibration Date: (xxx) | Expiry Date of the present Calibration: February 20, 2010 |
| Standard Measuring Equipment: | | | |
| Brand Name: MTE PRS200.3 | Series Number: 20694 | Accuracy: 0.02% | Certifications: ENERGIE-MESSTECHIK |
| Error-Rate (%) Tables | | | |
| TOP ERRORS ALLOWED IN ALL CONDITIONS: $\pm 0.2\%$ | | | |
| Condition: 10% 1 nominal | | | |
| Pulses | 0 Degrees | + 30 Degrees | + 60 Degrees |
| 1 | 0.084 | 0.143 | 0.136 |
| 2 | 0.042 | 0.096 | 0.100 |
| 3 | 0.058 | 0.103 | 0.109 |
| Average | 0.061 | 0.114 | 0.115 |
| Condition: 50% 1 nominal | | | |
| Pulses | 0 Degrees | + 30 Degrees | + 60 Degrees |
| 1 | 0.056 | 0.052 | 0.037 |
| 2 | 0.022 | 0.030 | 0.090 |
| 3 | 0.034 | 0.083 | 0.058 |
| Average | 0.037 | 0.055 | 0.062 |
| Condition: 100% 1 nominal | | | |
| Pulses | 0 Degrees | + 30 Degrees | + 60 Degrees |
| 1 | 0.004 | 0.013 | 0.018 |
| 2 | 0.090 | 0.097 | 0.017 |
| 3 | 0.013 | 0.082 | 0.054 |
| Average | 0.036 | 0.064 | 0.030 |
| RESULTS VALID FOR TWO YEARS: | | | |
| THE CALIBRATED EQUIPMENT IS WITHIN THE ACCURACY RANGE. | | | |
| THE CALIBRATED EQUIPMENT WAS NOT PREVIOUSLY ADJUSTED. | | | |
| Approval of Calibration Results | | | |
| BY CENACE: (AUTHORIZED SIGNATURE) Ing. Jorge Ortiz | BY HIDROABANICO: (AUTHORIZED SIGNATURE) Ing. Diego Peñaloza | BY EERC SUR: (AUTHORIZED SIGNATURE) Ing. Jorge Vera | |

| | | | |
|--|---|--|--|
| FO-DSI-CLB/01 | | CLB-2008-011 | |
| Calibration and Adjustment of Meters | | CLB-2008-011 | |
| GENERAL DATA | | | |
| Requesting Company: CENTRO SUR_MENDEZ | Date: February 20, 2008 | E-MAIL jvera@centrosur.com.ec | Phone Number: 099-396447 |
| Characteristics of Measurement Equipment | | | |
| Measurement Equipment to be Calibrated: | | | |
| Brand Name: MAXYS | Type: 2510 | Series Number: 90.222.535 | Nominal Tension (V): 40 - 140 |
| Nominal Current (A): 5 | Kh (Wh/Pulse): 1 | Last Calibration Date: (xxx) | Expiry Date of the present Calibration: February 20, 2010 |
| Standard Measuring Equipment: | | | |
| Brand Name: MTE PRS200.3 | Series Number: 20694 | Accuracy: 0.02% | Certifications: ENERGIE-MESSTECHIK |
| Error-Rate (%) Tables | | | |
| TOP ERRORS ALLOWED IN ALL CONDITIONS: $\pm 0.2\%$ | | | |
| Condition: 10% 1 nominal | | | |
| Pulses | 0 Degrees | + 30 Degrees | + 60 Degrees |
| 1 | 0.146 | 0.155 | 0.082 |
| 2 | 0.126 | 0.055 | 0.072 |
| 3 | 0.085 | 0.101 | 0.128 |
| Average | 0.119 | 0.104 | 0.094 |
| Condition: 50% 1 nominal | | | |
| Pulses | 0 Degrees | + 30 Degrees | + 60 Degrees |
| 1 | 0.076 | 0.129 | 0.110 |
| 2 | 0.044 | 0.114 | 0.096 |
| 3 | 0.032 | 0.084 | 0.069 |
| Average | 0.051 | 0.109 | 0.092 |
| Condition: 100% 1 nominal | | | |
| Pulses | 0 Degrees | + 30 Degrees | + 60 Degrees |
| 1 | 0.155 | 0.133 | 0.103 |
| 2 | 0.157 | 0.083 | 0.081 |
| 3 | 0.078 | 0.098 | 0.082 |
| Average | 0.130 | 0.105 | 0.089 |
| RESULTS VALID FOR TWO YEARS: | | | |
| THE CALIBRATED EQUIPMENT IS WITHIN THE ACCURACY RANGE. | | | |
| THE CALIBRATED EQUIPMENT WAS NOT PREVIOUSLY ADJUSTED. | | | |
| Approval of Calibration Results | | | |
| BY CENACE: (AUTHORIZED SIGNATURE) Ing. Jorge Ortiz | BY HIDROABANICO: (AUTHORIZED SIGNATURE) Ing. Diego Peñaloza | BY EERC SUR: (AUTHORIZED SIGNATURE) Ing. Jorge Vera | |

| | | | |
|---|--|--|--|
| FO-DSI-CLB/01 Calibration and Adjustment of Meters | | CLB-2008-012 | |
| GENERAL DATA | | | |
| Requesting Company: CENTRO SUR_MACAS | Date: February 20, 2008 | E-MAIL jvera@centrosur.com.ec | Phone Number: 099-396447 |
| Characteristics of Measurement Equipment | | | |
| Measurement Equipment to be Calibrated: | | | |
| Brand Name: MAXYS | Type: 2510 | Series Number: 90.222.533 | Nominal Tension (V): 40 - 140 |
| Nominal Current (A): 5 | Kh (Wh/Pulse): 1 | Last Calibration Date: (xxx) | Expiry Date of the present Calibration: February 20, 2010 |
| Standard Measuring Equipment: | | | |
| Brand Name: MTE PRS200.3 | Series Number: 20694 | Accuracy: 0.02% | Certifications: ENERGIE-MESSTECHIK |
| Error-Rate (%) Tables | | | |
| TOP ERRORS ALLOWED IN ALL CONDITIONS: $\pm 0.2\%$ | | | |
| Condition: 10% 1 nominal | | | |
| Pulses | 0 Degrees | + 30 Degrees | + 60 Degrees |
| 1 | 0.173 | 0.136 | 0.161 |
| 2 | 0.087 | 0.126 | 0.155 |
| 3 | 0.098 | 0.136 | 0.102 |
| Average | 0.119 | 0.133 | 0.139 |
| Condition: 50% 1 nominal | | | |
| Pulses | 0 Degrees | + 30 Degrees | + 60 Degrees |
| 1 | 0.152 | 0.108 | 0.132 |
| 2 | 0.142 | 0.082 | 0.112 |
| 3 | 0.112 | 0.105 | 0.092 |
| Average | 0.135 | 0.098 | 0.112 |
| Condition: 100% 1 nominal | | | |
| Pulses | 0 Degrees | + 30 Degrees | + 60 Degrees |
| 1 | 0.162 | 0.122 | 0.135 |
| 2 | 0.166 | 0.137 | 0.116 |
| 3 | 0.089 | 0.101 | 0.093 |
| Average | 0.139 | 0.120 | 0.115 |
| RESULTS VALID FOR TWO YEARS: | | | |
| THE CALIBRATED EQUIPMENT IS WITHIN THE ACCURACY RANGE. | | | |
| THE CALIBRATED EQUIPMENT WAS NOT PREVIOUSLY ADJUSTED. | | | |
| Approval of Calibration Results | | | |
| BY CENACE: <u>(AUTHORIZED SIGNATURE)</u> Ing. Jorge Ortiz | BY HIDROABANICO: <u>(AUTHORIZED SIGNATURE)</u> Ing. Diego Peñaloza | BY EERC SUR: <u>(AUTHORIZED SIGNATURE)</u> Ing. Jorge Vera | |

ANNEX 5



Oficio No. HA-07- 51108 -

Quito, 12 de Diciembre de 2007

Señor Ingeniero
Gonzalo Uquillas
Director de Medición Comercial
CORPORACION CENACE
Presente.-

Ref: Recalibración medidores en Subestación Hidroabanco No. 2

De mi consideración:

Como es de su conocimiento la fecha de calibración y ajuste de medidores instalados en la Subestación Hidroabanco No. 2 vence el 12 de diciembre de 2007, por lo que de la manera más comecida solicito a Usted instruya a la persona que corresponda realice la recalibración de los 4 Medidores MAXSYS 2510 Instalados en al Subestación Hidroabanco No.2 y cuyos registros de calibración originales son los siguientes: CLB-480; CLB-481; CLB-482 y CLB-483.

Por la favorable atención que se digne en dar a la presente le antícpo mis agradecimientos

Muy Atentamente,

Hernán Flores E.
Gerente General



Av. amazonas N41-56
e isla fluviana
edf. amazonas, piso 4
tel. 593.2.244.5707 / 243.8228
fax: 593.2.244.5708
casilla: 171200230
e-mail: hidroabanco@gne.com.ec
quito. ecuador

TRANSLATION OF THE LETTER TO CENACE

(LOGO OF THE COMPANY)

Official Letter No. HA-07-00108

Quito, December 12, 2007

Engineer
Gonzalo Uquillas
Director of Commercial Measurement
CENACE CORPORATION
Quito, Ecuador

Ref.: Recalibration of Meters of Substation Hidroabanico No. 2

Dear Director,

As per your knowledge, the date of calibration and adjustment of meters installed in the Substation Hidroabanico No. 2 is due on December 12, 2007. For this reason, I respectfully request you to kindly order to the corresponding person to perform the recalibration of the 4 Meters branded MAXSYS, Type 2510, installed in the Substation Hidroabanico No.2, and whose original calibration records are the following: CLB480; CLB-481; CLB-482 and CLB-483.

I thank you in advance for your kind attention to this request.

Regards,

(AUTHORIZED SIGNATURE)
Hernán Flores E.
GENERAL MANAGER

(RECEIPT SEAL FROM
CENACE
PRESIDENT'S OFFICE
December 13, 2007)

(BELOW: HIDROABANICO ADDRESS AND CONTACTING INFORMATION)

TRANSLATION EXPERT
(1 LETTER AND 4 TABLES - FOREGOING):



Maria Fernanda Merino Noboa

ID/PASSPORT 170728487-1

I CERTIFY THAT I AM FLUENT IN BOTH ENGLISH AND SPANISH LANGUAGES AND THAT I HAVE PREPARED THE ATTACHED TRANSLATION FROM THE ORIGINAL IN THE SPANISH LANGUAGE TO THE BEST OF MY KNOWLEDGE AND BELIEF.

I ALSO CERTIFY THAT I AM IN THE LIST OF TRANSLATORS OF THE EMBASSY OF UNITED STATES OF AMERICA..

QUITO, MARCH 10, 2008


MARÍA FERNANDA MERINO NOBOA
ID./PASSPORT 170128487-1

ADDRESS: CALLE A No. 100 Y AV. EDMUNDO CARVAJAL, EDIF. IVSEMON TENNIS.
TORRE 1, PISO 1, QUITO-ECUADOR
E-Mail: mfmerino@centrode traducciones.com