

Langemarckstrasse 20  
45141 Essen  
Germany

Phone: +49 201 825-0  
Fax: +49 201 825-2517

Info.tncert@tuev-nord.de  
www.tuev-nord-cert.com

TÜV®

CDM Executive Board

Our / Your Reference

Contact  
Rainer Winter  
E-Mail: [rwinter@tuev-nord.de](mailto:rwinter@tuev-nord.de)

Direct Dial  
Phone: -3329  
Fax: -2139

Date  
09.07.2007

## Request for Review

"Termoelétrica Santa Adélia Cogeneration Project (TSACP)" (0200)

Dear Sir/Madam,

Please find below the response of the project participants (Termoelétrica Santa Adélia Ltda., Ecoinvest Assessorial Ltda.) and the TÜV NORD JI/CDM Certification Program to the requests for review for the above mentioned project no. 0200.

If you have any questions do not hesitate to contact us.

Yours sincerely,

TÜV NORD JI/CDM Certification Program



Rainer Winter

Request for Review (1-3)	
Issue raised by EB Members / DNA	<p><i>“The monitoring plan does not specify the requirement for monitoring of the fossil fuel used within the project boundary, but the monitoring methodology applied to this project activity stipulates this requirement. The DOE should have verified that no emissions from the consumption of the fossil fuel have been generated by the project activity in accordance with the approved methodology.”</i></p>
Response of project participant	<p>Methodology AM0015 requires the monitoring of CO<sub>2</sub> emissions from fossil fuels combusted due to the project activity at the project site, where relevant.</p> <p>The only emissions due to fossil fuels at the project site are due to the transportation of sugar cane, by trucks, to the sugar mill. This transportation existed already in the baseline, and did not change because of the project, so that there are no net changes in CO<sub>2</sub> emissions from fossil fuels due to the project activity. See annexed a document provided by Caldema, the boiler’s manufacturer, stating that the equipment was designed to burn sugar cane bagasse and must not be put in operation burning other types of fuels.</p> <p>Santa Adélia monitors constantly that there are no relevant sources of fossil fuel emissions due to the project activity at the project site, and confirms that project emissions are zero. This information will be included in the Monitoring Report.</p>
Response of DOE	<p>The equipment in operation to produce electricity at Termoelétrica Santa Adélia Cogeneration Project is not appropriate to combust fossil fuels. This was verified during the on-site visit. Moreover there were no evidences like a stockyard for fossil fuels, a natural gas connection or records of fossil fuel delivery at the project site that indicate any use of fossil fuels for combustion. Therefore it can be concluded that no emissions from the consumption of the fossil fuel have been generated in the project activity. Additional information has been included in the revised verification report (chapter 4.1.2).</p> <p>If this information (incl. the revised monitoring report and verification report) is not sufficient to close the request for review, we appoint Ms. Maria Carolina Crisci Coelho as our contact person.</p> <p>Ms. Maria Carolina Crisci Coelho BRTÜV Alameda Madeira, 222 - 3o. andar (floor) CEP (ZIP) 06454-010 Barueri - São Paulo - Brazil Phone: +55 11 4689.9400 Email: <a href="mailto:maria.carolina@brtuv.com.br">maria.carolina@brtuv.com.br</a></p>