

 CDM project activity issuance review form <i>(By submitting this form, a Party involved (through the designated national authority) or an Executive Board member may request that a review is undertaken)</i>	
Designated national authority/Executive Board member submitting this form (Name in print)	
Title of the proposed CDM project activity for which issuance is requested	0227 6MW Somanamaradi grid connected SHP in Karnataka, India
DOE that requested for issuance and date of request	DNV 16/05/08
Please indicate, in accordance with paragraphs 65 of the CDM modalities and procedures, for which reason(s) you request review. (Place a cross (X) in front of the reason)	
<input type="checkbox"/> <i>Fraud</i> <input type="checkbox"/> <i>Malfeasance</i> <input checked="" type="checkbox"/> <i>Incompetence</i>	
Please indicate reasons for the request for review and attach any supporting documentation to this request form. (if space is not sufficient please attach further reasons)	
<p>Further clarifications are required regarding:</p> <ol style="list-style-type: none"> 1. The emission reduction claimed in this monitoring period is 70% more than the estimation in the PDD; 2. The DOE closed the Corrective Action Request (CAR) 1 raised regarding the over capacity electricity generation based on the confirmation from the supplier of the turbine stating that the turbine “was designed and manufactured with a 10% overload capacity above rated capacity” and “the excess generation is within the 10% overload.” However, the electricity generated in December 2007 was found to be 12% above the rated capacity. 	
Section below to be filled in by UNFCCC secretariat	
Date received at UNFCCC secretariat	12.06.2008