

2nd Monitoring Period of Dongyue CDM

No.	The Time of Stop		The Time of Restart		Reason of Stop	How long time was it lasted	Is R22 still In Production?
1	5-Apr	14:01	5-Apr	17:32	Trouble of Combustion Air Fan	3h 31min	YES
2	10-Apr	21:30	10-Apr	22:10	Trouble of Low Pressure Steam(L.P.S.)	40min	YES
3	20-Apr	2:00	20-Apr	16:43	Examine the L.P.S.	14h 43min	NO
4	23-Apr	10:57	23-Apr	17:40	Electricity cut off	6h 43min	YES
5	26-Apr	6:05	28-Apr	15:02	Maintenance for the whole group (including R22 plant)	56h 57min	NO
6	12-May	0:16	12-May	1:55	Trouble of Diesel Oil (D.O.)	1h 39min	NO
7	19-May	11:35	19-May	17:10	Repairing the nozzle of D.O.	5h 35min	NO
8	21-May	9:25	21-May	11:22	The level of Waste Water Tank is HH	1h 57min	YES
9	21-May	20:02	21-May	21:29	Trouble of L.P.S.	1h 27min	YES
10	23-May	16:58	23-May	19:33	Examine the Analyzer	2h 35min	YES
11	23-May	21:14	23-May	21:47	Trouble of L.P.S.	33min	YES
12	24-May	1:11	24-May	2:00	Trouble of L.P.S.	49min	YES
13	25-May	17:04	26-May	0:51	Electricity cut off	7h 47min	NO
14	26-May	16:30	26-May	18:46	Examine and Repair the L.P.S.	2h 16min	YES
15	29-May	18:09	29-May	20:37	Clean the nozzle of D.O.	2h 28min	YES
16	31-May	23:40	1-Jun	0:12	The Pressure of Instrument Air is LL	32min	YES
17	3-Jun	19:46	3-Jun	21:06	Swich the Combustion Air Fans	1h 20min	YES
18	5-Jun	9:07	5-Jun	10:02	Troubles in the Drier of Instrument Air	55min	YES
19	11-Jun	6:07	11-Jun	9:37	Electricity cut off	3h 30min	NO
20	26-Jun	13:40	26-Jun	14:34	Examine the Thermometers of Incinerator	54min	YES
21	27-Jun	8:16	27-Jun	14:20	Clean the nozzle of D.O.and Swich The D.O. Pumps	6h 4min	YES