



Mr. Hans Jürgen Stehr  
Chair, CDM Executive Board  
UNFCCC Secretariat  
[CDMinfo@unfccc.int](mailto:CDMinfo@unfccc.int)

November 5, 2007

Re Request for review of the CDM project activity "Wigton Wind Farm Project (WWF)" (N°. 0239)

Dear Mr. Stehr,

SGS has been informed that the request for issuance of the CDM project activity "Wigton Wind Farm Project (WWF)" (N°. 0239) is under consideration for review because three requests for review have been received from members of the Board.

The requests for review are based on the same reasons outlined below. SGS would like to provide a response to the issues:

- 1. The monitoring plan and the approved methodology require double check of electricity supplied by the project activity with the receipt of sales. However, neither the monitoring report nor the verification report mentioned this double check. Further information is required on how the DOE verified the electricity generation of the project.*

**SGS Reply:**

During the site visit as part of the second periodic verification, the electricity generation of the project was checked against the receipt of sales as a double check of the electricity supplied by the project activity. Although this information had not been included in the monitoring report nor the verification report, the double check was performed as per the registered Monitoring Plan and approved methodology. We apologise for these omissions. Please find the revised verification report with the required amendments as Annex 1 to this response.

- 2. The DOE shall further clarify whether the repeated power outages in a short period in 2006 would have required recalibration/readjustment of the meter after the outage of the plant.*

**SGS Reply:**

The manufacturer of the meter has confirmed that it is not necessary to undertake a recalibration / re-adjustment of the meter following an outage of the power plant and that this situation does not affect the functionality of the meter. Please find the attached documents submitted by the meter's manufacturer and the supplier of the calibration services concerning this subject attached as Annexes 2, 3 and 4.

Therefore, we feel that the queries of the board members have been answered. We do however apologize if this was not sufficiently clear from the earlier verification and certification report.



Emilio Doens (+507 3170828) will be the contact person for the review process and is available to address questions from the Board during the consideration of the review in case the Executive Board wishes.

Yours sincerely

Sanjeev Kumar  
Technical Reviewer  
[Sanjeev.kumar@sgs.com](mailto:Sanjeev.kumar@sgs.com)  
T: +31 (0) 181693287  
M: +31 (0) 651851777

Emilio Doens  
Team Leader  
[emilio.doens@sgs.com](mailto:emilio.doens@sgs.com)  
T: + 507 3170828  
M: +507 67471425

Enclosed Documents:

- Annex 1 Verification Report
- Annex 2 Emails from PP
- Annex 3 Press release on extended warranty
- Annex 4 Excel file with the crosscheck with the electricity invoices
- Annex 5 Electricity sales invoices.