

 CDM project activity issuance review form <i>(By submitting this form, a Party involved (through the designated national authority) or an Executive Board member may request that a review is undertaken)</i>	
Designated national authority/Executive Board member submitting this form (Name in print)	
Title of the proposed CDM project activity for which issuance is requested	0274 TSIL – Waste Heat Recovery Based Power Project
DOE that requested for issuance and date of request	SGS 21/05/08
Please indicate, in accordance with paragraphs 65 of the CDM modalities and procedures, for which reason(s) you request review. (Place a cross (X) in front of the reason)	
☐ <i>Fraud</i> ☐ <i>Malfeasance</i> ☒ <i>Incompetence</i>	
Please indicate reasons for the request for review and attach any supporting documentation to this request form. (if space is not sufficient please attach further reasons)	
1. Following the monitoring plan, the auxiliary electricity consumption of the operational system was not measured, but calculated based on the power requirement of operating equipments and the running hours. Although the DOE verified that this is conservative, this is not in accordance with the applied methodology ACM0004 version1 which requires this parameter to be continuously measured. Further clarification is required on how the DOE verified this parameter in accordance with the applied methodology. 2. The outage hours were not reported, but it is required by the monitoring plan to be monitored. Further information is required.	
Section below to be filled in by UNFCCC secretariat	
Date received at UNFCCC secretariat	20.06.2008