

 <b>CDM project activity issuance review form</b> <i>(By submitting this form, a Party involved (through the designated national authority) or an Executive Board member may request that a review is undertaken)</i>	
<b>Designated national authority/Executive Board member submitting this form (Name in print)</b>	
<b>Title of the proposed CDM project activity for which issuance is requested</b>	0279 Lihir Geothermal Power Project
<b>DOE that requested for issuance and date of request</b>	SGS 03/04/08
<b>Please indicate, in accordance with paragraphs 65 of the CDM modalities and procedures, for which reason(s) you request review. (Place a cross (X) in front of the reason)</b>	
<input type="checkbox"/> <i>Fraud</i> <input type="checkbox"/> <i>Malfeasance</i> <input checked="" type="checkbox"/> <i>Incompetence</i>	
<b>Please indicate reasons for the request for review and attach any supporting documentation to this request form. (if space is not sufficient please attach further reasons)</b>	
<p>1. The DOE verified the calculation of emission reduction based a grid emission factor of 0.678 tCO<sub>2</sub>/MWh, which was calculated for the years 2002, 2003 and 2004 from the PDD. However, the monitoring plan requires the grid emission factor to be calculated yearly. Clarification is required.</p> <p>2. The verification report states that the project comprises of 5 steam turbines of 11 MW with total capacity 55 MW, while the monitoring report states that the first stage (30MW) stage and the installation of two turbines (20MW) brings the full energy producing capacity to 50MW. Clarification is required on this discrepancy.</p>	
<b>Section below to be filled in by UNFCCC secretariat</b>	
Date received at UNFCCC secretariat	02.04.2008