

CDM project activity issuance review form
(By submitting this form, a Party involved (through the designated national authority) or an Executive Board member may request that a review is undertaken)

authority) or an Executive Board member may request that a review is undertaken)	
Designated national authority/Executive Board member submitting this form (Name in print)	
Title of the proposed CDM project activity for which issuance is requested	0445 Demand side energy conservation & reduction measures at IPCL – Gandhar Complex
DOE that requested for issuance and date of request	DNV
Please indicate, in accordance with paragraphs 65 of the CDM modalities and procedures, for which reason(s) you request review. (Place a cross (X) in front of the reason)	
Fraud Malfeasance	eX_ Incompetence
Please indicate reasons for the request for review and attach any supporting documentation to this request form. (if space is not sufficient please attach further reasons)	
1. Some monitored refrigeration values in June and July 2006 exceed the nameplate capacity of VARs. For example, the monitored refrigeration of 730 TR/hr by VAR unit 1 in Ethylene Oxide-Ethylene Glycol plant on 29 June 2006 was over than 700 TR/hr stated in the PDD. Further clarification is required. 2. The sectoral scope mentioned in the monitoring report (p.2) should be corrected to "Manufacturing industries".	
Section below to be filled in by UNFCCC secretariat	
Date received at UNECCC secretariat	05/02/2008