


|  |  |
|--|--|
|  <b>CDM project activity issuance review form</b><br><i>(By submitting this form, a Party involved (through the designated national authority) or an Executive Board member may request that a review is undertaken)</i>  |  |
| <b>Designated national authority/Executive Board member submitting this form (Name in print)</b>   |  |
| <b>Title of the proposed CDM project activity for which issuance is requested</b>  | 0498 SIDPL Methane extraction and Power generation project |
| <b>DOE that requested for issuance and date of request</b>   | DNV<br>18/06/08  |
| <b>Please indicate, in accordance with paragraphs 65 of the CDM modalities and procedures, for which reason(s) you request review. (Place a cross (X) in front of the reason)</b>  |  |
| ___ <i>Fraud</i> ___ <i>Malfeasance</i> <u>X</u> <i>Incompetence</i>   |  |
| <b>Please indicate reasons for the request for review and attach any supporting documentation to this request form. (if space is not sufficient please attach further reasons)</b>   |  |
| <p>1. The auxiliary electricity consumption and the total power consumption at the waste water treatment system were not measured, but calculated based on the estimated total rated capacity of auxiliary equipment of the power plant and wastewater treatment system respectively and the operation days. This deviates from the monitoring plan which requires these two parameters to be measured. Clarification is required how the DOE verified these two parameters in line with the monitoring plan.</p> <p>2. The grid emission factor of 0.88318 tCO<sub>2</sub>/MWh has been used in the baseline emissions calculation , however is the validated value as stated I n the PDD is 0.883tCO<sub>2</sub>/MWh . Clarification is required how the DOE verified the conservativeness of the application of this value.</p> <p>3. Monitored values of parameters including the quantity and NCV of biomass used, pressure and temperature and density of methane, methane content of the biogas and volume of biogas sent to the engine were not contained in the monitoring report. Further information is required.</p> |  |
| <b>Section below to be filled in by UNFCCC secretariat</b>   |  |
| Date received at UNFCCC secretariat  | 14.06.2008   |