

 CDM project activity issuance review form <i>(By submitting this form, a Party involved (through the designated national authority) or an Executive Board member may request that a review is undertaken)</i>	
Designated national authority/Executive Board member submitting this form (Name in print)	
Title of the proposed CDM project activity for which issuance is requested	0649 Trojes Hydropower project
DOE that requested for issuance and date of request	DNV - 14/05/08
Please indicate, in accordance with paragraphs 65 of the CDM modalities and procedures, for which reason(s) you request review. (Place a cross (X) in front of the reason)	
<input type="checkbox"/> <i>Fraud</i> <input type="checkbox"/> <i>Malfeasance</i> <input checked="" type="checkbox"/> <i>Incompetence</i>	
Please indicate reasons for the request for review and attach any supporting documentation to this request form. (if space is not sufficient please attach further reasons)	
<ol style="list-style-type: none"> 1. The meters were not calibrated until November 2007, after the previous calibration conducted in March, 2003. Clarification is required on how DOE verified the requirement of at least three years of the measurement equipment calibration frequency as specified in EB 35, Annex 35 had been met. 2. The electricity supply has been based on the readings of the CFE main meter whose deviation was verified to be bigger than +/- 0.20% (0.2675%) in this monitoring period. In accordance with ICC, this meter was replaced in November 2007 which was after this monitoring period. Clarification is required on how the DOE verified the conservativeness of the emission reduction claimed in this monitoring period. 	
Section below to be filled in by UNFCCC secretariat	
Date received at UNFCCC secretariat	06.06.2008