

 CDM project activity issuance review form <i>(By submitting this form, a Party involved (through the designated national authority) or an Executive Board member may request that a review is undertaken)</i>	
Designated national authority/Executive Board member submitting this form (Name in print)	
Title of the proposed CDM project activity for which issuance is requested	0751 Sanquhar and Delta Small Hydro Power Projects
DOE that requested for issuance and date of request	DNV 06/05/08
Please indicate, in accordance with paragraphs 65 of the CDM modalities and procedures, for which reason(s) you request review. (Place a cross (X) in front of the reason)	
<input type="checkbox"/> <i>Fraud</i> <input type="checkbox"/> <i>Malfeasance</i> <input checked="" type="checkbox"/> <i>Incompetence</i>	
Please indicate reasons for the request for review and attach any supporting documentation to this request form. (if space is not sufficient please attach further reasons)	
<p>1. The monitoring plan specified cross checking of net electricity export recorded from meter installed by the Ceylon electricity Board (CEB) with the meter reading installed on low voltage side by the Hydro Power Free Lanka (HPFL). The DOE is requested to clarify whether this requirement of the monitoring plan has been met.</p> <p>2. Further clarification is required how the DOE verified the constant values of electricity imported for Sanquhar plant between January 2004 until June 2006 and July 2006 until April 2007.</p> <p>3. The monitoring plan specified a calibration frequency of one year for main electricity meter installed and maintained by CEB and frequency of three years for meter installed by HPFL used for cross checking. Further clarification is required how the DOE verified that this requirement has been met.</p>	
Section below to be filled in by UNFCCC secretariat	
Date received at UNFCCC secretariat	05.05.2008