



Monthly Performance Report

Customer	Dhanalaxmi Fabrics	Unit Size of Turbine	1.25 MW
Location (Site)	Dhulia	No. Of Turbine	1 K004
State	Maharashtra	Model No	S 64
Commissioning Date	31-March-2004	Installed Capacity (MW)	1.25

Month	Generation At Controller (kWh)	M/C Avail. %	Grid Avail %	Gen. At 100% Grid Avail. (kWh)	PLF At 100% Grid
Apr-04	169,094	94.99	54.11	312500	34.72
May-04	379,651	97.36	91.19	416330	44.77
Jun-04	396,651	98.40	88.75	446931	49.66
Jul-04	411,057	98.79	97.84	420132	45.18
Aug-04	517,996	99.06	98.01	528513	56.83
Sep-04	134,923	99.05	90.19	149599	16.62
Total For 2004-2005	2,009,372	97.94	86.68	2,274,005	41.30

Yearly PLF (%)

18.35

20.77



Monthly Performance Report

Customer	Arvind Cotsyn Ltd	Unit Size of Turbine	1.25 MW
Location (Site)	Dhulia	No. Of Turbine	1 K003
State	Maharashtra	Model No	S 64
Commissioning Date	31-March-2004	Installed Capacity (MW)	1.25

Month	Generation At Controller (kWh)	M/C Avail. %	Grid Avail %	Gen. At 100% Grid Avail. (kWh)	PLF At 100% Grid
Apr-04	80,835	82.87	41.76	193570	21.51
May-04	369,641	96.02	92.98	397549	42.75
Jun-04	368,759	98.18	74.40	495644	55.07
Jul-04	388,904	97.03	96.98	401015	43.12
Aug-04	501,512	99.11	98.36	509874	54.83
Sep-04	132,287	96.09	89.89	147165	16.35
Total For 2004-2005	1,841,938	94.88	82.40	2,144,817	38.94

Yearly PLF (%)

16.82

19.59



Monthly Performance Report

Customer	Runwal Industries	Unit Size of Turbine	1.25 MW
Location (Site)	Dhulia	No. Of Turbine	1 K006
State	Maharashtra	Model No	S 64
Commissioning Date	31-March-2004	Installed Capacity (MW)	1.25

Month	Generation At Controller (kWh)	M/C Avail. %	Grid Avail %	Gen. At 100% Grid Avail. (kWh)	PLF At 100% Grid
Apr-04	61,338	85.95	43.80	140041	15.56
May-04	378,285	95.51	93.72	403633	43.40
Jun-04	383,965	97.57	88.73	432734	48.08
Jul-04	405,092	98.94	97.16	416933	44.83
Aug-04	520,992	99.58	98.27	530164	57.01
Sep-04	129,983	99.10	90.61	143453	15.94
Total For 2004-2005	1,879,655	96.11	85.38	2,066,958	37.47

Yearly PLF (%)

17.17

18.88



Monthly Performance Report

Customer	Vanaz Engineers Ltd	Unit Size of Turbine	1.25 MW
Location (Site)	Dhulia	No. Of Turbine	1 K009
State	Maharashtra	Model No	S 64
Commissioning Date	31-March-2004	Installed Capacity (MW)	1.25

Month	Generation At Controller (kWh)	M/C Avail. %	Grid Avail %	Gen. At 100% Grid Avail. (kWh)	PLF At 100% Grid
Apr-04	95,489	88.24	48.91	195234	21.69
May-04	294,117	85.18	86.22	341124	36.68
Jun-04	345,938	93.65	84.44	409685	45.52
Jul-04	356,050	97.92	97.31	365893	39.34
Aug-04	461,934	98.90	98.31	469875	50.52
Sep-04	116,050	98.54	90.70	127949	14.22
Total For 2004-2005	1,669,578	93.74	84.32	1,909,760	34.66

Yearly PLF (%)	15.25			17.44	
Apr-04	21.69	88.24	48.91	195234	95489
May-04	36.68	85.18	86.22	341124	294117
Jun-04	45.52	93.65	84.44	409685	345938
Jul-04	39.34	97.92	97.31	365893	356050
Aug-04	50.52	98.90	98.31	469875	461934
Sep-04	14.22	98.54	90.70	127949	116050
Total For 2004-2005	34.66	93.74	84.32	1,909,760	1,669,578