CDM project activity issuance review form (By submitting this form, a Party involved (through the designated national authority) or an Executive Board member may request that a review is undertaken)		
Designated national authority/Executive Board member submitting this form (Name in print)		
Title of the proposed CDM project activity for which issuance is requested	0290 Youngduk W (issuance over year	/ind Park Project r 2007)
DOE that requested for issuance and date of request	JACO 14/03/08	
Please indicate, in accordance with paragraphs 65 of the CDM modalities and procedures, for which reason(s) you request review. (Place a cross (X) in front of the reason)		
Fraud Malfeasancex_ Incompetence		
Please indicate reasons for the request for review and attach any supporting documentation to this request form. (if space is not sufficient please attach further reasons)		
The DOE verified that the calibrations for the four meters measuring the electricity generation were carried out firstly at the time of first installation in September 2004 and secondly in August 2007. However according to the monitoring plan, "calibration shall be performed at the first installation, and shall be done every two years after the installation". Further clarification is required on how the DOE verified the calibrations of the meters in accordance with the monitoring plan.		
Section below to be filled in by UNF	CCC secretariat	
Date received at UNFCCC secretariat		12.04.2008