CLEAN DEVELOPMENT MECHANISM PROJECT DESIGN DOCUMENT FORM (CDM-SSC-PDD) Version 03 - in effect as of: 22 December 2006

CONTENTS

- A. General description of the small scale project activity
- B. Application of a <u>baseline and monitoring methodology</u>
- C. Duration of the project activity / crediting period
- D. Environmental impacts
- E. <u>Stakeholders'</u> comments

Annexes

Annex 1: Contact information on participants in the proposed small scale project activity

- Annex 2: Information regarding public funding
- Annex 3: Baseline information
- Annex 4: Monitoring Information
- Appendix 1: Table for steam cost
- Appendix 2: Evidence of Management Decision

Revision history of this document

Version	Date	Description and reason of revision
Number		
01	21 January 2003	Initial adoption
02	8 July 2005	 The Board agreed to revise the CDM SSC PDD to reflect guidance and clarifications provided by the Board since version 01 of this document. As a consequence, the guidelines for completing CDM SSC PDD have been revised accordingly to version 2. The latest version can be found at <<u>http://cdm.unfccc.int/Reference/Documents></u>.
03	22 December 2006	 The Board agreed to revise the CDM project design document for small-scale activities (CDM-SSC-PDD), taking into account CDM-PDD and CDM-NM.

SECTION A. General description of small-scale project activity

A.1 Title of the small-scale project activity:

>>

Energy efficiency and fuel switch project at Welspun India Limited.

 Version: 03,
 Gelöscht: 2

 Date: 04/08/2008
 Gelöscht: 1

 A.2. Description of the small-scale project activity:
 Gelöscht: 3

>> Back ground of the project

Welspun India Ltd. is engaged in the manufacturing of Textiles. The company is located at Vapi, Gujarat – India.

Purpose of the project

This project activity involves installation of an energy efficient 5.9 MW (at 35^o C ambient temperature) gas turbine with heat recovery steam generator (HRSG), a 6.79 MW gas engine generator with 1260 TR vapour absorption chillers (VAC). These measures replace use of lower efficient power systems which comprises of FO based Generating sets (2*2MW, 1*4MW and 1 * 6MW) with Exhaust Gas Boiler (EGB) (1*1.5TPH, 1*2.1TPH, 1*1.6TPH) for steam and power generation, FO based boilers (3*6TPH) for steam generation and centrifugal chillers (2*500TR, 1*390 TR) for chilled water generation. The 1260 TR Vapour Absorption Chiller will use the exhaust heat from the gas engine for chilled water generation and in turn replaces use of Centrifugal Chillers thereby reducing the electricity consumption for the equivalent amount of chilled water generation.

The project activity also involves switching of fuel from Furnace Oil to natural gas in electricity and steam generation at above applications and processes. The fuel switch measure is happening due to installation of new Natural Gas based Gas turbine and Gas engine which replaces use of FO based DG set. In addition the other fuel switch measure is happening for steam generation at the existing boilers where switching of fuel from furnace oil to natural gas is done at 2 of the 3 number of boilers. The HRSG in project activity also uses natural gas for additional steam generation in addition to the steam generation from the exhaust heat from the GT.

All these energy efficiency and fuel switch measures primarily aims at reducing GHG emission into the atmosphere per unit of output through increase in efficiency and switching of fuel from Furnace Oil (FO) to natural gas in electricity and, steam generation. Energy efficiency is also happening in chilled water generation.

The process flow diagram of the Baseline Scenario is elaborated in Annex 3 and Project Activity Scenario diagram is elaborated in section B.3.

Contribution of the project activity to sustainable development

Ministry of Environment and Forests, Govt. of India has stipulated the social well being, economic well being, environmental well being and technological well being as the four indicators for sustainable



development in the host country approval eligibility criteria for Clean Development Mechanism (CDM) projects¹.

Social well being

- The project demonstrates harnessing electricity and steam from cleaner source of fuel (natural gas).
- The project activity has generated 2 more employment opportunities.

Environmental well being

- The project results in reduced GHG intensity per unit of electricity and steam generation at the Welspun India site.
- The project reduces the local air pollutants and environmental impacts due to use of natural gas for power generation.
- This is the first project activity which is initiated by the project proponent in Vapi region. It has already encouraged other facilities irrespective of sector to adopt such kind of project.

Economic well being

This kind of fuel switch initiative will allow the Project developer to adopt cleaner fuel switch measures and get the carbon revenue benefit through implementation of this measure.

Technological well being

• This is a clean technology demonstration which uses natural gas for electricity, steam and chilled water generation.

A.3. <u>Project participants</u> :				
>>				
Name of Party involved	Private and/or public entity(ies)	Kindly indicate if the Party		
((host) indicates a host	project participants (as	involved wishes to be		
Party)	applicable)	considered as project		
		participant (Yes/No)		
India (Host)	Welspun India Ltd.	No		
United Kingdom	Cantor Fitzgerald Europe	No		

A.4. Technical description of the small-scale project activity:

A.4.1. Location of the small-scale project activity:

>>

A.4.1.1. <u>Host Party</u>(ies):

>>

India

¹ http://cdmindia.nic.in/host_approval_criteria.htm

	A.4.1.2.	Region/State/Province etc.:	
>>			
Western Re	gion, Gujarat		
	A.4.1.3.	City/Town/Community etc:	
>>			
Vapi			
	A.4.1.4.	Details of physical location, including information allowing the	
unique identification of this <u>small-scale project activity</u> :			

>>

The Welspun India Limited's manufacturing facility is located in Morai Village, Valsad District, Gujarat State. The Gas engines are located along the east-south periphery of the existing factory within the same premises.

The project site at Morai village is located at $20^{0}25^{\circ}$ North latitude and $72^{0}54^{\circ}$ East Longitude. It is located near the National Highway Number 8. Vapi is the nearest railway station and Daman airport is the nearest airport.



A.4.2. Type and category (ies) and technology/measure of the small-scale project activity:

>> Project Category Type II:Energy Efficiency Improvement Projects Category IID: Energy efficiency and fuel switching measures for industrial facilities II.D./Version 9 Sectoral Scope: 4 EB 31

Technology that was employed by the project activity

The capacity of the gas gas engine generator is 6.79 MW. M/s Rolls Royce Marine of Norway is the supplier of this gas engines. The rated Active Power capacity of the Generator is 6790 kW and rated Power (MCR) of the engine is 6945 kW. The capacity of the gas turbine is 5.9 MW. M/s Turbomach of Switzerland is the supplier of this gas turbine. The capacity of the gas turbine at continuous rating at Power shaft at ISO conditions is 7886 kW (gas fuel)

The Gas turbine being used by Welspun is of the model Taurus 70 which is a single shaft, axial flow design consisting of air inlet assembly, fourteen stage compressor with fixed and variable vane assemblies, compressor diffuser assembly, combustor assembly with annual combustion chamber, three stage turbine assembly, turbine exhaust diffuser and exhaust system connector. The Gas Engine being used is a 4-stroke, turbocharged, inter-cooled Bergen Gas Engine. The use of natural gas in the gas turbine and gas engine replace use of furnace oil at the DG set for electricity generation and at the boiler for steam production.

The project activity primarily aims at reducing GHG gas emission through increase in efficiency and switching Furnace Oil as a fuel to Natural Gas as a fuel in plant's power and steam generation. The installed power generating capacity of the project is 12.69 MW. Welspun India Limited has installed Vapour Absorption Chillers on waste exhaust gases of Gas Engine and steam generated from waste exhaust gases from Gas Turbine Generator Set.

Vapour Absorption Chiller capacity of 1260 TR is operating on waste exhaust heat of Gas Engine . The 1260 TR VAC replaces use of Centrifugal Chillers for equivalent amount of chilled water generation thereby reducing the electricity consumption.

The Vapour Absorption chillers has been imported from Broad Company of China, market leader in Vapour Absorption technology. The VAC uses exhaust heat instead of electrical energy to provide cooling. A thermal compressor consists of an absorber, a generator, a pump, and a throttling device, and replaces the mechanical vapour compressor.

In the Vapour Absorption chiller, refrigerant vapour from the evaporator is absorbed by a solution mixture in the absorber. This solution is then pumped to the generator. There the refrigerant is revaporized using a waste steam heat source. The refrigerant-depleted solution then returns to the absorber via a throttling device. The refrigerant/absorbent mixtures used in absorption chillers are water/lithium bromide.

All the aforementioned technologies applied in the project activity are environmentally safe and sound.

A.4.3 Estimated amount of emission	reductions over the chosen <u>crediting period</u> :		
>>			
Total Chosen Crediting peri	Total Chosen Crediting period (June 2008 to May 2018)		
Years	Annual estimation reductions in		
	tonnes of CO ₂ e		
June 2008 – May 2009	35131		
June 2009 – May 2010	35131		
June 2010 – May 2011	35131		
June 2011 – May 2012	35131		
June 2012 – May 2013	35131		
June 2013 – May 2014	35131		
June 2014 – May 2015	35131		
June 2015 – May 2016	35131		
June 2016 – May 2017	35131		
June 2017 – May 2018	35131		
Total estimated reductions			
(tonnes of CO ₂ e)	351310		
Total number of crediting years	10		
Annual average of the estimated reduction			
over the crediting period	35131		

A.4.4. Public funding of the small-scale project activity:

>>

Public funding from Annex I and diversion of ODA is not involved in this project.

A.4.5. Confirmation that the small-scale project activity is not a debundled component of a large scale project activity:

As mentioned under Appendix C of the Simplified Modalities and Procedures for Small-Scale CDM project Activities, the following results into debundling of large CDM project:

"A proposed small-scale project activity shall be deemed to be a debundled component of a large project activity if there is a registered small-scale CDM project activity or an application to register another small-scale CDM project activity:

- With the same project participants;
- In the same project category and technology/measure; and .
- Registered within the previous 2 years; and
- Whose project boundary is within 1 km of the project boundary of the proposed small-scale activity at the closest point."

The identified CDM project is being promoted by Welspun India Ltd.

With reference to aforementioned points of de-bundling, the project activity does not comply with any of the above conditions, therefore, the project activity is considered as small scale CDM project activity.

SECTION B. Application of a baseline and monitoring methodology

B.1. Title and reference of the <u>approved baseline and monitoring methodology</u> applied to the <u>small-scale project activity</u>:

>>

Project has applied approved methodology available for small-scale CDM project at UNFCCC website under Appendix B of the simplified modalities and procedures for small-scale CDM project activities

Type II:Energy Efficiency Improvement Projects Category D: Energy efficiency and fuel switching measures for industrial facilities Reference: II.D./Version 9 Scope: 4 EB31

B.2 Justification of the choice of the project category:

According to the selected methodology for the small scale CDM project the baseline has defined as: **Type II:Energy Efficiency Improvement Projects**

Category D: Energy efficiency and fuel switching measures for industrial facilities

This category comprises any energy efficiency and fuel switching measure implemented at a single industrial or mining and mineral production facility. This category covers project activities aimed primarily at energy efficiency; a project activity that involves primarily fuel switching falls into category III.B. Examples include energy efficiency measures (such as efficient motors), fuel switching measures (such as switching from steam or compressed air to electricity) and efficiency measures for specific industrial or mining and mineral production processes (such as steel furnaces, paper drying, tobacco curing, etc.). The measures may replace, modify or retrofit existing facilities or be installed in a new facility. The aggregate energy savings of a single project may not exceed the equivalent of 60 GWhe per year is equivalent to a maximal saving of 180 GWhth per year in fuel input.

The applicability of the above mentioned methodology can be explained in the following given arguments:

- The Energy Efficiency and fuel switching measure is implemented at the single industrial facility at Welspun India Limited, Vapi.
- This project activity involves installation of an energy efficient 5.9 MW (at 35⁰ C ambient temperature) gas turbine with heat recovery steam generator, a 6.79 MW gas engine with 1260 TR vapour absorption chiller. These measures replace use of lower efficient systems which comprise of FO based Generating sets (2*2MW, 1*4MW and 1 * 6MW) with Exhaust Gas Boilers (EGB) (1*1.5TPH, 1*2.1TPH, 1*1.6TPH) for steam and power generation, modification of FO based boilers (2 out of the 3*6TPH) for steam generation and replacement of centrifugal chiller (2*500TR, 1*390 TR) for chilled water generation.

1260 TR Vapour Absorption Chillers will use the exhaust heat from the gas engine for chilled water generation and in turn replaces use of Conventional Centrifugal Chillers for the equivalent amount of chilled water generation thereby reducing the electricity consumption for chilled water generation. Thus project activity aims at GHG reductions into the atmosphere primarily by implementing energy efficiency measure for generation of electricity, steam and chilled water leading to decrease in consumption of fossil fuel quantities per unit of output.

- The project activity replaces furnace oil with the natural gas for power and steam generation.
- The aggregate fuel input saving of the project activity is 66.19 GWhth per annum.

From the above discussion, it can be concluded that project meets all the applicability criteria set under the selected approved small scale CDM methodology and hence the project category is applicable to the CDM project.

B.3. Description of the project boundary:

Boundary –According to the selected approved project category the project boundary is the physical, geographical site of the industrial or mining and mineral production facility, processes or equipment that are affected by the project activity.

The Physical boundary in this case consists of the Power Plant and the boiler house at Welspun India Ltd. . The equipments that are affected by the project activity are :

- 1. 5.9 MW Gas Turbine Generator Set with Heat Recovery Steam Generator (HRSG).
- 2. 6.79 MW Gas Engine Generator Set.
- 3. 1260 TR VAC

>>

4. Two numbers of 6 Tons Per Hour Natural Gas fired Boilers.



It is to be noted that the Boiler number 1 as shown in the diagram above is F.O fired boiler and will be used only in case of emergency. Though it is not the part of project boundary, the same has been shown in the diagram as the reading of the water flow meter W7 will be used in determining the total steam produced by the Natural Gas based Boilers (Boiler number 2^{nd} and 3^{rd}) in the project activity to ensure that the steam produced during the emergency by Boiler number 1 is not accounted for in the emission reduction calculation. (i.e. $ST_p = W1+W2+W3+W4+W5+W6-W7$).

Source	Gas	Included?	Justification / Explanation
Fuel Consumption for electricity	CO ₂	Yes	Main emission source.
generation (DG sets)	CH ₄	No	Excluded for simplification.
	N ₂ O	No	Excluded for simplification.
Fuel Consumption for steam	CO ₂	Yes	Main emission source.
generation (boilers)	CH ₄	No	Excluded for simplification.
()	N ₂ O	No	Excluded for simplification.
Electricity Consumption (CO ₂	Yes	Main emission source.
Centrifugal Chiller)	CH ₄	No	Excluded for simplification.
	N ₂ O	No	Excluded for simplification.
Fuel Consumption for electricity	CO ₂	Yes	Main emission source.
generation (Gas Turbine and Gas	CH ₄	No	Excluded for simplification.
Engine)	N ₂ O	No	Excluded for simplification.
Fuel Consumption for steam	CO ₂	Yes	Main emission source.
generation (Boiler)	CH ₄	No	Excluded for simplification
	N ₂ O	No	Excluded for simplification
Electricity Consumption (CO ₂	Yes	Main emission source.
Vapour Absoprtion Chiller)	CH ₄	No	Excluded for simplification
	N ₂ O	No	Excluded for simplification
	Source Fuel Consumption for electricity generation (DG sets) Fuel Consumption for steam generation (boilers) Electricity Consumption (Centrifugal Chiller) Fuel Consumption for electricity generation (Gas Turbine and Gas Engine) Fuel Consumption for steam generation (Boiler) Electricity Consumption (Boiler) Electricity Consumption (Vapour Absoption Chiller)	SourceGasFuel Consumption for electricity generation (DG sets)CH4N2ON2OFuel Consumption for steam generation (boilers)CH2Electricity Consumption (Centrifugal Chiller)CO2Fuel Consumption (Centrifugal Chiller)CO2Fuel Consumption (Centrifugal Chiller)CO2Fuel Consumption (Centrifugal Chiller)CO2Fuel Consumption for electricity generation (Gas Turbine and Gas Engine)CO2Fuel Consumption for steam generation (Gas Turbine and Gas Engine)CO2Fuel Consumption for steam generation (Gas 	SourceGasIncluded?Fuel Consumption for electricity generation (DG sets)CO2YesRuel Consumption for steam generation (boilers)CO2YesFuel Consumption for steam generation (boilers)CO2YesRuel Consumption (boilers)CO2YesRuel Consumption (boilers)CO2YesRuel Consumption (Centrifugal Chiller)CO2YesSumption (Centrifugal Chiller)CO2YesRuel Consumption for electricity generation (Gas Turbine and Gas Engine)CO2YesFuel Consumption for steam generation (Gas Turbine and Gas Engine)CO2YesFuel Consumption for steam generation (Gas Turbine and Gas Engine)CO2YesFuel Consumption for steam generation (Gas for steam generation (Gas fo

B.4. Description of <u>baseline and its development</u>:

>>

As per the methodology:

Type II D

- In the case of replacement, modification or retrofit measures, the baseline consists of the energy baseline of the existing facility or sub-system that is replaced, modified or retrofitted. In the case of a new facility the energy baseline consists of the facility that would otherwise be built.
- In the absence of the CDM project activity, the existing facility would continue to consume energy (ECbaseline, in GWh/year) at historical average levels (EChistorical, in GWh/year), until the time at which the industrial or mining and mineral production facility would be likely to be replaced, modified or retrofitted in the absence of the CDM project activity (DATEBaselineRetrofit). From that point of time onwards, the baseline scenario is assumed to correspond to the project activity, and baseline energy consumption (ECbaseline) is assumed to equal project energy consumption (ECy, in GWh/year), and no emission reductions are assumed to occur.

ECbaseline = EChistorical until DATEBaselineRetrofit

ECbaseline = ECy on/after DATEBaselineRetrofit

In order to estimate the point in time when the existing equipment would need to be replaced in the absence of the project activity (DATEBaselineRetrofit), project participants may take the following approaches into account:

(a) The typical average technical lifetime of the equipment type may be determined and documented, taking into account common practices in the sector and country, e.g. based on industry surveys, statistics, technical literature, etc.

(b) The common practices of the responsible industry regarding replacement schedules may be evaluated and documented, e.g. based on historical replacement records for similar equipment. The point in time when the existing equipment would need to be replaced in the absence of the project activity should be chosen in a conservative manner, i.e. if a range is identified, the earliest date should be chosen.

• Each energy form in the emission baseline is multiplied by an emission coefficient (in kg CO₂e/kWh). For the electricity displaced, the emission coefficient is calculated in accordance with provisions under category I.D. For fossil fuels, the IPCC default values for emission coefficients may be used.

As per the methodology AMS II D the baseline scenario consists of the energy baseline of the existing facility or sub-system that is replaced, modified or retrofitted. Therefore the project proponent can continue the current business as usual practice of producing electricity from the DG set, steam from the boiler and exhaust gas boiler and operation of centrifugal chiller. In this case FO is used as the input fuel in the DG sets and boilers and electricity generated in the DG sets is used in the centrifugal chiller.

The project activity replaces the use of FO based DG set and centrifugal chillers which will be used as stand by for operation under emergency situations at the existing facility. The documents related to the residual lifetime of all the equipments has been submitted to the DOE to prove that the residual lifetime of all the equipments are more than the crediting period of the current project activity. The equipments have been assessed by Chartered Engineer on the basis of following factors:

- Local environment in which machine has been installed and is being operated: Local environment is free from pollutants and aggressive chemicals which can harm DG Set, Boilers and chillers.
- Operating parameters: Operating parameters were checked and compared with parameters recorded during commissioning and were found to be within range specified by manufacturer.
- Maintenance records: Maintenance records were verified and found to be done as per manufacturer guidelines.
- General condition of machines: Cylinder head covers, cam shaft covers and crankcase covers were opened to check the conditions of parts and these were found to be in perfect condition for DG Sets. Boiler internal and external inspection was carried out parts were in good condition.

The residual lifetime of the major equipments being retired due to this project activity were assessed as :

Equipment	Year of	Remaining
	installation	Life (year) as
		<u>on</u>
		September
		<u>2007</u>
<u>DG Set No. 1 (2140 kW)</u>	<u>1995</u>	<u>12</u>
<u>DG Set No. 3 (6220 kW)</u>	<u>1998</u>	<u>15</u>
<u>DG Set No. 4 (4206 kW)</u>	<u>2002</u>	<u>19</u>
EGB-1 with DG-1 (1.5 TPH at 10.5 kg/cm ²)	<u>1998</u>	<u>30</u>
EGB-2 with DG-3 (2.24 TPH at 10.5 kg/cm ²)	<u>1998</u>	<u>30</u>
EGB-3 with DG-4 (1.87 TPH at 10.5 kg/cm ²)	<u>2003</u>	<u>35</u>
Boiler -1 (6 TPH at 10.5 kg/cm ²)	<u>1994</u>	<u>26</u>
Boiler -2(6 TPH at 10.5 kg/cm ²)	<u>1999</u>	<u>31</u>
<u>Boiler – 3 (6 TPH at 10.5 kg/cm²)</u>	<u>1999</u>	<u>31</u>
Chiller – PEH 087	2001	<u>18</u>
Chiller – HS 400 S	1997	14

Formatiert: Nummerierung und Aufzählungszeichen

Gelöscht: <#>Local environment in which machine has been installed and is being operated¶ <#>Operating parameters¶ <#>Maintenance records¶ <#>General condition of machines¶

Since all the major equipments had remaining life time more than 10years, the DATEBaselineRetrofit is the year 2019 which beyond the crediting period opted by the project participant. Hence ECbaseline = EChistorical for the entire crediting period

The project activity aims at GHG reductions into the atmosphere primarily due to increased energy efficiency resulting in decrease in fossil fuel quantities per unit of output and switch over of fuel to low carbon intensive fuel. In the absence of the project activity the baseline would be consumption of furnace oil as fuel for power, steam generation and continuation of the use of centrifugal chillers. Therefore the emissions at the baseline are the emissions that would have occurred due to the use of lower efficient DG sets and burning of the fossil fuel i.e. Furnace Oil in the DG sets engines, boilers, and the consumption of electricity by centrifugal chillers.

Type II D

Baseline Emissions

Baseline emissions have been calculated using the actual data of consumption and generation for the year 2005 and 2006.

 $BE=SE_1 \times EG_{PA} + SE2 \times ST_P + E_{CB}$

- BE = Total Baseline emissions (tCO_2e) per annum.
- SE_1 = Specific Emission Factor for Electricity Generation in baseline (tCO₂e/kWh)
- EG_{PA} = Electricity generated in Project activity(kWh) per annum.
- SE₂ = Specific Emission Factor for Steam Generation in baseline(tCO₂e/Kg)
- ST_P = Steam Generated during the Project Activity (steam from HRSG and boilers) (Kg) per annum.
- E_{CB} = Baseline Emissions from Centrifugal Chiller in Baseline activity for chilled water generation (tCO₂e) per annum.

 $SE_1 = E_{GB} / EG_{BA}$

- E_{GB} = Emissions from Electricity Generation in Baseline Activity (tCO₂e) in the year 2005 and 2006.
- EG_{BA} = Electricity generated by DG sets in the baseline scenario (kWh) in the year 2005 and 2006.

 $SE_2 = E_{SB} / ST_{total}$

SE₂= Specific emission for steam generation in baseline activity (tCO₂e/Kg)

- E_{SB}=Emissions from Steam Generation in Baseline (tCO₂e) in the year 2005 and 2006.
- ST_{total} = Total steam generated in baseline (Kg) in the year 2005 and 2006.

 $ST_{total} = ST_{B1} + ST_{B2}$

ST_{B1}=Quantity of Steam Generated from 3 Boilers in baseline (Kg) in the year 2005 and 2006.

 ST_{B2} = Quantity of steam generated from 3 Exhaust Gas Boilers in (Kg) baseline in the year 2005 and 2006.

Emission for Electricity Generation

 $E_{GB} = Q_{FOB1} \times D_{FOB} \times NCV_{FOB} \times (4.186/10^{9}) \times EF_{FO}/1000$

- E_{GB} = Emissions from Electricity Generation in Baseline Activity (tCO₂e) in the year 2005 and 2006.
- Q_{FOB1} =Quantity of Furnace Oil consumed in DG Sets (liters) in the year 2005 and 2006.

D_{FOB} =Density of FO (kg/liters)

NCV_{FOB} =Net calorific value of Furnace Oil (kcal/kg)

4.186/10^9 =Conversion from kcal to TJ

 EF_{FO} = Effective CO₂ Emission Factor of Furnace Oil (kgCO2e/TJ)

 $SE_1 = E_{GB} / EG_{BA}$

 E_{GB} =Emissions from Electricity Generation in Baseline Activity (tCO₂e) in the year 2005 and 2006. EG_{BA} = Electricity generated by DG sets in the baseline scenario (kWh) in the year 2005 & 2006.

Emission for Steam Generation



- $E_{SB} = Q_{FOB2} \times D_{FOB} \times NCV_{FOB} \times (4.186/10^{9}) \times EF_{FO}/1000$
- E_{SB} =Emissions from Steam Generation in Baseline Activity (tCO₂e) in the year 2005 and 2006.
- Q_{FOB2} =Quantity of Furnace Oil consumed in 3 Boilers (liters) in the year 2005 and 2006.
- D_{FOB} =Density of FO (kg/liters)

 NCV_{FOB} =Net calorific value of Furnace Oil (kcal/kg)

4.186/10^9 =Conversion from kcal to TJ

 EF_{FO} = Effective CO₂ Emission Factor of Furnace Oil (kgCO2e/TJ)

 $SE_2 = E_{SB} / ST_{total}$

 SE_2 = Specific emission for steam generation in baseline activity (tCO₂e/Kg)

- E_{SB} =Emissions from Steam Generation in Baseline (tCO₂e) in the year 2005 and 2006.
- ST_{total} = Total steam generated in baseline (Kg) in the year 2005 and 2006.
- $ST_{total} = ST_{B1} + ST_{B2}$
- ST_{B1}=Quantity of Steam Generated from 3 Boilers in baseline (Kg) in the year 2005 and 2006.
- ST_{B2} = Quantity of steam generated from 3 Exhaust Gas Boilers in (Kg) baseline in the year 2005 and 2006.

Emission for Chilled water generation

The baseline scenario involves 2 centrifugal chillers having cooling capacity of 500 TR each and 1 centrifugal chiller having cooling capacity of 390 TR. The electricity consumption figure for the year 2005 and 2006 has been considered for determining baseline emissions.

Actual refrigeration generated was monitored. However as a conservative approach we have considered total cooling capacity of the centrifugal chiller as the cooling capacity factor in the specific power consumption calculation of power driven centrifugal chillers.

 E_{CB} = SE₃ x R_P x OH_P×SE_P

- E_{CB} =Emissions from Centrifugal Chiller in Baseline activity for chilled water generation (tCO_{2e}) per annum.
- SE_3 = Specific Power Consumption of centrifugal chiller (kW/TR).
- R_P =VAC Cooling Capacity (TR)
- OH_P = Operating hours of VAC in a year (Hours)
- SE_P = Specific Emission Factor for electricity generation in Project Scenario (tCO₂e/kWh)

SE3=EC_{chillers} / R_B

 $EC_{chillers}$ = Power consumption by 3 centrifugal chillers in baseline activity in 2005 and 2006(kWh). R_B =Total Cooling Generated in the year 2005 & 2006(TR)

 $R_{B} = R_{1} \times OH_{1} + R_{2} \times OH_{2} + R_{3} \times OH_{3}$

 R_B =Total Cooling Generated in the year 2005 & 2006 (TR).

R₁ =Rated Capacity of McQuay – PH1 Centrifugal Chillers (TR.

OH₁ = Operating Hours of McQuay - PH1 Centrifugal Chillers for the year 2005 & 2006.

R₂ = Rated Capacity of McQuay – PH2 Centrifugal Chillers (TR).

 OH_2 = Operating Hours of McQuay - PH2 Centrifugal Chillers for the yer 2005 & 2006.

R₃ = Rated Capacity of Voltas Centrifugal Chillers (TR).

OH₃ = Operating Hours of Voltas Centrifugal Chillers (TR) for the year 2005 & 2006.

Variable	Data Source
Q _{FOB1} – Quantity of Furnace Oil Consumed in	Plant record for 2005 and 2006
4 DG Sets	
QFOB2 - Quantity of Furnace Oil Consumed in	Plant Record for 2005 and 2006
3 Boilers	
EC _{Chillers} - Electricity Consumed by the 3	Plant Record for 2005 and 2006
centrifugal chillers	
EG _{BA} – Electricity generated by the 4 DG sets	Plant Record for 2005 and 2006
ST_{B1} – Quantity of Steam generated from 3	Plant Record for 2005 and 2006
Boilers	
ST_{B2} – Quantity of Steam generated from 3	Plant Record for 2005 and 2006
Exhaust Gas boilers	
Operating Hours for chillers	Plant Record for 2005 and 2006
Parameter	Data Source
NCV _{FO} – Calorific value of Furnace Oil	As per IS:1448 [P : 7] – 1960
EF _{FO} - Emission Factor of Furnace Oil	IPCC Default Value, Table 1.4, Chapter 1, Volume 2,
	2006 IPCC Guidelines for National Greenhouse Gas
	Inventories
Rated Capacity of Chillers	Technical Specification

Refer to Annexure 3 for further information

B.5. Description of how the anthropogenic emissions of GHG by sources are reduced below those that would have occurred in the absence of the registered <u>small-scale</u> CDM project activity:

As explained above, the project initiative qualifies under Type IID- Energy efficiency and fuel switching measures for industrial facilities. The following paragraph has been detailed on project additionality.

In response to decision 1/CMP.2 (paragraph 15(a)), which encouraged the Board to provide non-binding best practice examples on the demonstration of additionality to assist the development of project design documents, in particular for small-scale project activities, after considering public input and an expert assessment, the Board at its thirty-fifth meeting agreed to provide the following examples:

Project participants shall provide an explanation to show that the project activity would not have occurred anyway due to at least one of the following barriers:

- Investment barrier:
- Technological barrier:
- Barrier due to prevailing practice:
- Other barriers

The barriers that has been overcome by the project developer is listed below: a) Investment barrier

Investment Barrier:

The project activity envisages switching of fuel from Furnace Oil to Natural gas for electricity and steam generation and installation of VAC (with an installed capacity 1260 TR) replacing the Centrifugal Chillers. The investment would reduce the emission of GHGs into the atmosphere (a) on account of the use of lesser GHG emissive fuels for steam and power generation and (b) due to the reduced consumption of electricity for the chilled water generation and (c) fuel saving due to steam generation from the exhaust heat from the GT at the HRSG. Therefore, the baseline scenario is FO based electricity and steam generation and utilization of Centrifugal chillers.

The project is a small scale project activity. Nevertheless, the PP has chosen to establish the additionality of the project activity using the NPV financial tool. Several financial indicators like IRR, NPV, Cost Benefit Analysis and Levelized unit cost of electricity are available to demonstrate the additionality. Invariably, the choice is between NPV and IRR. NPV, as opposed to IRR is a direct measure of the rupee economic value (or loss) expected on a project and thus facilitates quick decision making. Both NPV and IRR methods involve discounted cash flow analysis, the mathematics of which affects the rate that a project's cash flows can be reinvested during the life of the project. The reinvestment rate embedded in NPV is the project's cost of capital. The reinvestment rate assumed under IRR is the IRR rate itself. Reinvestment at the cost of capital is a better and correct assumption. These features render NPV as a superior financial indicator as compared to IRR for this project activity.

The baseline is compared with the proposed project activity using following parameters to demostrate additionality

- Cost of generation of electricity
- Benefit from steam generation from HRSG (refer to Appendix 1)
- Reduction in electricity consumption for chilled water generation

Investment decision of the project activity is based on NPV . NPV is computed as the difference in the cash flow derived from the cost of generation of electricity and steam in the project activity and the baseline activity. The differential cash flow takes into account

- Cost of generation of electricity
- Benefit from steam generation from HRSG (refer to Appendix 1)
- Reduction in electricity consumption for chilled water generation
 - 17

Due to cost difference between natural gas and FO, as well as the initial investment required to be made, the differential cash flow is negative in the initial years and positive in the later years. The Project participant has computed the cash flow differential for a period of 15 years – being the life of the project. The negative cash flow differential in the initial years has been taken as the cash outflow. Further more as a conservative approach, the initial investment in VAC and conversion of 2 numbers of Furnace Oil fired Boilers to Natural Gas fired boilers has not been considered in the financial analysis. The inclusion of these investments would only further strengthen and reinforce the additionality conclusion.

In the instant case, the entire project activity is financed by loan from bank. This loan carry interest at 9%._Discount rate for NPV calculation is taken as 9% which is equal to the interest on loan It is imperative that the net cash flows discounted at the benchmark – being the interest rate on loan – should be atleast zero if not positive. A negative NPV is indicative of the financial unattractiveness of the project..

In order to compute the differential cash flows, the PP has made certain assumptions, which together with the basis for making such assumptions are as follows:

Furnace Oil Generator	Units	Value	Basis
Furnace Oil (FO) Generator Output	KWe	14000	Technical Specification
Auxiliary consumption	%	4.00	Plant data
Net Calorific Value of FO	Kcal/Kg	9842	Supplier Invoice
Heat rate at Generator terminal	Kcal/kwhe	2059	Supplier Data
Genset loading	%	81.30	Plant Data
No. of days working	days	350	Plant Data
No. of hours working	hours	24	Plant Data
Lube oil consumption	Grams/kwhe	0.70	Plant Data
Lube Oil cost	Rs./Kg.	90.00	Supplier Invoice
FO landed cost	Rs./Kg.	9.93	Supplier Invoice
Escalation in FO and Lube oil cost	% p.a.	4.00	Past supplier invoice
Spares and O&M cost	Re/kWh	0.25	Plant Data
Stocking period of FO	days	15	Plant Data
O & M expenses	month	1.00	Plant Data
Lube oil	month	2.00	Plant Data
Bank interest	%	9.00	Loan sanction letter
Natural Gas			
N.G. Generator output – GTG	kWe	5900	Technical Specification
- GDG	kWe	6790	Technical Specification
Auxiliary consumption – GTG	%	1.08	Technical Specification

- GDG		%	2.25	Technical Specification
Net Calorific Value of NG	Kcal/SCM	8350	Supplier's invoice	
Heat rate at Generator termi	nal - GTG	Kcal/kwhe	2808	Tech.input from supplier
	- GDG	Kcal/kwhe	1960	Tech. input from supplier
Genset loading	GTG	%	95.00	Plant Data /Tech. Specs.
	- GDG		70.00	Plant Data / Tech. Spec.
No. of days working		days	350	Plant Data
No. of hours working		hours	24	Plant Data
Lube oil consumption	- GTG	Grams/kwhe	0.10	Tech. Specs.
	- GDG	Grams/kwhe	0.42	Tech. Specs
Total equipment cost	- GTG	Rs. Lakhs	1857	CAPEX document
	- GDG	Rs. lakhs	1463	CAPEX Document
Amortisation period of loan		Year	6.00	Loan sanction letter
Initial Moratorium		Year	1.00	Loan sanction letter
Interest on term loan		%	9.00	Loan sanction letter
NG landed cost		Rs./SCM	9.70	Supplier data
Lube oil cost		Rs./Kg.	90.00	Historical data
Escalation in NG and Lube oil cost		% p.a.	4.00	Historical data
Spares and O&M cost		Re/kWh	0.25	Tech. Specs.
Rate of depreciation		%	10.34	Company's Act,
Steam generation		TPH	14.00	Plant data
Steam credit		Re./Kg.	0.73	Computed (Refer to Apepndix -1))

The financial analysis made, based on the above assumptions, reveals that the fuel switch and chiller switch are not financially attractive as the NPV (of net cash flows discounted at 9%) without CDM revenues is (-) Rs. 100.52 million. The economically attractive scenario will be the use of furnace oil for power and steam generation and use of centrifugal chillers for chilled water generation. However, when the benefits from CDM revenues are taken into account (considering CERs at Euro 14/tCO2 and an exchange rate of Rs.57 per Euro), the NPV becomes positive at Rs.79.39 million. Therefore, it is only with credits from GHG emission reductions that the PP can hope to reduce the deficit.

Thus from the above discussion it can be concluded that the project activity faces the investment barrier and is not a business as usual scenario.

As the starting date of project activity is before the commencement of validation, the evidence of serious consideration of CDM benefit in the form of Board of directors resolution dated 30th July 2004 is incorporated in Appendix 2 of this PDD.

B.6. Emission reductions:

B.6.1. Explanation of methodological choices:

In the absence of the project activity the baseline would be consumption of furnace oil as fuel for power generation and steam generation.

Baseline Emissions

 $BE=SE_1 \times EG_{PA} + SE2 \times ST_P + E_{CB}$

BE = Total Baseline emissions (tCO_2e) per annum.

- SE_1 = Specific Emission Factor for Electricity Generation in baseline (tCO₂e/kWh)
- EG_{PA} = Electricity generated in Project activity(kWh) per annum.
- SE_2 = Specific Emission Factor for Steam Generation in baseline(tCO₂e/Kg)
- ST_P = Steam Generated during the Project Activity (steam from HRSG and boilers) (Kg) per annum.
- E_{CB} = Baseline Emissions from Centrifugal Chiller in Baseline activity for chilled water generation (tCO₂e) per annum.

 $SE_1 = E_{GB} / EG_{BA}$

 E_{GB} = Emissions from Electricity Generation in Baseline Activity (tCO₂e) in the year 2005 and 2006 EG_{BA} = Electricity generated by DG sets in the baseline scenario (kWh) in the year 2005 and 2006

 $SE_2 = E_{SB} / ST_{total}$

SE₂= Specific emission for steam generation in baseline activity (tCO₂e/Kg)

- E_{SB} =Emissions from Steam Generation in Baseline (tCO₂e) in the year 2005 and 2006.
- ST_{total} = Total steam generated in baseline (Kg) in the year 2005 and 2006.
- $ST_{total} = ST_{B1} + ST_{B2}$
- ST_{B1}=Quantity of Steam Generated from 3 Boilers in baseline (Kg) in the year 2005 and 2006.
- ST_{B2} = Quantity of steam generated from 3 Exhaust Gas Boilers in (Kg) baseline in the year 2005 and 2006.

Emission for Electricity Generation

 $E_{GB} = Q_{FOB1} \times D_{FOB} \times NCV_{FOB} \times (4.186/10^{9}) \times EF_{FO}/1000$

- E_{GB} =Emissions from Electricity Generation in Baseline Activity (tCO₂e) in the year 2005 and 2006.
- Q_{FOB1} =Quantity of Furnace Oil consumed in DG Sets (liters) in the year 2005 and 2006.
- D_{FOB} =Density of FO (kg/liters).
- NCV_{FOB} =Net calorific value of Furnace Oil (kcal/kg)
- 4.186/10^9 =Conversion from kcal to TJ
- EF_{FO} = Effective CO₂ Emission Factor of Furnace Oil (kgCO2e/TJ)

 $SE_1 = E_{GB} / EG_{BA}$

 E_{GB} =Emissions from Electricity Generation in Baseline Activity (tCO₂e) in the year 2005 and 2006. EG_{BA} = Electricity generated by DG sets in the baseline scenario (kWh) in the year 2005 and 2006.

Emission for Steam Generation

 $E_{SB} = Q_{FOB2} \times D_{FOB} \times NCV_{FOB} \times (4.186/10^{9}) \times EF_{FO}/1000$

ESB=Emissions from Steam Generation in Baseline Activity (tCO2e) in the year 2005 and 2006QFOB2=Quantity of Furnace Oil consumed in Boilers (liters) in the year 2005 and 2006

 $\begin{array}{ll} D_{FOB} & = Density \ of \ FO \ (kg/liters) \\ NCV_{FOB} & = Net \ calorific \ value \ of \ Furnace \ Oil \ (kcal/kg) \\ 4.186/10^{A9} = Conversion \ from \ kcal \ to \ TJ \\ EF_{FO} & = Effective \ CO_2 \ Emission \ Factor \ of \ Furnace \ Oil \ (kgCO2e/TJ) \end{array}$

 $SE_2 = E_{SB} / ST_{total}$

 SE_2 = Specific emission for steam generation in baseline activity (tCO₂e/Kg)

E_{SB}=Emissions from Steam Generation in Baseline (tCO₂e) in the year 2005 and 2006.

 ST_{total} = Total steam generated in baseline (Kg) in the year 2005 and 2006.

 $ST_{total} = ST_{B1} + ST_{B2}$

ST_{B1}=Quantity of Steam Generated from 3 Boilers in baseline (Kg) in the year 2005 and 2006.

 ST_{B2} = Quantity of steam generated from 3 Exhaust Gas Boilers in (Kg) baseline in the year 2005 and 2006.

Emission for Chilled water generation

The baseline scenario involves 2 centrifugal chillers having cooling capacity of 500 TR each and 1 centrifugal chiller having cooling capacity of 390 TR. The electricity consumption figure for the year 2005 and 2006 has been considered for the baseline reference figure.

Actual refrigeration generated was monitored. However as a conservative approach we have considered total cooling capacity of the centrifugal chiller as the cooling capacity factor in the specific power consumption calculation of power driven centrifugal chillers.

 $E_{CB} = SE_3 \times R_P \times OH_P \times SE_P$

 E_{CB} =Emissions from Centrifugal Chiller in Baseline activity for chilled water generation (tCO_{2e}) per annum.

 SE_3 = Specific Power Consumption of centrifugal chiller (kW/TR)

R_P =VAC Cooling Capacity (TR)

 OH_P = Operating hours of VAC (hours)

 SE_P = Specific Emission Factor for electricity generation in Project Scenario (tCO₂e/kWh)

SE3=EC_{chillers} / R_B

 $EC_{chillers}$ = Power consumption by 3 centrifugal chillers in baseline activity in 2005 and 2006 R_B =Total Cooling Generated in the year 2005 & 2006(TR)

 $R_{\rm B} = R_1 \times OH_1 + R_2 \times OH_2 + R_3 \times OH_3$

 R_B =Total Cooling Generated in the year 2005 & 2006 (TR).

R₁ =Rated Capacity of McQuay – PH1 Centrifugal Chillers (TR).

OH₁ = Operating Hours of McQuay - PH1 Centrifugal Chillers for the year 2005 & 2006.

R₂ = Rated Capacity of McQuay – PH2 Centrifugal Chillers (TR).

 OH_2 = Operating Hours of McQuay - PH2 Centrifugal Chillers for the yer 2005 & 2006.

R₃ = Rated Capacity of Voltas Centrifugal Chillers (TR).

 OH_3 = Operating Hours of Voltas Centrifugal Chillers (TR) for the year 2005 & 2006.

Project Emissions Emission for Electricity Generation

 $E_{GP}=(Q_{NGP1}+Q_{NGP2}) \times NCV_{NG} \times (4.186/10^{9}) \times EF_{NG}/1000$

EGP =Emissions from Electricity Generation in Project Activity (tCO2e) per annum. =Quantity of Natural Gas consumed in Gas Turbine (sm³) per annum. Q_{NGP1} =Quantity of Natural Gas consumed in Gas Engine (sm³) per annum. Q_{NGP2} NCV_{NGP} =Net calorific value of Natural Gas (kcal/sm³) 4.186/10^9 =Conversion from kcal to TJ =Effective CO₂ Emission Factor of Natural Gas (kgCO₂/TJ) EF_{NG}

 $SE_P = E_{GP} / EG_{PA}$

SE_P =Specific Emission Factor for electricity generation in Project Scenario (tCO₂e/kWh)

 E_{GP} =Emissions from Electricity Generation in Project Activity (tCO₂e) per annum.

 EG_{PA} = Electricity generated in the project activity (kWh) per annum

Emission for Steam Generation

 $E_{SP} = (Q_{NGP3} + Q_{NGP4} + Q_{NG5}) \times NCV_{NG} \times (4.186/10^{9}) \times EF_{NG}/1000$

Esp =Emissions from Steam Generation in Project Activity (tCO₂e) per annum.

=Quantity of natural gas consumed in HRSG Boiler (sm³) per annum. Q_{NGP3}

Q_{NGP4}

=Quantity of natural gas consumed in 2nd Boiler (sm³) per annum. =Quantity of natural gas consumed in 3rd Boiler (sm³) per annum. Q_{NGP5}

 NCV_{NG} =Net calorific value of Natural gas (kcal/sm³)

4.186/10^9 =Conversion from kcal to TJ

=Effective CO₂ Emission Factor of Natural Gas (kgCO2/TJ) EF_{NG}

Emission for Chilled water generation

The project activity involves installation of a 1260 TR VAC operating on exhaust gas of the Gas Engines. This replaces use of centrifugal chillers of similar capacity.

 $E_{CP} = EG_C \times SE_P + E_{VACNG}$

E_{CP} =Emissions from Vapour Absorption Chiller in Project activity for chilled water generation(tCO₂e) per annum.

 EG_{C} = Electricity consumed by the VAC (kWh) per annum.

SE_P =Specific Emission Factor for electricity generation in Project Scenario (tCO₂e/kWh)

E_{VACNG} =Emissions from NG firing in VAC in Project Activity (tCO₂e) per annum.

 $EG_{C} = VAC_{AUX} \times OH_{P}$

 EG_{C} =Total electricity consumed by the VAC per annum.

VAC_{AUX} =Rated capacity of auxiliaries (kW)

 OH_P = Number of operating hours of VAC (hours) in a year.

NG will be fired into the VAC only when exhaust gas from Gas engine generator will not be available.

$E_{VACNG} = (Q_{NGP6}) \times (4.186/10^{9}) \times EF_{NG}/1000$

 E_{VACNG} =Emissions from VAC in Project Activity due to natural gas use (tCO₂e) per annum. Q_{NGP6} =Quantity of natural gas consumed in VAC (sm³) per annum. EF_{NG} =Effective CO₂ Emission Factor of Natural Gas (kgCO2/TJ)

Project Emissions (PE) = $E_{GP} + E_{SP} + E_{CP}$

Leakage

As per the methodology AMS II D If the energy efficiency technology is equipment transferred from another activity or if the existing equipment is transferred to another activity, leakage is to be considered. In the project activity case equipments has not be transferred to another activity. Hence the leakage is not to be considered in this scenario.

Emissions Reductions = Baseline Emissions (BE) - Project Emissions (PE) - Leakage (L)

B.6.2. Data and parameters that are available at validation:

(Copy this table for each data and parameter)

Data / Parameter:	EG _{BA}
Data unit:	kWh
Description:	Electricity generated during the baseline activity from the 4 DG sets in the year 2005 and 2006.
Source of data used:	Management Information system (MIS)
Value applied:	163240636
Justification of the	It is calculated as the summation of the electricity generated by the DG sets
choice of data or	which is calculated from measurement done on continuous basis and recorded
description of	on daily basis. It is entered into the computer on daily basis.
measurement methods	
and procedures	
actually applied :	
Any comment:	The data in the value applied row is the total of the historic plant data during
	the years of 2005 and 2006.

Data / Parameter:	Q _{FOB1}
Data unit:	liters
Description:	Quantity of Furnace oil consumed in 4 DG Sets in the baseline for electricity in
	the year 2005 and 2006.
Source of data used:	Power plant daily MIS log sheet
Value applied:	38154876 (19187083 for the year 2005 + 18967793 for the year 2006).
Justification of the	Tank Dip difference method is used for monitoring on daily basis. Difference
choice of data or	of oil level in tank is considered as basis for that. This is measured at 6am and
description of	the data is entered into power plant MIS soft copy. The operator takes the level
measurement methods	of FO in the tank and deducts the previous reading. If any fresh receipt of

and procedures actually applied :	furnace oil, it is added into the FO stock. This level difference is converted to respective litres quantity in the tank as per the calibration chart. Total four
	number of tanks are there.
Any comment:	Calculated on daily basis. The data in the value applied row is the total figure
	of the accumulated daily data of the years 2005 and 2006

Data / Parameter:	Q _{FOB2}
Data unit:	liters
Description:	Quantity of Furnace oil consumed in 3 Boilers in the baseline in the year 2005
	and 2006.
Source of data used:	Boiler house steam log sheet,
Value applied:	8409862 (4017873 for the year 2005 + 4391989 for the year 2006).
Justification of the	Tank Dip difference method is used for monitoring on daily basis. Difference
choice of data or	of oil level in tank is considered as basis for that. This is measured at 6am and
description of	the data is entered into power plant MIS soft copy. The operator takes the level
measurement methods	of FO in the tank and deducts the previous reading. If any fresh receipt of
and procedures	furnace oil, it is added into the FO stock. This level difference is converted to
actually applied :	respective litres quantity in the tank as per the calibration chart. This is done on
	the main tank.
Any comment:	Calculated on daily basis. The data in the value applied row is the total figure
	of the accumulated daily data of the years 2005 and 2006.

Data / Parameter:	ST _{B1}
Data unit:	kg
Description:	Steam generated from 3 Boilers during the baseline activity in 2005 and 2006.
Source of data used:	Boiler house steam log sheet,
Value applied:	119177667
Justification of the	Is the quantity of steam produced in the boilers in kg (corresponds to the
choice of data or	quantity of boiler feed water plus condensate minus boiler blowdown minus
description of	steam from EGB). As a conservative emission reduction calculation measure
measurement methods	boiler blowdown is excluded from the calculation.
and procedures	
actually applied :	
Any comment:	The data in the value applied row is the total of the accumulated daily data for
	the years 2005 and 2006

Data / Parameter:	ST _{B2}
Data unit:	kg
Description:	Steam generated from the exhaust gas boilers during the baseline activity in
	2005 and 2006
Source of data used:	Boiler house steam log sheet,
Value applied:	78725411
Justification of the	This is measured by the Steam flow meter of the exhaust gas boilers. This is
choice of data or	measured on hourly basis in a daily EGB log sheet and same data feed into the
description of	computer by the shift engineer.
measurement methods	
and procedures	

actually applied :	
Any comment:	Is measured using the flow meter. the data in the value applied row is the total
	of the accumulated daily data for the years 2005 and 2006

Data / Parameter:	D _{FOB}
Data unit:	Kg/liters
Description:	Density of Furnace Oil
Source of data used:	FO invoice
Value applied:	0.97 or the year 2005 and 0.9696 for 2006
Justification of the	This is given by the suppliers in their invoices.
choice of data or	
description of	
measurement methods	
and procedures	
actually applied :	
Any comment:	

Data / Parameter:	NCV _{FOB}
Data unit:	kcal/kg
Description:	Net Calorific Value of Furnace Oil
Source of data used:	FO invoice/ IS:1448-1960
Value applied:	9842.5 for the year 2005 and 9847.14 for the year 2006
Justification of the	This is calculated by using IS:1448-1960. Density of FO given in the FO
choice of data or	supplier invoice is matched with the calorific value chart of the IS 1448-1960
description of	chart.
measurement methods	
and procedures	
actually applied :	
Any comment:	

Data / Parameter:	EC _{Chillers}
Data unit:	kWh
Description:	Electricity consumed by 3 centrifugal chillers in baseline activity in 2005 &
	2006.
Source of data used:	SPG 1 and SPG 2 column from MIS .
Value applied:	8180570
Justification of the	Operators Calculated from readings of energy meters and all the reading is
choice of data or	entered into computer by the engineers. This is summation of two meters
description of	readings. The data is stored in WTT tab of the MIS (Power Plant).
measurement methods	
and procedures	
actually applied :	
Any comment:	The data in the value applied row is the accumulated daily data for the years
	2005 and 2006.
Data / Parameter:	OH ₁
Data unit:	Hours

Description:	Number of operational hours of McQuay-PH1 Chiller in the year 2005 and
	2006
Source of data used:	Chiller log book
Value applied:	6772
Justification of the	These data is recorded from the hours meter. The operating hours are calculated
choice of data or	from recorded initial reading at the start and the final reading at the end of each
description of	year.
measurement methods	
and procedures	
actually applied :	
Any comment:	The data in the value applied row is the figure of the accumulated daily data of
	the years 2005 and 2006

Data / Parameter:	OH ₂
Data unit:	Hours
Description:	Number of operational hours of McQuay-PH2 Chiller in the year 2005 and
	2006
Source of data used:	Chiller log book
Value applied:	9220
Justification of the	These data is recorded from the hours meter. The operating hours are calculated
choice of data or	from recorded initial reading at the start and the final reading at the end of each
description of	year.
measurement methods	
and procedures	
actually applied :	
Any comment:	The data in the value applied row is the figure of the accumulated daily data of
	the years 2005 and 2006

Data / Parameter:	OH ₃
Data unit:	Hours
Description:	Number of operational hours of Voltas Chiller in the year 2005 and 2006
Source of data used:	Chiller log book
Value applied:	6859
Justification of the	These data is recorded from the hours meter. The operating hours are calculated
choice of data or	from recorded initial reading at the start and the final reading at the end of each
description of	year.
measurement methods	
and procedures	
actually applied :	
Any comment:	The data in the value applied row is the figure of the accumulated daily data of
	the years 2005 and 2006

Data / Parameter:	\mathbf{R}_1
Data unit:	TR
Description:	Chiller Cooling capacity of McQUAY – PH1 Chiller
Source of data used:	Name plate/Technical specification
Value applied:	500

Justification of the	Actual refrigeration generated was monitored. However as a conservative
choice of data or	approach we have considered total cooling capacity of the McQUAY - PH1
description of	centrifugal chiller in calculating the total coolig generated (R _B) in the specific
measurement methods	power consumption calculation of power driven centrifugal chillers.
and procedures	
actually applied :	
Any comment:	

Data / Parameter:	R_2	
Data unit:	TR	
Description:	Chiller Cooling capacity of McQUAY – PH2 Chiller	
Source of data used:	Name plate/Technical specification	
Value applied:	500	
Justification of the	Actual refrigeration generated was monitored. However as a conservative	
choice of data or	approach we have considered total cooling capacity of the McQUAY – PH2	
description of	centrifugal chiller in calculating the total coolig generated (R _B) in the specific	
measurement methods	power consumption calculation of power driven centrifugal chillers.	
and procedures		
actually applied :		
Any comment:		

Data / Parameter:	R ₃	
Data unit:	TR	
Description:	Chiller Cooling capacity of Voltas Chillers	
Source of data used:	Name plate/Technical specification	
Value applied:	390	
Justification of the	Actual refrigeration generated was monitored. However as a conservative	
choice of data or	approach we have considered total cooling capacity of the Voltas centrifugal	
description of	centrifugal chiller in calculating the total coolig generated (R _B) in the specific	
measurement methods	power consumption calculation of power driven centrifugal chillers.	
and procedures		
actually applied :		
Any comment:		

Data / Parameter:	EF _{FO}		
Data unit:	Kg CO ₂ e/TJ		
Description:	Emission Factor of Furnace Oil		
Source of data used:	IPCC Default Value, Table 1.4, Chapter 1, Volume 2, 2006 IPCC Guidelines		
	for National Greenhouse Gas Inventories		
Value applied:	77400		
Justification of the	Table 1.4, Chapter 1, Volume 2, 2006 IPCC Guidelines for National		
choice of data or	Greenhouse Gas Inventories		
description of			
measurement methods			
and procedures			
actually applied :			
Any comment:	IPCC Default Value		

Data / Parameter:	EF _{NG}		
Data unit:	Kg CO ₂ e/TJ		
Description:	Emission Factor of Natural Gas		
Source of data used:	IPCC Default Value, Table 1.4, Chapter 1, Volume 2, 2006 IPCC Guidelines		
	for National Greenhouse Gas Inventories,		
Value applied:	56100		
Justification of the	Table 1.4, Chapter 1, Volume 2, 2006 IPCC Guidelines for National		
choice of data or	Greenhouse Gas Inventories		
description of			
measurement methods			
and procedures			
actually applied :			
Any comment:	IPCC Default Value		

Data / Parameter:	SE1		
Data unit:	tCO ₂ e/kWh		
Description:	Specific Emission Factor for Electricity Generation		
Source of data used:	calculated		
Value applied:	0.0007232		
Justification of the	$SE_1 = E_{GB} / EG_{BA}$		
choice of data or			
description of			
measurement methods			
and procedures			
actually applied :			
Any comment:	The value is based on the electricity generation and furnace oil consumption		
	data for the year 2005 & 2006. This value would be used through the crediting		
	period for calculating equivalent amount of baseline emissions for electricity		
	generated in project activity.		

Data / Parameter:	SE ₂	
Data unit:	tCO ₂ e/Kg	
Description:	Specific Emission Factor for Steam Generation	
Source of data used:	calculated	
Value applied:	0.0001314	
Justification of the	$SE_2 = E_{SB} / ST_{total}$	
choice of data or		
description of		
measurement methods		
and procedures		
actually applied :		
Any comment:	The value is based on the steam generation and Furnace oil consumption data	
	for the year 2005 & 2006. This value would be used through the crediting	
	period for calculating equivalent amount of baseline emissions for steam	
	generated in project activity.	

Data / Parameter:	SE ₃		
Data unit:	kW/TR		
Description:	Specific Power Consumption of centrifugal chiller		
Source of data used:	calculated		
Value applied:	0.77		
Justification of the	SE ₃ =EC _{chillers} / RB		
choice of data or			
description of	ECchillers = Power consumption by 3 centrifugal chillers in baseline activity		
measurement methods	in 2005 and 2006(kWh)		
and procedures	RB =Total Cooling Generated in the year 2005 & 2006(TR)		
actually applied :	$RB = R1 \times OH1 + R2 \times OH2 + R3 \times OH3$		
	RB =Total Cooling Generated in the year 2005 & 2006 (TR)		
R1 =Rated Capacity of McQuay – PH1 Centrifugal Chillers (TR)			
	OH1 = Operating Hours of McQuay - PH1 Centrifugal Chillers for the year		
	2005 & 2006		
	R2 = Rated Capacity of McQuay – PH2 Centrifugal Chillers (TR)		
	OH2 = Operating Hours of McQuay - PH2 Centrifugal Chillers for the year		
	2005 & 2006		
	R3 = Rated Capacity of Voltas Centrifugal Chillers (TR)		
	OH3 = Operating Hours of Voltas Centrifugal Chillers (TR) for the year 2005		
	& 2006		
A	The makes is based on data for the man 2005 & 2006 This will be all the set		
Any comment:	The value is based on data for the year 2005 & 2006. This value would be used		
	through the crediting period for calculating equivalent amount of baseline		
	emissions for chilled water generated in project activity.		

Data / Parameter:	VAC _{AUX}
Data unit:	kW
Description:	Rated capacity of auxiliaries (kW)
Source of data used:	Supplier data
Value applied:	191.2
Justification of the	It is calculated as the summation of the electricity auxiliaries of the VAC.
choice of data or	
description of	
measurement methods	
and procedures	
actually applied :	
Any comment:	

B.6.3 Ex-ante calculation of emission reductions: Baseline Emissions

 $BE=SE_1 \times EG_{PA} + SE2 \times ST_P + E_{CB}$

- BE = Total Baseline emissions (tCO_2e) per annum.
- SE_1 = Specific Emission Factor for Electricity Generation in baseline (tCO₂e/kWh)
- EG_{PA} = Electricity generated in Project activity(kWh) per annum.
- SE₂ = Specific Emission Factor for Steam Generation in baseline(tCO₂e/Kg)
- ST_P = Steam Generated during the Project Activity (steam from HRSG and boilers) (Kg) per annum.
- E_{CB} = Baseline Emissions from Centrifugal Chiller in Baseline activity for chilled water generation (tCO₂e) per annum.

 $SE_1 = E_{GB} / EG_{BA}$

 E_{GB} = Emissions from Electricity Generation in Baseline Activity (tCO₂e) in the year 2005 and 2006 EG_{BA} = Electricity generated by DG sets in the baseline scenario (kWh) in the year 2005 and 2006

 $SE_2 = E_{SB} / ST_{total}$

 SE_2 = Specific emission for steam generation in baseline activity (tCO₂e/Kg)

- E_{SB} =Emissions from Steam Generation in Baseline (tCO₂e) in the year 2005 and 2006.
- ST_{total} = Total steam generated in baseline (Kg) in the year 2005 and 2006.

 $ST_{total} = ST_{B1} + ST_{B2}$

- ST_{B1}=Quantity of Steam Generated from 3 Boilers in baseline (Kg) in the year 2005 and 2006.
- ST_{B2} = Quantity of steam generated from 3 Exhaust Gas Boilers in (Kg) baseline in the year 2005 and 2006.

Emission for Electricity Generation

 $E_{GB}=Q_{FOB1}\times D_{FOB}\times NCV_{FOB}\times (4.186/10^{\circ}9)\times EF_{FO}/1000$

E _{GB}	Emissions from Electricity Generation in Baseline Activity (tCO2e) in the year 2005 and
	2006.

Q_{FOB1} =Quantity of Furnace Oil consumed in DG Sets (liters) in the year 2005 and 2006.

D_{FOB} =Density of FO (kg/liters).

NCV_{FOB} =Net calorific value of Furnace Oil (kcal/kg).

4.186/10^9 =Conversion from kcal to TJ.

 EF_{FO} = Effective CO₂ Emission Factor of Furnace Oil (kgCO₂e/TJ).

$$\begin{split} E_{GB} &= 19187083 \times 0.97 \times 9842.50 \times (4.186/10^{\circ}) \times 77400/1000 + 18967793 \times 0.9696 \times 9847.14 \times (4.186/10^{\circ}) \times 77400/1000 = 118055.069(tCO_2e) \end{split}$$

19177083 = Fuel consumption for the year 2005 (liters)

0.97 = The data for density for the year 2005 (kg/liters)

9842.50 = The data for Net Calorific value for the year 2005 (kcal/kg)

18967793= Fuel consumption for the year 2006 (liters)

0.9696 = The data for density for the year 2006 (kg/liters)

9847.14 = The data for Net Calorific value for the year 2006 (kcal/kg)

= Effective CO₂ Emission Factor of Furnace Oil (kgCO2e/TJ)

 $SE_1 = E_{GB} / EG_{BA}$

E_{GB}=Emissions from Electricity Generation in Baseline Activity (tCO₂e) in the year 2005 and 2006.

 EG_{BA} = Electricity generated by DG sets in the baseline scenario (kWh) in the year 2005 and 2006

 $SE_1 = 118055.069 / 163240636 = 0.0007232 (tCO_2e/kWh)$

 $118055.069 = E_{GB}$ (tCO₂e) $163240636 = EG_{BA}$ (kWh)

Emission for Steam Generation

 $E_{SB} = Q_{FOB2} \times D_{FOB} \times NCV_{FOB} \times (4.186/10^{9}) \times EF_{FO}/1000$

- E_{SB} =Emissions from Steam Generation in Baseline Activity (tCO₂e) in the year 2005 and 2006.
- Q_{FOB2} =Quantity of Furnace Oil consumed in Boilers (liters) in the year 2005 and 2006
- D_{FOB} =Density of FO (kg/liters)
- NCV_{FOB} =Net calorific value of Furnace Oil (kcal/kg)
- 4.186/10^9 =Conversion from kcal to TJ
- EF_{FO} = Effective CO₂ Emission Factor of Furnace Oil (kgCO2e/TJ)

 $SE_2 = E_{SB} / ST_{total}$

SE₂= Specific emission for steam generation in baseline activity (tCO₂e/Kg)

- E_{SB} =Emissions from Steam Generation in Baseline (tCO₂e) in the year 2005 and 2006
- ST_{total} = Total steam generated in baseline (Kg) in the year 2005 and 2006
- $ST_{total} = ST_{B1} + ST_{B2}$
- ST_{B1} =Quantity of Steam Generated from 3 Boilers in baseline(Kg) in the year 2005 and 2006
- ST_{B2} = Quantity of steam generated from 3 Exhaust Gas Boilers in baseline(Kg) in the year 2005 and 2006

 $(E_{SB}) = 4017873 \times 0.97 \times 9842.50 \times (4.186/10^{\circ}) \times 77400/1000 + 4391989 \times 0.9696 \times 9847.14 \times (4.186/10^{\circ}) \times 77400/1000 = 26020.714(tCO_2e)$

4017873 = Fuel consumption for the year 2005(liters)

- 0.97 =The data for density for the year 2005 (kg/liters)
- 9842.50 = The data for Net Calorific value for the year 2005 (Kcal/kg)
- 4391989 = Fuel consumption for the year 2006 (liters)
- 0.9696 = The data for density for the year 2006 (kg/liters)
- 9847.14 = The data for Net Calorific value for the year 2006 (Kcal/kg)

 $SE_2 = E_{SB} / ST_{total}$

 E_{SB} =Emissions from Steam Generation in Baseline (tCO₂e) in the year 2005 and 2006. ST_{total} = Total steam generated in baseline (Kg) in the year 2005 and 2006. ST_{total} = ST_{B1} + ST_{B2}

 $ST_{B1}\mbox{=}Quantity of Steam Generated from 3 Boilers in baseline in 2005 and 2006$

 ST_{B2} = Quantity of steam generated from 3 Exhaust Gas Boilers in baseline in 2005 and 2006 $ST_{total} = 119177667 + 78725411 = 197903078$

$$\begin{split} SE_2 &= 26020.714 \ / \ 197903078 = 0.000131483 \\ 26020.714 \ &= E_{SB} \\ 197903078 &= \ ST_{total} \ (\ kg) \end{split}$$

Emission for Chilled water generation

The baseline scenario involves 2 centrifugal chillers having cooling capacity of 500 TR each and 1 centrifugal chiller having cooling capacity of 390 TR. The electricity consumption figure for the year 2005 and 2006 has been considered for the baseline reference figure.

Actual refrigeration generated was monitored. However as a conservative approach we have considered total cooling capacity of the centrifugal chiller as the cooling capacity factor in the specific power consumption calculation of power driven centrifugal chillers.

 $E_{CB} = SE_3 \times R_P \times OH_P \times SE_P$

 E_{CB} =Emissions from Centrifugal Chiller in Baseline activity for chilled water generation for the year 2005 and 2006.

 SE_3 = Specific Power Consumption of centrifugal chiller (kW/TR)

 R_P =VAC Cooling Capacity (TR)

 OH_P = Operating hours of VAC (hours) per year.

 SE_P = Specific Emission Factor for electricity generation in Project Scenario (tCO₂e/kWh)

 $E_{CB} = 0.77 \times 1260 \times 8400 \times 0.00055779 = 4526$

SE3=EC_{chillers} / R_B

 $EC_{chillers}$ = Power consumption by 3 centrifugal chillers in baseline activity in 2005 and 2006(kWh) R_B =Total Cooling Generated in the year 2005 & 2006(TR) $R_B = R_1 \times OH_1 + R_2 \times OH_2 + R_3 \times OH_3$

R_B =Total Cooling Generated in the year 2005 & 2006 (TR)

R₁ =Rated Capacity of McQuay – PH1 Centrifugal Chillers (TR) OH₁ = Operating Hours of McQuay - PH1 Centrifugal Chillers for the year 2005 & 2006

R₂ = Rated Capacity of McQuay – PH2 Centrifugal Chillers (TR) OH₂ = Operating Hours of McQuay - PH2 Centrifugal Chillers for the yer 2005 & 2006

R₃ = Rated Capacity of Voltas Centrifugal Chillers (TR)
 OH₃ = Operating Hours of Voltas Centrifugal Chillers (TR) for the year 2005 & 2006

SE₃= 8180570 / 10670620=0.77

 R_B = 500 x 6772 + 500 x 9220 + 390 x 6859=10670620

 $BE=SE_1 \times EG_{PA} + SE2 \times ST_P + E_{CB}$

- BE = Total Baseline emissions (tCO_2e) per annum.
- SE_1 = Specific Emission Factor for Electricity Generation in baseline (tCO₂e/kWh) =0.00072
- EG_{PA} = Electricity generated in Project activity(kWh) per annum.= 84791364
- SE_2 = Specific Emission Factor for Steam Generation in baseline(tCO₂e/Kg) =0.0001314
- ST_P = Steam Generated during the Project Activity (steam from HRSG and boilers) (Kg) per annum.= 143746086
- E_{CB} = Baseline Emissions from Centrifugal Chiller in Baseline activity for chilled water generation (tCO₂e) per annum = 4526

 $BE = 0.00072 \times 84791364 + 0.0001314 \times 143746086 + 4526 = 84747 tCO_2e$

Year	BEy $(tCO_2 e)$
June 2008 – May 2009	84747
June 2009 – May 2010	84747
June 2010 – May 2011	84747
June 2011 – May 2012	84747
June 2012 – May 2013	84747
June 2013 – May 2014	84747
June 2014 – May 2015	84747
June 2015 – May 2016	84747
June 2016 – May 2017	84747
June 2017 – May 2018	84747

Project Emission

Emission for Electricity Generation

 E_{GP} = (Q_{NGP1} + Q_{NGP2}) × NCV_{NG} × (4.186/10^9) × EF_{NG}/1000

E_{GP} =Emissions from Electricity Generation in Project Activity (tCO₂e) per annum.

 Q_{NGP1} =Quantity of Natural Gas consumed in Gas Turbine (sm³) per annum.

 Q_{NGP2} =Quantity of Natural Gas consumed in Gas Engine (sm³) per annum.

NCV_{NGP} =Net calorific value of Natural Gas (kcal/sm³)

4.186/10^9 =Conversion from kcal to TJ

EF_{NG} =Effective CO₂ Emission Factor of Natural Gas (kgCO2/TJ)

 $E_{GP} = 24119939 \times 8350 \times (4.186/10^{9}) \times 56100/1000 = 47296 \text{ tCO}_2\text{e}$

24119939=(15279921+8840018)= Quantity of NG consumed in Gas Turbine and Gas Engine.

8350 = Net calorific value of Natural Gas (kcal/sm³)

56100 = Effective CO_2 Emission Factor of Natural Gas (kgCO2/TJ)

 $SE_P = E_{GP} / EG_{PA}$

SE_P =Specific Emission Factor for electricity generation in Project Scenario (tCO₂e/kWh)

 E_{GP} =Emissions from Electricity Generation in Project Activity (tCO₂e) per annum.

 EG_{PA} = Electricity generated in the project activity (kWh) per annum.

 $\begin{array}{ll} SE_{P} \left(tCO_{2}e/kWh \right) = 47296 \ / \ 84791364 = 0.00055779 \\ 47296 & = E_{GP} \\ 84791364 = EG_{PA} \end{array}$

Emission for Steam Generation

 $E_{SP} = (Q_{NGP3} + Q_{NGP4} + Q_{NG5}) \times NCV_{NG} \times (4.186/10^{9}) \times EF_{NG}/1000$

 $\begin{array}{ll} E_{SP} & = Emissions from Steam Generation in Project Activity (tCO_2e) per annum. \\ Q_{NGP3} & = Quantity of natural gas consumed in HRSG Boiler (sm³) per annum. \\ Q_{NGP4} & = Quantity of natural gas consumed in 2nd Boiler (sm³) per annum. \\ Q_{NGP5} & = Quantity of natural gas consumed in 3rd Boiler (sm³) per annum. \\ NCV_{NG} & = Net calorific value of Natural gas (kcal/sm³) \\ 4.186/10^{A9} = Conversion from kcal to TJ \\ EF_{NG} & = Effective CO_2 Emission Factor of Natural Gas (kgCO2/TJ) \end{array}$

 $E_{sp}(tCO_2e) = 726168 \times 8350 \times (4.186/10^{9}) \times 56100/1000 = 1424 tCO_2e$

 $\begin{array}{lll} 726168 &= (Q_{NGP3} + Q_{NGP4} + Q_{NG5}) \\ 8350 &= NCV_{NG} \\ 56100 &= EF_{NG} \end{array}$

Emission for Chilled water generation

The project activity involves installation of a 1260 TR VAC operating on exhaust gas of the Gas Engines. This replaces use of centrifugal chillers of similar capacity.

 $E_{CP} = EG_C \times SE_P + E_{VACNG}$

 E_{CP} =Emissions from Vapour Absorption Chiller in Project activity for chilled water generation(tCO₂e) per annum.

 EG_{C} = Electricity consumed by the VAC (kWh) per annum.

 $SE_P \quad = Specific \ Emission \ Factor \ for \ electricity \ generation \ in \ Project \ Scenario \ (tCO_2e/kWh)$

 E_{VACNG} = Emissions from VAC in Project Activity (tCO₂e) (tCO₂e) per annum.

 $EG_{C} = VAC_{AUX} \times OH_{P}$

 VAC_{AUX} =Rated capacity of auxiliaries (kW) OH_P = Number of operating hours of VAC (hours) in a year.

EG_c=191.2 X 8400 = 1606080 kWh 191.2=VAC_{AUX} 8400= OH_P

NG will be fired into the VAC only when exhaust gas from Gas engine generator will not be available.

 $E_{VACNG} = (Q_{NGP6}) \times (4.186/10^{9}) \times EF_{NG}/1000$

 $\begin{array}{l} E_{VACNG} = & Emissions \mbox{ from VAC in Project Activity due to natural gas use (tCO_2e)} \\ Q_{NGP6} = & Quantity \mbox{ of natural gas consumed in VAC (sm^3)} \\ EF_{NG} = & Effective \mbox{ CO}_2 \mbox{ Emission Factor of Natural Gas (kgCO2/TJ)} \end{array}$

 $(E_{CP}) = (1606080 \times 0.00055779) + (0) = 896 \text{ tCO}_2\text{e}$

1606080= EG_c=Total electricity consumed by the VAC (kWh) in a year. 0.00055779= SE_p=Specific Emission Factor for electricity generation in Project Scenario (Refer to Emission for Electricity Generation section)

 $0 = Q_{NGP6} = Quantity of natural gas consumed in VAC (sm³)$

Project Emissions (PE) = $E_{GP} + E_{SP} + E_{CP}$

PE = 47296+ 1424 + 896 = 49616 tCO2e

Year	PEy (tCO_2e)
June 2008 – May 2009	49616
June 2009 – May 2010	49616
June 2010 – May 2011	49616
June 2011 – May 2012	49616
June 2012 – May 2013	49616
June 2013 – May 2014	49616
June 2014 – May 2015	49616
June 2015 – May 2016	49616
June 2016 – May 2017	49616
June 2017 – May 2018	49616

Leakage

As per the methodology AMS II D If the energy efficiency technology is equipment transferred from another activity or if the existing equipment is transferred to another activity, leakage is to be considered. In the project activity case DG sets will not be transferred to another activity. Hence the leakage is not to be considered in this scenario.

B.6.4	Summary of the ex-ante estimation of emission reductions:
>>	

Emissions Reductions = Baseline Emissions (BE) – Project Emissions (PE) – Leakage (L)

Year	Estimation of Project activity emissions (tCO ₂ e)	Estimation of baseline emissions (tCO ₂ e)	Estimation of leakage (tCO ₂ e)	Estimation of overall emission reductions (tCO ₂ e)
	t CO2	t CO2		t CO2
June 2008 – May 2009	49616	84747	0	35131

ſ

June 2009 – May 2010	49616	84747	0	35131
June 2010 – May 2011	49616	84747	0	35131
June 2011 – May 2012	49616	84747	0	35131
June 2012 – May 2013	49616	84747	0	35131
June 2013 – May 2014	49616	84747	0	35131
June 2014 – May 2015	49616	84747	0	35131
June 2015 – May 2016	49616	84747	0	35131
June 2016 – May 2017	49616	84747	0	35131
June 2017 – May 2018	49616	84747	0	35131
Total (tonnes of CO2e)	496160	847470	0	351310

B.7 Application of a monitoring methodology and description of the monitoring plan:

As per the AMS II D for the project activity monitoring shall consist of:

(a) Documenting the specifications of the equipment replaced;

(b) Metering the energy use of the industrial or mining and mineral production facility, processes or the equipment affected by the project activity;

(c) Calculating the energy savings using the metered energy obtained from subparagraph (b).

B.7.1 Data and parameters monitored:		
Data / Parameter:	EG _{PA}	
Data unit:	kWh	
Description:	Electricity Generated during the project activity from the Gas turbine and gas engine per annum	
Source of data to be used:	Daily MIS (Management Information System) log sheet in the power plant	
Value of data	84791364	
Description of measurement methods and procedures to be applied:	The electricity generated is calculated as the sum of the electricity generated from the Gas Engine and Gas Turbine which is measured using the energy meter on continuous basis. This is recorded on daily basis. The GT energy meter E5 is located at GT HT panel. The Gas engine energy meter E6 is located at HT panel in the Gas DG set. E5+E6 (Final reading – initial reading). The above value is based on the actual data of May 07 and June 07 and extrapolated for 12 months.	
QA/QC procedures to be applied:	As per the ISO 9000/ISO14001 procedures	
Any comment:		

Data / Parameter:	Q _{NGP1}
Data unit:	SCM
Description:	Quantity of NG consumed in Gas Turbine per annum.
Source of data to be	Power plant daily MIS sheet

used:	
Value of data	15279921
Description of	The quantity of NG used is calculated from initial and final readings using the
measurement methods	Gas turbine flow meter G2 on daily basis (Final reading – initial reading). The
and procedures to be	measurement by G2 is on continuous basis.
applied:	The above value is based on the actual data of May 07 and June 07 and
	extrapolated for 12 months.
QA/QC procedures to	As per the ISO 9000/ ISO 14001 procedures
be applied:	
Any comment:	

Data / Parameter:	Q _{NGP2}
Data unit:	SCM
Description:	Quantity of NG consumed in Gas Engine per annum.
Source of data to be	Power plant daily MIS sheet
used:	
Value of data	8840018
Description of	The quantity of NG used is calculated from initial and final readings measured
measurement methods	using the Gas flow meter G3 on daily basis (Final reading – initial reading). The
and procedures to be	measurement by G3 is on continuous basis.
applied:	The above value is based on the actual data of May 07 and June 07 and
	extrapolated for 12 months.
QA/QC procedures to	As per the ISO 9000/ ISO 14001 procedures
be applied:	
Any comment:	

Data / Parameter:	Q _{NGP3}
Data unit:	SCM
Description:	Quantity of NG consumed in HRSG per annum.
Source of data to be	Distributed Control System (DSC) system on HRSG
used:	
Value of data	726168
Description of	The quantity of NG used is calculated from initial and final readings measured
measurement methods	using the gas flow meter G4 on daily basis (Final reading – initial reading). The
and procedures to be	measurement by G4 is on continuous basis.
applied:	The above value is based on the actual data of May 07 and June 07 and
	extrapolated for 12 months.
QA/QC procedures to	As per the ISO 9000/ ISO 14001 procedures
be applied:	
Any comment:	

Data / Parameter:	Q _{NGP4}
Data unit:	SCM
Description:	Quantity of NG consumed in the 2 nd boiler per annum.
Source of data to be	Power plant daily MIS sheet
used:	
Value of data	0

Description of measurement methods and procedures to be applied:	The quantity of NG used is calculated from initial and final readings will be measured using the Gas flow meter G7 on daily basis (Final reading – initial reading). The measurement by G7 will on continuous basis.
QA/QC procedures to be applied: Any comment:	As per the ISO 9000/ ISO 14001 procedures

Data / Parameter:	Q _{NGP5}
Data unit:	SCM
Description:	Quantity of NG consumed in the 3 rd boiler per annum.
Source of data to be	Power plant daily MIS sheet
used:	
Value of data	0
Description of	The quantity of NG used is calculated from initial and final readings will be
measurement methods	measured using the Gas flow meter G8 on daily basis (Final reading – initial
and procedures to be	reading). The measurement by G8 will on continuous basis.
applied:	
QA/QC procedures to	As per the ISO 9000/ ISO 14001 procedures
be applied:	
Any comment:	

Data / Parameter:	Q _{NGP6}
Data unit:	SCM
Description:	Quantity of NG consumed in VAC per annum.
Source of data to be	Power plant daily MIS sheet
used:	
Value of data	0
Description of	The quantity of NG used will be calculated from initial and final readings using
measurement methods	the VAC flow meter G5 on daily basis (Final reading – initial reading). The
and procedures to be	measurement by G5 will be on continuous basis.
applied:	
QA/QC procedures to	As per the ISO 9000/ ISO 14001 procedures
be applied:	
Any comment:	

Data / Parameter:	ST _P
Data unit:	kg
Description:	Amount of steam generated from HRSG, Boiler no 2 and 3 per annum.
Source of data to be	Power plant MIS
used:	
Value of data	143746086
Description of	The steam generated is calculated from readings measured using the meters W1,
measurement methods	W2, W3, W4, W5 and W6 on daily basis W1+W2+W3+W4+W5+W6. The
and procedures to be	steam for the boiler number 1 (W7) will be deducted from the above figure. Net
applied:	steam produced by HRSG, Boiler 2 and 3 will be W1+W2+W3+W4+W5+W6-

	W7 Measurements by water meters will be on continuous basis. The above value is based on the actual data of May 07 and June 07 and extrapolated for 12 months.
QA/QC procedures to	As per the ISO 9000/ ISO 14001 procedures
be applied:	
Any comment:	

Data / Parameter:	R _P
Data unit:	TR
Description:	Vapour Absorption Chiller Cooling Capacity
Source of data to be	Chiller Log Book
used:	
Value of data	1260
Description of	The cooling generated is measured in the display and operating panel of the
measurement methods	VAC and the reading is recorded every 2 hours. The operating hours of the VAC
and procedures to be	is recorded by the shift engineer. The daily cumulative readings of the cooling
applied:	generation noted down is divided 12, being number of readings in the day and is
	multiplied with the operating hours of the chiller to calculate the actual cooling
	generation.
QA/QC procedures to	As per the ISO 9000/ ISO 14001 procedures
be applied:	
Any comment:	

Data / Parameter:	OH _P
Data unit:	Hours
Description:	Number of operational hours of VAC in a year
Source of data to be	VAC log sheet
used:	
Value of data	8400
Description of	The operating hours of the chiller is recorded every hour by the shift operator
measurement methods	and is stored in the VAC log sheet.
and procedures to be	
applied:	
QA/QC procedures to	As per the ISO 9000/ ISO 14001 procedures
be applied:	
Any comment:	

Data / Parameter:	NCV _{NGP}
Data unit:	Kcal/SCM
Description:	Net Calorific Value of Natural Gas
Source of data to be	Invoice from suppliers
used:	
Value of data	8350
Description of	GSPL provides GCV of NG on daily basis. It is normally observed that NCV is
measurement methods	approx. 90% of GCV.
and procedures to be	
applied:	

QA/QC procedures to be applied:	As per the ISO 9000/ ISO 14001 procedures
Any comment:	

Data / Parameter:	SE _P
Data unit:	tCO ₂ e/kWh
Description:	Specific Emission Factor for electricity generation in Project Scenario
Source of data to be	Calculated
used:	
Value of data	0.00055779
Description of	Specific Emission Factor for electricity generation in Project Scenario (SE _P)
measurement methods	$(tCO_2e/kWh) = E_{GP} / EG_{PA}$
and procedures to be	
applied:	
QA/QC procedures to	
be applied:	
Any comment:	The value of SE _P will be used in calculation of baseline emissions for equivalent
	amount of chill water generated in project activity. This value would be
	calculated ex-post each year during crediting period.

Data / Parameter:	Energy_Saving
Data unit:	GWhth
Description:	Aggregate Fuel Input Saving per annum in the project activity.
Source of data to be	Calculated
used:	
Value of data	66.19
Description of measurement methods and procedures to be applied:	Calculated as Energy Saving = (energy consumption per annum in project scenario for steam generation (E_{Steam}) + energy consumption per annum in project scenario for electricity generation ($E_{Electricity}$)) – ((Specific energy consumption for steam generation in baseline (SE ₄) * amount of steam generated per annum in project scenario (EG _{PA})) + (specific energy consumption for electricity generation in baseline (SE ₅) * amount of electricity generated per annum in project scenario (ST _P)) + electricity consumption reduction due to VAC per annum (ECR _{VAC}) (GWhth) $E_{Steam} = ((Q_{NGP3} + Q_{NGP4} + Q_{NGP5}) * NCV_{NGP})/(860*10^{6})$ $E_{Electricity} = ((Q_{NGP1} + Q_{NGP2}) * NCV_{NGP})/(860*10^{6})$ $E_{CR_{VAC}} = 3 * ((SE_3 * OH_P * R_P) - (VAC_{AUX} - OH_P))$
QA/QC procedures to	The amount of energy savings will be calculated ex-post each year during the
be applied:	crediting period.
Any comment:	

B.7.2 Description of the monitoring plan:

Λ	n
4	υ

The site has ISO 9001:2000, ISO14001: 2004 and SA 8000:2001 Management systems in place. Accordingly, the monitoring plan proposed herein has become an integral part of the project Management Programmes and would be constituent of operational and management structure of the Management systems.

The project activity is operated and managed by the project proponent. The individual plant record data related to their respective project activity. In order to monitor and control the project performance, Welspun India Ltd. has placed a project management team. They are coordinated by Project Executor and Head (Power Plant and Utilities) who is responsible for checking the information consistency. Welspun India Ltd. has well diversified procedure for collection of data and analysis of data at different levels and for subsequent corrective actions as when required in line with these policies.

The project team has been entrusted with the responsibility of storing, recording the data related to the project activity. The project team is also responsible for calculation of actual emission reduction in the most transparent and relevant manner.

Inspection and record of daily check list of critical parameters of project activity is maintained. The maintenance staff access the condition of all the power plant equipment and measuring equipment and any action required is taken.

Installed meters are calibrated according to the calibration schedule programmed at the start of the operation and recalibrated annually.

All the monitoring data is stored /will be recorded and kept under safe custody of the Project Executor and Head (Power Plant and Utilities) for a period of crediting period (10 years fixed crediting period) + 2 years or the last issuance of CERs + 2 years whichever occurs later.

The Instrumentation and the control system for the project activity are designed with adequate instruments to control and monitoring the various operating parameters for safe and efficient operations. All the instruments are of reputed make and are calibrated at regular intervals.

The natural gas based power project abides and will abide by all regulatory and statutory requirements as prescribed under the state and central laws and regulations.

Also any change within the project boundary, such as change in equipments will be recorded and any change in the emission reduction due to such alteration will also be studied and recorded.

Details of the meters and daily CDM monitorijg sheet have been given in Annexure 4..

Operational and Management Structure

All relevant functions and tasks are sufficiently described in the manual and the standard operating procedures of the quality management system.



Designation Vice-President (Engineering & Power Plant)

G. M. - Power Plant

Sr. Manager – Power Plant

Shift Engineers And Operators (Operation and Maintenance) **Responsibilities** Registration Project Execution

Operation Verification of data Inspection of data whenever necessary to independently check the authenticity of data and take corrective actions wherever required. Storage of data Operation, Monitoring and Verification of Data Data Recording Storage of data Operation and Maintenance Storage of data Data Recording Data Collection Archiving of data Observation ,Monitoring

B.8 Date of completion of the application of the baseline and monitoring methodology and the name of the responsible person(s)/entity(ies)

Mr. Tarnjit Singh, Welspun India Ltd.

Date of completing the final draft of this baseline section (DD/MM/YYYY): 16/02/2008

SECTION C. Duration of the project activity / crediting period

C.1 Duration of the project activity:

C.1.1. Starting date of the project activity:

>> 27/11/2004

>>

C.1.2. Expected operational lifetime of the project activity:

15 years 0 Months

C.2	Choice of the crediting period and related information:

C.2	.1. Renewable c	Renewable crediting period	
NA			
	C.2.1.1.	Starting date of the first crediting period:	
>>			
NA			
	C.2.1.2.	Length of the first crediting period:	
>>			
NA			
C.2	C.2.2. Fixed crediting period:		
10 years			
	C.2.2.1.	Starting date:	
01/06/2008 or a date not earlier than the date of registration			
r			
	C.2.2.2.	Length:	

>>

10 years 0 months

SECTION D. Environmental impacts

>>

D.1. If required by the <u>host Party</u>, documentation on the analysis of the environmental impacts of the project activity:

>>

As stated in the environmental impact assessment (EIA) notification vide S.O. $60(E)^2$ dated 27/01/1994, India's Environmental Protection Act of 1986 project such as this with the investment of less than Rs.

² http://www.envfor.nic.in/legis/eia/so-60(e).html

Formatiert

500 million does not have to produce an EIA. The investment in this project is less than 500 million i.e. it involves investment of 332 millions only. Thus EIA is not required to be conducted. However a rapid environmental impact assessment was conducted by third party for Welspun India Limited, as a voluntary initiative to understand the impacts and mitigate any additional impacts that may arise due to the proposed project activity.

The environmental Impact Assessment study showed that overall environmental impacts are not significant. A summary of impacts is presented below:

Land use

The project activity is located at the power plant. Therefore it will not change any land use.

<u>Water quality</u> It will not have any impact on water quality.

<u>Air quality</u> The air quality will be cleaner in comparison to the furnace oil situations.

Liquid Effluent generation

The waste water characteristics will improve due to project activity as the oil and grease concentration will be reduced.

Solid Waste Generation

Tank bottom sludge is not expected to be there in the case of Natural gas, in comparison to FO. Accordingly, the solid waste generation is expected to reduce in the case of Natural Gas.

Surface and Ground Water.

It will not have any impact on surface and groundwater sources;

Flora and Fauna

No impacts of ecology - flora and fauna, is expected.

Employment

There will be marginal decrease in employment, as the handling of FO required labour and this is not required in the case of natural Gas. However the gas supplier has engaged number of people for the gas pipeline connection.

D.2. If environmental impacts are considered significant by the project participants or the <u>host</u> <u>Party</u>, please provide conclusions and all references to support documentation of an environmental impact assessment undertaken in accordance with the procedures as required by the <u>host Party</u>:

>>

Only positive impacts are expected, such as better local air quality and GHG emission reductions into the atmosphere. The environmental impacts are considered not significant by the project participants.

SECTION E. Stakeholders' comments

>>

E.1. Brief description how comments by local stakeholders have been invited and compiled:

A stakeholders consultation meeting was organized on 24th August 2006 at Welspun India Limited, Vapi. Welspun identified its employees, suppliers, distributors, local community and govt officials as the most important stakeholders for the project activity. Accordingly the stakeholders were duly informed 15 days before the meeting by means of invitation letters to suppliers, local community, government officials and by notice on company notice board to its employees of the consultation meeting. In addition public notices were also displayed and distributed at key public places for the local stakeholder consultation meeting.

Comments of stakeholders were recorded during the stakeholder meeting.

The stake holder meeting process is followed in the following sequence

- Election of the Chair of the meeting and approval of the proposed Agenda
- Presentation of the CDM-Kyoto Protocol and role of local stake holder
- Presentation of the Projects completed or undertaken at Welspun India Limited
- Discussion and Articulation of concerns
- Chair summarizing the local stake holder concerns
- Vote of Thanks followed by Tea

Mr. Idris A. Vohra (IAS) was elected as the chairman for the stakeholder meeting.

The language used for the presentation, sharing and responding to the questions was in Gujarati. The summary of the meeting was recorded - copy of which will be made available to Designated Operating Entity during validation process. The list of participants with their signature is kept for record and photographs of the event were also taken.

The participants i.e. representatives of regulating agencies, Pradhan and his colleagues (panchs) villagers, regular and contractor employees of Welspun India Limited, Vapi were welcomed by Mr. Darra Pardiwala (Secretary to Chairman). Then the agenda and purpose of meeting i.e. to receive, understand, record and address the concerns of stakeholders for CDM projects was presented and got approved.

Mr. Niroj Mohanty had presented the concept of Kyoto Protocol and Clean Development Mechanism (CDM). He had also stressed the role of stakeholders in the fuel switch project activity.

After his presentation Mr Darra Pardiwala had presented detailed about all the project activity (completed and undertaken) in the regional Gujarati language (Gujarati).

The participants were then requested to share their views or concerns.

At the end the chairman in his speech appreciated the CDM initiatives and applauded the effort towards cleaner energy. He commended Welspun for being the first company in south Gujarat who has taken up such kind of initiative. Overall there was unanimous agreement that the project activity was really a proactive initiative by the project party, which contributes, to the sustainable development.

E.2. Summary of the comments received:

>>

The specific concerns expressed by the participants are summarized below along with clarifications provided on such concerns:

Stakeholder concerns / question / comment	Answer / clarifications
What will be the amount of reduction in the pollution by this Natural Gas based power Plant initiative?	It was informed that emission reduction will be to the extent of 40% in comparison to the baseline scenario.
What are the advantages to Welspun with this project initiative	Welspun will get financial benefit through the sale of Carbon Credits
Why did Welspun not opt for wind power in place of natural gas based power plant	It was informed that considering the plant location wind power is not a feasible option
What are the socio-economic benefits of this project	Socio-economic benefits of this project will be cleaner environment and reduced traffic hazards because of road transportation of fossil fuels will be eliminated.
What are the other project initiative through which you will be able to reduce emission	It was informed that the other initiatives reduction in power consumption by installations of the VFDs and hot water recovery. Welspun is thinking of other initiatives through which it will be able to reduce electricity and fuel consumption.

E.3. Report on how due account was taken of any comments received:

>>

The stakeholders were provided clarifications on the issues raised as above to their satisfaction. None of the concerns expressed by the stakeholders required an action to be taken by the Welspun India Ltd during the project operation and at any other stage.

Annex 1

CONTACT INFORMATION ON PARTICIPANTS IN THE **<u>PROJECT ACTIVITY</u>**

Organization:	Welspun India Ltd.
Street/P.O.Box:	Survey No.76
Building:	Morai Village, Vapi
City:	Valsad Dist
State/Region:	Gujarat
Postfix/ZIP:	396191
Country:	INDIA
Telephone:	+91-260-2437437
FAX:	+91-260-2437088
E-Mail:	Tarnjit_singh@welspun.com
URL:	www.welspun.com
Represented by:	
Title:	V.P (Engineering & Power plant)
Salutation:	Mr
Last Name:	Singh
Middle Name:	
First Name:	Tarnjit
Department:	Engineering
Mobile:	+91-9825127347
Direct FAX:	+91-260-2437088
Direct tel:	+91-260-2437588
Personal E-Mail:	

Organization:	Cantor Fitzgerald Europe
Street/P.O.Box:	17 Crosswall
Building:	
City:	London
State/Region:	
Postfix/ZIP:	EC3N 2LB
Country:	United Kingdom
Telephone:	+44 207 894 7000
FAX:	+44207 894 7553
E-Mail:	msnelling@cantor.co.uk
URL:	www.cantor.co.uk
Represented by:	
Title:	Director Legal (Europe and Asia) and Company Secretary
Salutation:	Mr
Last Name:	Snelling
Middle Name:	
First Name:	Mark
Department:	Legal
Mobile:	
Direct FAX:	+44207 894 7553
Direct tel:	+44 207 94 7892
Personal E-Mail:	

Annex 2

INFORMATION REGARDING PUBLIC FUNDING

Public funding from Annex I and diversion of ODA is not involved in this project.



Annex 3

	Total Baseline Emissions from Steam Generation									
Year	Steam ger Boiler Kg)	i of (in EGB (in Kg)	Total Steam	FO cons of Boiler (in Ltr)	Density		(Kcal/Kg)	EF (k⊈CO2/TJ)	Emissions (tCO2)	
2005	54817	35881154	90698829	4017873		0.97	9842.50	77400	0.00 12434.1178	
2006	6435999	42844257	107204249	4391989	0.96961	4286	9847.14	77400	0.00 13586.59633	
		Total Steam Generation	on (Kg)	197903078				Total Emissions	26020.71414	
Spec	cific Em	issions Facto	r		0.0	001314	48 (tC	O2/Kg of ste	am)	
								C C	,	
			Baseline I	Emissions Fro	om Powe	r Genera	ition			
Year	, (POWER GEN (KWh)	FUEL CONS	Density	(Kơ/l)	NCV (K	(cal/kg)	EE	Emissions	
1 ctai				Density	(128/1)	110 / (11	ieui/RB)		((002)	
	2005	81862152	19187	083	0.97		9842.50	77400.00	59378.29486	
	2006	81378484	18967	793	0.97		9847.14	77400	58676.77419	
	Total I	Power Genration	163240	636		Total Er	nissions		118055.0691	

(tCO2/KWh)

			Baseline emis	ssion for	Chilled Water	Generation		
				Elect				
				ri-				
	Specific			city			Specific	
	Power			cons		Electricity	Emission	
	consum-		Total	u-		consumpti	Factor for	
	ption in		Installed	mpti	Electricity	on	Electricity	
	baseline		capacity of	on in	consumption	reduction	Generation	
	scenario	Quantity	auxillaries	VAC	in baseline	due to	in project	Baseline
Yea	(kW/TR	generated	in VAC	(KW	scenario	VAC	scenario(tCO	Emissions
r)	from VAC	(KW)	h)	(kWh)	(kWh)	2/GWH)	(tCO2)
				1606				
		10584000.0		080.		6508083.1		4526.02432
1	0.77	0	191.20	00	8114163.11	1	0.000557793	6

	METER	METER TAG NO. IN DRG	ACCURACY CLASS / % ACCURACY	CALIBRATION FREQUENCY	REMARK	
	GAS TURBINE ENERGY METER	E 5	1	YEARLY		
	GAS ENGINE ENERGY METER	E 6	0.5	YEARLY		
	VAC CHILLER ENERGY METER	E 8	1	YEARLY		
	4 BAR GAS FLOW METER	G 1	1%	YEARLY		
	TURBINE GAS FLOW METER	G 2	1%	YEARLY		
	GAS ENGINE GAS FLOW METER	G 3	1%	YEARLY		
	HRSG GAS FLOW METER	G 4	1%	YEARLY		
	EXHAUST CHILLER GAS FLOW METER	G 5	1%	YEARLY	ORDER PLACED, TO BE PROVIDED	
	BOILER NO-2 GAS FLOW METER	G 7	1%	YEARLY	ORDER PLACED, TO BE PROVIDED	
	BOILER NO-3 GAS FLOW METER	G 8	1%	YEARLY	ORDER PLACED, TO BE PROVIDED	
	HOT WATER FLOW METER			YEARLY		Gelöscht: -
I	CONDENSATE FLOW METER	W-2	2%	YEARLY	(Gelöscht: -
I	CONDENSATE FLOW METER	₩-3	2%	YEARLY	(Gelöscht: -
I	CONDENSATE FLOW METER		2%	YEARLY		Gelöscht: -
I	CONDENSATE FLOW METER	₩-5	2%	YEARLY		Gelöscht: -
	CONDENSATE FLOW METER		2%	YEARLY		Gelöscht: -
	WATER FLOW METER FOR BOILER NUMBER 1 BASED ON FURNACE OIL	W7	1%	YEARLY		

<u>Annex 4</u> MONITORING INFORMATION

_

A.

DATE											
				CDM DAII	LY MONITO	RING SHEE	Г				
	MONITORING POINT				DATE		METER READING				
	EQUIPMENT	TAG NO.	UNIT	LOCATION OF METER	CALIBRA TION DONE	CALIBRA TION DUE	INITIAL	FINAL	DIFFEREN CE	MULTIPL YING FACTOR	TOTAL
POWER	GAS TURBINE	E 5	KWH	POWER PLANT					0	14000	0
N	GAS ENGINE	E 6	KWH	GAS DG SHED					0	10000	0
	GAS INLET 4 BAR	G 1	SM ³	4 BAR PRS STATION					0	1	0
	GAS TURBINE	G 2	SM ³	GTG SHED					0	1	0
	GAS ENGINE	G 3	SM ³	GAS DG SHED					0	1	0
GAS CONSUMPTI	HRSG	G 4	SM ³	SCADA SYSTEM					0	1	0
ON	EXHAUST CHILLER	G 5	SM ³	POWER PLANT					0	1	0
	BOILER NO-2	G 7	SM ³	TO BE PROVIDED					0	1	0
	BOILER NO-3	G 8	SM ³	TO BE PROVIDED					0	1	0
	HOT WATER F/M- B/H	W 1	LTR	BOILER HOUSE					0	1	0
BOILER	CONDENSATE F/M - B/H	W 2	LTR	BOILER HOUSE					0	1	0
CONSUMPTI	CONDENSATE F/M - B/H	W 3	LTR	BOILER HOUSE					0	1	0
STEAM	CONDENSATE F/M - B/H	W 4	LTR	BOILER HOUSE					0	1	0
GENERATIO N	CONDENSATE F/M - B/H	W 5	LTR	BOILER HOUSE					0	1	0
	CONDENSATE F/M - PTR	W 6	LTR	NEAR PTR					0	1	0
	WATER FLOW METER BOILER NO. 1 - BOILER HOUSE	W 7	LTR	BOILER HOUSE							
STEAM GENERATIO N	TOTAL OF WATER AND CONDENSATE FLOW METER		KG								0
CHILLED WATER GENERATIO N FROM EXHAUST CHILLER	EXHAUST CHILLER		TR	POWER PLANT							
CHILLER POWER CONSUMPTI ON	EXHAUST CHILLER	E 8	кwн	GAS DG SHED					0	1	0

- ----

Appendix 1

The steam credit for Gas Turbine when the comparison is made with Furnace Oil is taken INR 0.73/Kg The assumption for the steam credit calculation is given below: Steam Cost

<u>Steam Cost</u>									
DESCRIPTION	UNIT	<u>FO BOILER</u>	BASIS						
Net steam required									
from fired boiler	Tons / hr	7.0							
Type of fuel		FO							
Net Calorific value of									
fuel	Kcal/kg	9842	Supplier Invoice						
Thermal efficiency	%	83	CII Report						
Enthalpy of steam at 7.5									
bar	Kcal/kg	660.2	From steam table						
Feed water temperature	deg C	65.0	Plant Data						
Fuel consumption/kg									
steam	kg/kg steam	0.07	Calculated						
Steam generation / kg									
fuel	Kg/liters/kg	13.72	Calculated						
Cost of fuel	Rs / kg	9930	Supplier Invoice						
Fuel cost	Rs/kg steam	0.72	Calculated						
Fuel consumption/day	kg/day	12241	Calculated						
Connected electrical									
load	kw	53							
Power consumption	Kwh	42	Plant Data						
Manpower:									
Operator @Rs 4500/-									
PM	No.	3	Plant Data						
Fireman @ 2500/- PM	No.	0	Plant Data						
Helper @ 2500/- PM	No.	3	Plant Data						
	Rs								
Power cost @ 2,40/kwh	Lacs/Month	0.030	Calculated						
	Rs								
Manpower cost	Lacs/Month	0.210	Calculated						
Steam consumption	Tons / month	5040	Plant Data						
-	Rs								
Steam cost / month	Lacs/Month	36.47	Calculated						
	Rs.								
Operating cost	Lacs/Month	36.71	Calculated						
Steam cost	Rs/kg	0.73	Calculated						

Appendix -2 MC WELSPUN INDIA LIMITED WELSPUN VV EXTRACTS FROM THE MINUTES OF THE MEETING OF THE BOARD OF DIRECTORS OF WELSPUN INDIA LIMITED HELD ON 30TH JULY, 2004. "**RESOLVED THAT** the Board do approve establishment of natural gas based power plant for which the Company will take the initiative accordingly and explore CDM revenue from the project for the purpose of obtaining necessary approval from appropriate authorities and also benefits that may be accrued to the Company, Mr. B. K. Goenka, Mr. R. R. Mandawewala, Mr. M. L. Mittal, Mr. Swapan Nath, Mr. D. K. Patil and Mr. Tarnjit Singh are severally authorized to do all such acts, deeds and things as may be necessary to give effect to the foregoing." CERTIFIED TRUE COPY FOR WELSPUN INDIA LIMITED $12 | 06| 20 \circ 7$ D. K. PATIL COMPANY SECRETARY Corporate Office: Trade World, '8' Wing, 9th Floor Kamala Mills Compound Senapati Bapat Marg Lower Parel, Mumbai - 400 013.INDIA Tel: +91-22-66136000 / 24908000 Fax: +91-22-24908020 E-mail: welspun@bom2.vsnl.net.in URL: www.welsput.com Registered Office: Survey No. 76, Village Moral, Vapi, Dist. Valsad, Gujarat - 396 191, INDIA. Tel: +91-260-2437437 Fax: +91-260-2437088 Email: wttvapi@v Works: Welspun City, Tal. Anjar, Dist. Kutch, Gujarat - 370 110, INDIA. Tel: +91-02836-279000 / 09 Fax: +91-02836-279010 2