

**REVIEW OF THE PROJECT ACTIVITY****“Integrated Energy Ltd. Grid Connected Electricity Generation Plant using Natural Gas”
(1870)**

At its forty-sixth meeting the Board could not register the project activity “Integrated Energy Ltd. Grid Connected Electricity Generation Plant using Natural Gas” (1870), submitted for registration by the DOE (TÜV-NORD), because the DOE and project participant failed to:

- (i) Comply with the requirements of the applicable methodology on the identification of baseline alternatives that provide similar level of output and services, as the baseline scenario of 350 MW is not comparable to the 205 MW project activity in terms of similar level of outputs and services i.e. equivalent generation capacity per year; and
- (ii) Substantiate the suitability of input values, as many key parameters relate to the USA and are not considered to be applicable in the context of Israel, in particular the coal price.
