

	Date	WHRSG#1 Steam Generation (tons)	FRC Steam Generation (tons)	Total Steam generation (tons)	TG#1					TG#3					TG#2					Total Steam Consumption (tons)	Dunp Steam	Effective WHR steam (tons)	% WHR of Total steam fed to TGs	WHRSG#2 Steam Generation (tons)
					Avg. Temp. Degree	Avg. Press. Kg/Cm2	Avg. MW	Steam Consumption/MW	TG #1 Total Steam Consumption (tons)	Avg. Temp. Degree	Avg. Press. Kg/C m2	Avg. MW	Steam Consumption/MW	TG #3 Total Steam Consumption (tons)	Avg. Temp. Degree	Avg. Press. Kg/C m2	Avg. MW	Steam Consumption/MW	Total Steam Consumption (tons)					
Jun-06	1-Jun-06	391	1523	2671	405	33	8.93	4.72	1013.00	400	34	6.74	4.68	757.00	402	33.5	6.17	5.57	825.00	2595.00	76.00	315.00	17.12	757
	2-Jun-06	363	1541	2783	405	33	9.17	4.75	1046.00	406	34	7.74	4.71	875.00	402	33	6.25	5.66	849.00	2770.00	13.00	450.00	22.60	779
	3-Jun-06	521	1508	2807	403	33	9.24	4.76	1056.00	407	34	7.92	4.69	891.00	405	33	6.29	5.63	851.00	2793.00	9.00	512.00	25.35	778
	4-Jun-06	515	1563	2852	406	33	9.20	4.79	1058.00	405	34	8.10	4.77	927.00	404	34	6.48	5.60	874.00	2856.00	6.00	509.00	24.57	784
	5-Jun-06	511	1475	2834	404	33.3	9.23	4.74	1049.00	405	33	7.88	4.75	895.00	402	34	6.69	5.51	885.00	2829.00	5.00	506.00	25.51	848
	6-Jun-06	538	1474	2637	405	34	8.93	4.75	1018.00	406	33	7.19	4.76	821.00	407	33	5.22	5.82	729.00	2568.00	69.00	269.00	15.43	825
	7-Jun-06	236	1539	2621	396	33	9.04	4.81	1044.00	400	34	7.37	4.83	854.00	395	33.5	5.01	5.88	706.00	2604.00	17.00	219.00	12.57	855
	8-Jun-06	180	1518	2595	395	34	9.15	4.76	1045.00	397	33	7.21	4.79	829.00	400	33	4.83	5.92	690.00	2504.00	31.00	149.00	8.96	892
	9-Jun-06	73	1485	2439	405	33	8.88	4.82	1028.00	405	33.5	6.89	4.85	802.00	402	34	5.43	6.53	538.00	2398.00	71.00	2.00	0.12	881
	10-Jun-06	29	1470	2376	400	33	9.05	4.79	1041.00	396	34	7.08	4.80	816.00	402	33.5	2.96	6.78	482.00	2399.00	37.00	0.00	0.00	872
	11-Jun-06	0	1467	2376	400	33	9.12	4.75	1039.00	397	34	7.11	4.83	823.00	396	33.5	3.23	6.60	511.00	2373.00	3.00	0.00	0.00	899
	12-Jun-06	0	1479	2281	400	33	8.04	5.09	983.00	397	33.5	6.91	4.81	798.00	402	33	3.30	6.31	500.00	2281.00	9.00	0.00	0.00	892
	13-Jun-06	0	1467	2347	398	32.5	8.93	4.76	1020.00	400	34	7.30	4.80	841.00	396	33	3.03	6.10	443.00	2304.00	43.00	0.00	0.00	890
	14-Jun-06	0	1464	2342	400	32	8.83	4.74	1005.00	398	32.5	7.40	4.74	842.00	405	33	3.25	6.04	471.00	2318.00	24.00	0.00	0.00	878
	15-Jun-06	0	1237	1913	380	32.5	6.86	4.79	788.00	398	33	5.42	4.65	605.00	400	34	2.98	5.90	422.00	1515.00	98.00	0.00	0.00	676
	16-Jun-06	0	723	1517	404	31.5	4.57	5.16	565.60	407	33.7	5.66	4.66	633.92	400	35	1.32	7.04	257.00	1455.60	51.40	0.00	0.00	894
	17-Jun-06	0	1557	2741	402	34	7.69	4.58	875.00	385	33	6.32	4.74	719.00	405	34	3.63	8.03	700.00	2384.00	30.00	0.00	0.00	752
	18-Jun-06	0	1504	2243	405	33.2	6.03	5.92	727.00	395	34.2	6.91	5.69	778.00	400	33.6	4.73	6.17	701.00	2206.00	37.00	0.00	0.00	739
	19-Jun-06	0	1488	2257	404	32.4	7.63	4.90	897.00	401	33.1	6.75	4.65	758.00	400	33.2	3.83	6.26	876.00	2231.00	26.00	0.00	0.00	771
	20-Jun-06	0	1431	2160	405	32.5	8.41	4.87	983.00	400	33	6.51	4.68	731.00	398	33	2.47	6.98	413.00	2127.00	35.00	0.00	0.00	729
	21-Jun-06	0	1434	2253	408	32.6	8.52	4.87	996.00	403	32.7	6.33	4.66	709.00	400	33.8	2.98	6.70	479.00	2184.00	39.00	0.00	0.00	789
	22-Jun-06	0	1476	2283	407	33	8.75	4.89	1028.00	405	33	6.84	4.69	771.00	400	33	2.94	6.59	463.00	2264.00	21.00	0.00	0.00	809
	23-Jun-06	0	1523	2340	408	32	8.84	4.90	1040.00	407	33	7.29	4.73	827.00	406	33	2.82	6.63	452.00	2319.00	24.00	0.00	0.00	812
	24-Jun-06	0	1510	2275	407	32.2	8.85	4.89	1060.00	403	33.1	6.94	4.70	782.00	400	33.3	2.99	6.03	433.00	2277.00	9.00	0.00	0.00	755
	25-Jun-06	0	1520	2363	408	32	8.95	5.29	1136.00	403	33	6.91	4.59	762.00	400	33	3.12	6.22	466.00	2364.00	4.00	0.00	0.00	818
	26-Jun-06	0	1545	2342	409	31	9.15	5.24	1150.00	400	32	6.67	4.61	747.00	405	33	3.09	6.01	445.00	2342.00	0.00	0.00	0.00	777
	27-Jun-06	0	1517	2345	407	30	8.77	5.36	1128.00	397	31	6.78	4.61	750.00	398	32	3.17	6.12	466.00	2344.00	2.00	0.00	0.00	790
	28-Jun-06	0	1480	2276	410	30	8.43	5.27	1065.00	383	31	7.13	4.58	786.00	400	31	2.83	6.21	422.00	2275.00	2.00	0.00	0.00	790
	29-Jun-06	0	1546	2355	409.3	35.12	8.91	5.63	1075.00	410.5	36.97	6.90	4.74	785.00	403	36.8	3.04	6.37	463.00	2364.00	5.00	0.00	0.00	809
	30-Jun-06	0	1590	2369	410	32	8.93	5.32	1140.00	392	33	6.60	4.51	710.00	401	34	3.26	5.90	452.00	2364.00	11.00	0.00	0.00	809
	TOTAL	3257	15021	71502			255.03	147.51408	30068.6			129.12	141.5542	13676			115.57	187.1752	16975	5019.6	297.00	2931	152.232	24237

For, Godawari Power & Ispat Limited,

Authorised Signatory