


# POWER GENERATION GODAWARI POWER & ISP LIMITED


DATE: 31.01.2006.....

TIME: 15:15 HRS.

GENERATOR DETAILS	MAKE	SR. NO.	CAPACITY	CT PROVIDED	PT PROVIDED	NOTE:- T.G.-3 GENERATION ADDED WITH EFFECT FROM 01.01.2006.				
TG-NO.1	C.A. PARSON	3682	10 MW	800/1 AMP	11 KV/ 110 V					
TG-NO.2	C.A. PARSON	3806	10 MW	800/1 AMP	11 KV/ 110 V					
TG-NO.3	HITACHI	MP12428	10 MW	800/1 AMP	11 KV/ 110 V					
1250 KVA DG SET (SID)	KERELA ELECT.	31005	1250KVA	2500/5 AMP	415V					
750 KVA DG SET-1	STAMFORD	4101508	750KVA	1200/5 AMP	415V					
750 KVA DG SET-2	STAMFORD	4081548	750KVA	1200/5 AMP	415V					
<b>X'MER DETAILS</b>										
AUX. TRANSFORMER-1	VOLTAMP	JN6021/1	2900kVA	150/1 AMP	11 KV/ 110 V					
AUX. TRANSFORMER-2	EMCO	1923	2500kVA	400/1 AMP	11 KV/ 110 V					
METER DETAILS	MAKE	SR. NO.	CTR	PTR	PRESENT RDG.	PREVIOUS RDG.	DIFF.	M.F.	UNIT GENERATED	
TG-NO.1	SIMCO	195678	800/1 AMP	11 KV/ 110 V	125358.2	122812.9	2545.3	1600	4072480	
TG-NO.2	SIMCO	195677	800/1 AMP	11 KV/ 110 V	69402	66653.5	2748.5	1600	4397600	
TG-NO.3	SIMCO	3511213642	800/1 A	11KV/ 110V	35863.6	42.0	35821.6	160	5731456	
1250 KVA DG SET (SID)	HPL SOCOMEC	1K047405	— /5 AMP	415V	4.4	4.0	0.4	500	200	
750 KVA DG SET-1	HPL SOCOMEC	1K048829	— /5 AMP	415V	5.5	4.3	1.2	240	288	
750 KVA DG SET-2	HPL SOCOMEC	1K048825	— /5 AMP	415V	8.5	4.3	4.2	240	1008	
									<b>UNIT CONSUMED</b>	
AUX. TRANSFORMER-1	DUCATI	27/020290	150/1 AMP	11 KV/ 110 V	3601950	2855835	746115	1	746115	
AUX. TRANSFORMER-2	ENERCON	E34/576-503	400/1 AMP	11 KV/ 110 V	2169	1455	714	1000	714000	
<b>TOTAL UNIT GENERATED (TG-1+2+3)+(DG-1+2+3)</b>		<b>14203032</b>		<b>TOTAL AUX.CONSUMPN. (AUX. X'MER-1+2)</b>		<b>1460115</b>		<b>TOTAL UNIT FOR CESS (Gen. - Aux.Con.)</b>		<b>12742917</b>

ISPAT GODAWARI LIMITED  
SIGNATURE   
NAME: R.K.SHAKAR (Dy.Mgr.Electrical)

CSEB O&M  
SIGNATURE  
NAME: .....

CSEB MRT  
SIGNATURE   
NAME: ..... K.K. Yadav

# POWER GENERATION GODAWARI POWER & ISPAT LIMITED

DATE: 28.02.2006.....

TIME: 16:05 HRS.

GENERATOR DETAILS										
GENERATOR DETAILS	MAKE	SR. NO.	CAPACITY	CT PROVIDED	PT PROVIDED					
TG-NO.1	C.A. PARSON	3682	10 MW	800/1 AMP	11 KV/ 110 V					
TG-NO.2	C.A. PARSON	3806	10 MW	800/1 AMP	11 KV/ 110 V					
TG-NO.3	HITACHI	MP12428	10 MW	800/1 AMP	11 KV/ 110 V					
1250 KVA DG SET (SID)	KERELA ELECT.	31005	1250kVA	2500/5 AMP	415V					
750 KVA DG SET-1	STAMFORD	4101508	750kVA	1200/5 AMP	415V					
750 KVA DG SET-2	STAMFORD	4081548	750kVA	1200/5 AMP	415V					
X'MER DETAILS										
AUX. TRANSFORMER-1	VOLTAMP	JN6021/1	2900kVA	150/1 AMP	11 KV/ 110 V					
AUX. TRANSFORMER-2	EMCO	1923	2500kVA	400/1 AMP	11 KV/ 110 V					
METER DETAILS						PRESENT RDG.	PREVIOUS RDG.	DIFF.	M.F.	UNIT GENERATED
TG-NO.1	SIMCO	195678	800/1 AMP	11 KV/ 110 V	127213.3	125358.2	1855.1	1600	2968160	
TG-NO.2	SIMCO	195677	800/1 AMP	11 KV/ 110 V	71887.5	69402	2485.5	1600	3976800	
TG-NO.3	SIMCO	3511213642	800/1 A	11KV/ 110V	68106	35863.6	32242.4	160	5158784	
1250 kVA DG SET (SID)	HPL SOCOMEC	1KQ47405	— /5 AMP	415V	4.5	4.4	0.1	500	50	
750 kVA DG SET-1	HPL SOCOMEC	1K048829	— /5 AMP	415V	5.5	5.5	0.0	240	0	
750 kVA DG SET-2	HPL SOCOMEC	1K048825	— /5 AMP	415V	8.5	8.5	0.0	240	0	
									UNIT CONSUMED	
AUX. TRANSFORMER-1	DUCATI	27/020290	150/1 AMP	11 KV/ 110 V	4204230	3601950	602280	1	602280	
AUX. TRANSFORMER-2	ENERCON	E34/576-503	400/1 AMP	11 KV/ 110 V	2653	2169	484	1000	484000	
TOTAL UNIT GENERATED (TG-1+2+3)+(DG-1+2+3)		<b>12103794</b>		TOTAL AUX.CONSUMPN. (AUX. X'MER-1+2)		<b>1086280</b>		TOTAL UNIT FOR CESS (Gen. - Aux.Con.)		<b>11017514</b>

ISPAT GODAWARI LIMITED

SIGNATURE

*[Signature]*  
28/02/06

NAME: R.K.SHAKAR (Dy.Mgr.Electrical)

CSEB O&M

SIGNATURE

*[Signature]*  
AE M

NAME: .....

CSEB MRT

SIGNATURE

*[Signature]*  
AE (SJM) Rg

NAME: .....

**POWER GENERATION GODAWARI POWER & ISPA LIMITED**

MARCH - 2006

DATE: 31.03.2006.....

TIME: .....18:20 HRS.

GENERATOR DETAILS						X'MER DETAILS				
GENERATOR DETAILS	MAKE	SR. NO.	CAPACITY	CT PROVIDED	PT PROVIDED					
TG-NO.1	C.A. PARSON	3682	10 MW	800/1 AMP	11 KV/ 110 V					
TG-NO.2	C.A. PARSON	3806	10 MW	800/1 AMP	11 KV/ 110 V					
TG-NO.3	HITACHI	MP12428	10 MW	800/1 AMP	11 KV/ 110 V					
1250 KVA DG SET (SID)	KERELA ELECT.	31005	1250kVA	2500/5 AMP	415V					
750 KVA DG SET-1	STAMFORD	4101508	750kVA	1200/5 AMP	415V					
750 KVA DG SET-2	STAMFORD	4081548	750kVA	1200/5 AMP	415V					
X'MER DETAILS										
AUX. TRANSFORMER-1	VOLTAMP	JN6021/1	2900kVA	150/1 AMP	11 KV/ 110 V					
AUX. TRANSFORMER-2	EMCO	1923	2500kVA	400/1 AMP	11 KV/ 110 V					
METER DETAILS						PRESENT RDG.	PREVIOUS RDG.	DIFF.	M.F.	UNIT GENERATED
TG-NO.1	SIMCO	195678	800/1 AMP	11 KV/ 110 V	128535.2	127213.3	1321.9	1600	2115040	
TG-NO.2	SIMCO	195677	800/1 AMP	11 KV/ 110 V	74074.1	71887.5	2186.6	1600	3498560	
TG-NO.3	SIMCO	3511213642	800/1 A	11KV/ 110V	100418.9	68106	32312.9	160	5170064	
1250 kVA DG SET (SID)	HPL SOCOMEC	1K047405	— /5 AMP	415V	8.7	4.5	4.2	500	2100	
750 kVA DG SET-1	HPL SOCOMEC	1K048829	— /5 AMP	415V	5.5	5.5	0.0	240	0	
750 kVA DG SET-2	HPL SOCOMEC	1K048825	— /5 AMP	415V	8.5	8.5	0.0	240	0	
										UNIT CONSUMED
AUX. TRANSFORMER-1	DUCATI	27/020290	150/1 AMP	11 KV/ 110 V	4294545 / 549270	4204230	90315 + 549270	1	639585	
AUX. TRANSFORMER-2	ENERCON	E34/576-503	400/1 AMP	11 KV/ 110 V	3188	2653	535	1000	535000	
TOTAL UNIT GENERATED (TG-1+2+3)+(DG-1+2+3)		<b>10785764</b>		TOTAL AUX.CONSUMPN. (AUX. X'MER-1+2)		<b>1174585</b>	TOTAL UNIT FOR CESS (Gen. - Aux.Con.)		<b>9611179</b>	

ISPAT GODAWARI LIMITED

SIGNATURE

NAME: R.K.SHAKAR (Dy.Mgr.Electrical)

CSEB O&M

SIGNATURE

NAME: .....

CSEB MRT

SIGNATURE

NAME: .....


*[Handwritten Signature]*  
31/3/06  
A.E.W.


**POWER CORPORATION GODAWARI POWER AND ISPAT LIMITED**



DATE: 29.04.2006

TIME: 18:15 HRS.

GENERATOR DETAILS		MAKE	SR. NO.	CAPACITY	CT PROVIDED	PT PROVIDED				
TG-NO.1	C.A. PARSON	3682	10 MW	800/1 AMP	11 KV/ 110 V					
TG-NO.2	C.A. PARSON	3806	10 MW	800/1 AMP	11 KV/ 110 V					
TG-NO.3	HITACHI	MP12428	10 MW	800/1 AMP	11 KV/ 110 V					
1250 kVA DG SET (SID)	KERELA ELECT.	31005	1250kVA	2500/5 AMP	415V					
750 kVA DG SET-1	STAMFORD	4101508	750kVA	1200/5 AMP	415V					
750 kVA DG SET-2	STAMFORD	4081548	750kVA	1200/5 AMP	415V					
X'MER DETAILS										
AUX. TRANSFORMER-1	VOLTAMP	JN6021/1	2900kVA	150/1 AMP	11 KV/ 110 V					
AUX. TRANSFORMER-2	EMCO	1923	2500kVA	400/1 AMP	11 KV/ 110 V					
METER DETAILS		MAKE	SR. NO.	CTR	PTR	PRESENT RDG.	PREVIOUS RDG.	DIFF.	M.F.	UNIT GENERATED
TG-NO.1	SIMCO	195678	800/1 AMP	11 KV/ 110 V	132391.8	128535.2	3856.6	1600	6170560	
TG-NO.2	SIMCO	195677	800/1 AMP	11 KV/ 110 V	76925.3	74074.1	2851.2	1600	4561920	
TG-NO.3	SIMCO	3511213642	800/1 A	11KV/ 110V	125723	100418.9	25304.1	160	4048656	
1250 kVA DG SET (SID)	HPL SOCOMEC	1K047405	— /5 AMP	415V	8.7	8.7	0.0	500	0	
750 kVA DG SET-1	HPL SOCOMEC	1K048829	— /5 AMP	415V	5.5	5.5	0.0	240	0	
750 kVA DG SET-2	HPL SOCOMEC	1K048825	— /5 AMP	415V	8.5	8.5	0.0	240	0	
UNIT CONSUMED										
AUX. TRANSFORMER-1	DUCATI	27/020290	150/1 AMP	11 KV/ 110 V	1454715	549270	905445	1	905445	
AUX. TRANSFORMER-2	ENERCON	E34/576-503	400/1 AMP	11 KV/ 110 V	3787	3188	599	1000	599000	
TOTAL UNIT GENERATED (TG-1+2+3)+(DG-1+2+3)		<b>14781136</b>		TOTAL AUX.CONSUMPN. (AUX. X'MER-1+2)		<b>1504445</b>		TOTAL UNIT FOR CESS (Gen. - Aux.Con.)		<b>13276691</b>

GODAWARI POWER AND ISPAT LIMITED  
SIGNATURE   
NAME: R.K.SHAKAR (Dy. Mgr. Electrical)

CSEB O&M   
SIGNATURE  
NAME: .....

  
CSEB MRT  
SIGNATURE  
NAME: 

# GODAWARI POWER & ISPAT LIMITED

DATE: 31.05.2006

TIME: 13:05 HRS.

GENERATOR DETAILS		MAKE	SR. NO.	CAPACITY	CT PROVIDED	PT PROVIDED				
TG-NO.1		C.A. PARSON	3682	10 MW	800/1 AMP	11 KV/ 110 V				
TG-NO.2		C.A. PARSON	3806	10 MW	800/1 AMP	11 KV/ 110 V				
TG-NO.3		HITACHI	MP12428	10 MW	800/1 AMP	11 KV/ 110 V				
1250 kVA DG SET (SID)		KERELA ELECT.	31005	1250kVA	2500/5 AMP	415V				
750 kVA DG SET-1		STAMFORD	4101508	750kVA	1200/5 AMP	415V				
750 kVA DG SET-2		STAMFORD	4081548	750kVA	1200/5 AMP	415V				
X'MER DETAILS										
AUX. TRANSFORMER-1		VOLTAMP	JN6021/1	2900kVA	150/1 AMP	11 KV/ 110 V				
AUX. TRANSFORMER-2		EMCO	1923	2500kVA	400/1 AMP	11 KV/ 110 V				
METER DETAILS	MAKE	SR. NO.	CTR	PTR	PRESENT RDG.	PREVIOUS RDG.	DIFF.	M.F.	UNIT GENERATED	
TG-NO.1	SIMCO	195678	800/1 AMP	11 KV/ 110 V	136206.0	132391.8	3814.2	1600	6102720	
TG-NO.2	SIMCO	195677	800/1 AMP	11 KV/ 110 V	80066.3	76925.3	3141	1600	5025600	
TG-NO.3	SIMCO	3511213642	800/1 A	11KV/ 110V	161948.5	125723	36225.5	160	5796080	
1250 kVA DG SET (SID)	HPL SOCOMEC	1K047405	— /5 AMP	415V	8.7	8.7	0	500	0	
750 kVA DG SET-1	HPL SOCOMEC	1K048829	— /5 AMP	415V	5.5	5.5	0	240	0	
750 kVA DG SET-2	HPL SOCOMEC	1K048825	— /5 AMP	415V	8.5	8.5	0	240	0	
									UNIT CONSUMED	
AUX. TRANSFORMER-1		DUCATI	27/020290	150/1 AMP	11 KV/ 110 V	2445735	1454715	991020	1	991020
AUX. TRANSFORMER-2		ENERCON	E34/576-503	400/1 AMP	11 KV/ 110 V	4534	3787	747	1000	747000
TOTAL UNIT GENERATED (TG-1+2+3)+(DG-1+2+3)		<b>16924400</b>		TOTAL AUX.CONSUMPN. (AUX. X'MER-1+2)		<b>1738020</b>		TOTAL UNIT FOR CESS (Gen. - Aux.Con.)		<b>15186380</b>

GODAWARI POWER AND ISPAT LIMITED

SIGNATURE

*R.K. Shakar*  
31/05/06

NAME: R.K.SHAKAR (Dy.Mgr.Electrical)

CSEB O&M

SIGNATURE

NAME: .....

*[Handwritten Signature]*  
31/5/06  
RE-88

CSEB MRT

SIGNATURE

NAME: .....

*[Handwritten Signature]*  
31/05/06  
K.K. Yadav

# POWER GENERATION GODAWARI POWER & ISPAT LIMITED

DATE: 30.06.2006

TIME: 14:10 HRS.

GENERATOR DETAILS										
TC NO.	MAKE	SR. NO.	CAPACITY	CT PROVIDED	PT PROVIDED					
TC-NO.1	C.A. PARSON	3682	10 MW	800/1 AMP	11 KV/ 110 V					
TC-NO.2	C.A. PARSON	3806	10 MW	800/1 AMP	11 KV/ 110 V					
TC-NO.3	HITACHI	MP12428	10 MW	800/1 AMP	11 KV/ 110 V					
1250 KVA DG SET (S/D)	KERELA ELECT.	31005	1250KVA	2500/5 AMP	415V					
750 KVA DG SET-1	STAMFORD	4101508	750KVA	1200/5 AMP	415V					
750 KVA DG SET-2	STAMFORD	4081548	750KVA	1200/5 AMP	415V					
X'IMER DETAILS										
AUX. TRANSFORMER-1	VOLTAMP	JN6021/1	2900KVA	150/1 AMP	11 KV/ 110 V					
AUX. TRANSFORMER-2	EMCO	1923	2500KVA	400/1 AMP	11 KV/ 110 V					
METER DETAILS										
TC NO.	MAKE	SR. NO.	CTR	PTR	PRESENT RDG.	PREVIOUS RDG.	DIFF.	M.F.	UNIT GENERATED	
TC NO.1	SIMCO	195678	800/1 AMP	11 KV/ 110 V	140040.0	136206.0	3834	1600	613440	
TC NO.2	SIMCO	195877	800/1 AMP	11 KV/ 110 V	81833.2	80066.3	1766.9	1600	2827040	
TC NO.3	SIMCO	3511213842	800/1 A	11KV/ 110V	193440	161948.5	31491.5	160	5038640	
1250 KVA DG SET (S/D)	HPL SOCOMEC	1K047405	— /5 AMP	415V	8.7	8.7	0	500	0	
750 KVA DG SET-1	HPL SOCOMEC	1K048829	— /5 AMP	415V	5.5	5.5	0	240	0	
750 KVA DG SET-2	HPL SOCOMEC	1K048825	— /5 AMP	415V	8.5	8.5	0	240	0	
AUX TRANSFORMER-1	DUCATI	27/020290	150/1 AMP	11 KV/ 110 V	3419520	2445735	973785	1	973785	
AUX TRANSFORMER-2	ENERCON	E34/576-503	400/1 AMP	11 KV/ 110 V	5207	4534	673	1000	673000	
TOTAL UNIT GENERATED (TC-1+2+3)-(DG-1+2+3)		14000380		TOTAL AUX. CONSUMPN. (AUX. X'IMER-1+2)		1346785		TOTAL UNIT FOR CESS (Gen - Aux. Con.)		12353295

GODAWARI POWER AND ISPAT LIMITED

SIGNATURE

NAME: R.K. SHAKAR (Mgt. Electrical)

CSEB O&M

SIGNATURE

NAME: .....

CSEB MRT

SIGNATURE

NAME: .....

# POWER GENERATION GODAWARI POWER & ISPAT LIMITED

DATE: 31.07.2006

TIME: 15:10 HRS.

Fax. To SHRI MARATHE JL.

GENERATOR DETAILS	MAKE	SR. NO.	CAPACITY	CT PROVIDED	PT PROVIDED					
TG-NO.1	C.A. PARSON	3682	10 MW	800/1 AMP	11 KV/ 110 V					
TG-NO.2	C.A. PARSON	3806	10 MW	800/1 AMP	11 KV/ 110 V					
TG-NO.3	HITACHI	MP12428	10 MW	800/1 AMP	11 KV/ 110 V					
1250 KVA DG SET (SID)	KERELA ELECT.	31005	1250KVA	2500/5 AMP	415V					
750 KVA DG SET-1	STAMFORD	4101508	750KVA	1200/5 AMP	415V					
750 KVA DG SET-2	STAMFORD	4081548	750KVA	1200/5 AMP	415V					
X'MER DETAILS										
AUX. TRANSFORMER-1	VOLTAMP	JN6021/1	2900KVA	150/1 AMP	11 KV/ 110 V					
AUX. TRANSFORMER-2	EMCO	1923	2500KVA	400/1 AMP	11 KV/ 110 V					
METER DETAILS	MAKE	SR. NO.	CTR	PTR	PRESENT RDG.	PREVIOUS RDG.	DIFF.	M.F.	UNIT GENERATED	
TG-NO.1	SIMCO	195678	800/1 AMP	11 KV/ 110 V	143944.8	140040.0	3904.8	1600	6247680	
TG-NO.2	SIMCO	195677	800/1 AMP	11 KV/ 110 V	84092.6	81833.2	2259.4	1600	3615040	
TG-NO.3	SIMCO	3511213642	800/1 A	11KV/ 110V	211514	193440	18074	160	2891840	
1250 KVA DG SET (SID)	HPL SOCOMEC	1K047405	— /5 AMP	415V	8.7	8.7	0	500	0	
750 KVA DG SET-1	HPL SOCOMEC	1K048829	— /5 AMP	415V	5.5	5.5	0	240	0	
750 KVA DG SET-2	HPL SOCOMEC	1K048825	— /5 AMP	415V	8.5	8.5	0	240	0	
									UNIT CONSUMED	
AUX. TRANSFORMER-1	DUCATI	27/020290	150/1 AMP	11 KV/ 110 V	4293480 / 39840	3419520	873960 + 39840	1	913800	
AUX. TRANSFORMER-2	ENERCON	E34/576-503	400/1 AMP	11 KV/ 110 V	5772	5207	565	1000	565000	
<b>TOTAL UNIT GENERATED (TG-1+2+3)+(DG-1+2+3)</b>		<b>12754560</b>		<b>TOTAL AUX.CONSUMPN. (AUX. X'MER-1+2)</b>		<b>1478800</b>		<b>TOTAL UNIT FOR CESS (Gen. - Aux.Con.)</b>		<b>11275760</b>

GODAWARI POWER AND ISPAT LIMITED

SIGNATURE

NAME: R.K.SHAKAR (Manager Electrical)

CSEB O&M

SIGNATURE

NAME: .....

CSEB MRT

SIGNATURE

NAME: .....

# POWER GENERATION GODAWARI POWER & ISPAT LIMITED

DATE: 31.08.2006


TIME: 16:25 HRS.

GENERATOR DETAILS		MAKE	SR. NO.	CAPACITY	CT PROVIDED	PT PROVIDED					
TG-NO.1	C.A. PARSON	3682	10 MW	800/1 AMP	11 KV/ 110 V						
TG-NO.2	C.A. PARSON	3806	10 MW	800/1 AMP	11 KV/ 110 V						
TG-NO.3	HITACHI	MP12428	10 MW	800/1 AMP	11 KV/ 110 V						
1250 kVA DG SET (SID)	KERELA ELECT.	31005	1250kVA	2500/5 AMP	415V						
750 kVA DG SET-1	STAMFORD	4101508	750kVA	1200/5 AMP	415V						
750 kVA DG SET-2	STAMFORD	4081548	750kVA	1200/5 AMP	415V						
<b>X'MER DETAILS</b>											
AUX. TRANSFORMER-1	VOLTAMP	JN6021/1	2900kVA	150/1 AMP	11 KV/ 110 V						
AUX. TRANSFORMER-2	EMCO	1923	2500kVA	400/1 AMP	11 KV/ 110 V						
METER DETAILS		MAKE	SR. NO.	CTR	PTR	PRESENT RDG.	PREVIOUS RDG.	DIFF.	M.F.	UNIT GENERATED	
TG-NO.1	SIMCO	195678	800/1 AMP	11 KV/ 110 V		147030.0	143944.8	3085.2	1600	4936320	
TG-NO.2	SIMCO	195677	800/1 AMP	11 KV/ 110 V		86258.4	84092.6	2165.8	1600	3465280	
TG-NO.3	SIMCO	3511213642	800/1 A	11KV/ 110V		232414.0	211514.0	20900	160	3344000	
1250 kVA DG SET (SID)	HPL SOCOMEC	1K047405	— /5 AMP	415V		13.7	8.7	5	500	2500	
750 kVA DG SET-1	HPL SOCOMEC	1K048829	— /5 AMP	415V		14.8	5.5	9.3	240	2232	
750 kVA DG SET-2	HPL SOCOMEC	1K048825	— /5 AMP	415V		10.7	8.5	2.2	240	528	
<b>UNIT CONSUMED</b>											
AUX. TRANSFORMER-1	DUCATI	27/020290	150/1 AMP	11 KV/ 110 V		965865	39840	926025	1	926025	
AUX. TRANSFORMER-2	ENERCON	E34/576-503	400/1 AMP	11 KV/ 110 V		6328	5772	556	1000	556000	
<b>TOTAL UNIT GENERATED (TG-1+2+3)+(DG-1+2+3)</b>		<b>11750860</b>			<b>TOTAL AUX.CONSUMPN. (AUX. X'MER-1+2)</b>		<b>1482025</b>		<b>TOTAL UNIT FOR CESS (Gen. - Aux.Con.)</b>		<b>10268835</b>

GODAWARI POWER AND ISPAT LIMITED


SIGNATURE 

NAME: R.K.SHAKAR (Manager Electrical)

CSEB O&M 

SIGNATURE

NAME: .....

CSEB MRT 

SIGNATURE

NAME: .....




# POWER GENERATION GODAWARI POWER & ISPAT LIMITED

DATE: 29.09.2006

TIME: 14:40 HRS.

GENERATOR DETAILS	MAKE	SR. NO.	CAPACITY	CT PROVIDED	PT PROVIDED					
TG-NO.1	C.A. PARSON	3682	10 MW	800/1 AMP	11 KV/ 110 V					
TG-NO.2	C.A. PARSON	3806	10 MW	800/1 AMP	11 KV/ 110 V					
TG-NO.3	HITACHI	MP12428	10 MW	800/1 AMP	11 KV/ 110 V					
1250 KVA DG SET (SID)	KERELA ELECT.	31005	1250kVA	2500/5 AMP	415V					
750 KVA DG SET-1	STAMFORD	4101508	750kVA	1200/5 AMP	415V					
750 KVA DG SET-2	STAMFORD	4081548	750kVA	1200/5 AMP	415V					
<b>X'MER DETAILS</b>										
AUX. TRANSFORMER-1	VOLTAMP	JN6021/1	2900kVA	150/1 AMP	11 KV/ 110 V					
AUX. TRANSFORMER-2	EMCO	1923	2500kVA	400/1 AMP	11 KV/ 110 V					
METER DETAILS	MAKE	SR. NO.	CTR	PTR	PRESENT RDG.	PREVIOUS RDG.	DIFF.	M.F.	UNIT GENERATED	
TG-NO.1	SIMCO	195678	800/1 AMP	11 KV/ 110 V	150677.6	147030.0	3647.6	1600	5836160	
TG-NO.2	SIMCO	195677	800/1 AMP	11 KV/ 110 V	88083.2	86258.4	1824.8	1600	2919680	
TG-NO.3	SIMCO	3511213642	800/1 A	11KV/ 110V	257821.0	232414.0	25407	160	4065120	
1250 KVA DG SET (SID)	HPL SOCOMEC	1K047405	— /5 AMP	415V	15.0	13.7	1.3	500	650	
750 KVA DG SET-1	HPL SOCOMEC	1K048829	— /5 AMP	415V	15.1	14.8	0.3	240	72	
750 KVA DG SET-2	HPL SOCOMEC	1K048825	— /5 AMP	415V	11.4	10.7	0.7	240	168	
<b>UNIT CONSUMED</b>										
AUX. TRANSFORMER-1	DUCATI	27/020290	150/1 AMP	11 KV/ 110 V	1947720	965865	981855	1	981855	
AUX. TRANSFORMER-2	ENERCON	E34/576-503	400/1 AMP	11 KV/ 110 V	7000	6328	672	1000	672000	
<b>TOTAL UNIT GENERATED</b> (TG-1+2+3)+(DG-1+2+3)		<b>12821850</b>		<b>TOTAL AUX.CONSUMPN.</b> (AUX. X'MER-1+2) + (DG-2+3)		<b>1654095</b>		<b>TOTAL UNIT FOR CESS</b> (Gen. - Aux.Con.)		<b>11167755</b>

GODAWARI POWER AND ISPAT LIMITED

SIGNATURE 

NAME: R.K.SHAKAR (Manager Electrical)

CSEB O&M

SIGNATURE 

NAME: .....

CSEB MRT

SIGNATURE 

NAME: .....


*AE (MRT-1)*  
29.09.06


# POWER GENERATION GODAWARI POWER & ISPAT LIMITED


DATE: 31.10.2006

TIME: 17:20 HRS.

GENERATOR DETAILS	MAKE	SR. NO.	CAPACITY	CT PROVIDED	PT PROVIDED					
TG-NO.1	C.A. PARSON	3682	10 MW	800/1 AMP	11 KV/ 110 V	<b>NOTE:-</b> T.G. # 3, SEMS MAKE ENERGY METER PUT IN SERVICE ON 08/10/2006, AT 14:00 HRS. COPY OF TEST CERTIFICATE & COVERING LETTER ATTACHED FOR YOUR READY REFERENCE.				
TG-NO.2	C.A. PARSON	3806	10 MW	800/1 AMP	11 KV/ 110 V					
TG-NO.3	HITACHI	MP12428	10 MW	800/1 AMP	11 KV/ 110 V					
1250 kVA DG SET (SID)	KERELA ELECT.	31005	1250kVA	2500/5 AMP	415V					
750 kVA DG SET-1	STAMFORD	4101508	750kVA	1200/5 AMP	415V					
750 kVA DG SET-2	STAMFORD	4081548	750kVA	1200/5 AMP	415V					
<b>X'MER DETAILS</b>						<b>T.G. # 3 SIMCO METER STOPPED AT READING <u>268268.6</u></b>				
AUX. TRANSFORMER-1	VOLTAMP	JN6021/1	2900kVA	150/1 AMP	11 KV/ 110 V					
AUX. TRANSFORMER-2	EMCO	1923	2500kVA	400/1 AMP	11 KV/ 110 V					
METER DETAILS	MAKE	SR. NO.	CTR	PTR	PRESENT RDG.	PREVIOUS RDG.	DIFF.	M.F.	UNIT GENERATED	
TG-NO.1	SIMCO	195678	800/1 AMP	11 KV/ 110 V	155105.0	150677.6	4427.4	1600	7083840	
TG-NO.2	SIMCO	195677	800/1 AMP	11 KV/ 110 V	90692.5	88083.2	2609.3	1600	4174880	
TG-NO.3	<b>SIMCO / SEMS</b>	<b>3511213642 / MSE64366</b>	<b>800/1 A / 800/1A</b>	<b>11KV/ 110V</b>	<b>268268.6 / 4723.7</b>	<b>257821 / 11.5</b>	<b>1671616 +4712200</b>	<b>160 / 1000</b>	<b>6383816</b>	
1250 kVA DG SET (SID)	HPL SOCOMEC	1K047405	— /5 AMP	415V	15.0	15.0	0	500	0	
750 kVA DG SET-1	HPL SOCOMEC	1K048829	— /5 AMP	415V	15.1	15.1	0	240	0	
750 kVA DG SET-2	HPL SOCOMEC	1K048825	— /5 AMP	415V	11.4	11.4	0	240	0	
<b>UNIT CONSUMED</b>										
AUX. TRANSFORMER-1	DUCATI / SEMS	27/020290	150/1 AMP	11 KV/ 110 V	3129135	1947720	1181415	1	1181415	
AUX. TRANSFORMER-2	ENERCON / SEMS	E34/576-503	400/1 AMP	11 KV/ 110 V	7590	7000	590	1000	590000	
<b>TOTAL UNIT GENERATED (TG-1+2+3)+(DG-1+2+3)</b>		<b>17642536</b>			<b>TOTAL AUX.CONSUMPN. (AUX. X'MER-1+2) + (DG-2+3)</b>		<b>1771415</b>		<b>TOTAL UNIT FOR CESS (Gen. - Aux.Con.)</b>	
									<b>15871121</b>	

GODAWARI POWER AND ISPAT LIMITED  
 SIGNATURE   
 NAME: R.K.SHAKAR (Manager Electrical)

CSEB O&M  
 SIGNATURE   
 NAME: .....

CSEB MRT  
 SIGNATURE   
 NAME: .....


# POWER GENERATION GODAWARI POWER & ISPAT LIMITED


DATE: 30.11.2006


TIME: 15:00 HRS.

GENERATOR DETAILS										
GENERATOR DETAILS	MAKE	SR. NO.	CAPACITY	CT PROVIDED	PT PROVIDED					
TG-NO.1	C.A. PARSON	3682	10 MW	800/1 AMP	11 KV/ 110 V					
TG-NO.2	C.A. PARSON	3806	10 MW	800/1 AMP	11 KV/ 110 V					
TG-NO.3	HITACHI	MP12428	10 MW	800/1 AMP	11 KV/ 110 V					
1250 KVA DG SET (SID)	KERELA ELECT.	31005	1250kVA	2500/5 AMP	415V					
750 KVA DG SET-1	STAMFORD	4101508	750kVA	1200/5 AMP	415V					
750 KVA DG SET-2	STAMFORD	4081548	750kVA	1200/5 AMP	415V					
<b>X'MER DETAILS</b>										
AUX. TRANSFORMER-1	VOLTAMP	JN6021/1	2900kVA	150/1 AMP	11 KV/ 110 V					
AUX. TRANSFORMER-2	EMCO	1923	2500kVA	400/1 AMP	11 KV/ 110 V					
METER DETAILS						PRESENT RDG.	PREVIOUS RDG.	DIFF.	M.F.	UNIT GENERATED
TG-NO.1	SIMCO / SEMS	195678/ MSE64365	800/1 A / 800/1A	CTR	PTR	158088.7 / 1245.2	155105.0 / 11.6	2983.7 /	1600 /	(4773920 + 1233600)
TG-NO.2	SIMCO / SEMS	195677/ MSE64364	800/1 A / 800/1A			91130.0 / 3606.0	90692.5 / 13.0	1233.6	1000	= 6007520
TG-NO.3	SEMS	MSE64366	800/1A			10628.5	4723.7	437.5 /	1600 /	(700000 + 3593000) =
1250 KVA DG SET (SID)	HPL SOCOMEC	1K047405	— /5 AMP	800/1A	11KV/ 110V	16.0	15.0	3593.0	1000	4293000
750 KVA DG SET-1	HPL SOCOMEC	1K048829	— /5 AMP	800/1A	11KV/ 110V	415V	15.0	5904.8	1000	5904800
750 KVA DG SET-2	HPL SOCOMEC	1K048825	— /5 AMP	800/1A	11KV/ 110V	415V	15.1	1	500	500
						11.4	11.4	0	240	0
								0	240	0
										<b>UNIT CONSUMED</b>
AUX. TRANSFORMER-1	SEMS	MSE64368	150/1 AMP	11 KV/ 110 V		1959.8	570	1389.8	750	1042350
AUX. TRANSFORMER-2	SEMS	MSE64367	400/1 AMP	11 KV/ 110 V		531.1	117.1	414	2000	828000
<b>TOTAL UNIT GENERATED (TG-1+2+3)+(DG-1+2+3)</b>		<b>16205820</b>		<b>TOTAL AUX.CONSUMPN. (AUX. X'MER-1+2) + (DG-2+3)</b>		<b>1870350</b>		<b>TOTAL UNIT FOR CESS (Gen. - Aux.Con.)</b>		<b>14335470</b>

**NOTE:-** 1) T.G. # 1 SEMS MAKE ENERGY METER PUT IN SERVICE ON 22/11/2006, AT 20:04 HRS.  
2) T.G. # 2 SEMS MAKE ENERGY METER PUT IN SERVICE ON 05/11/2006, AT 21:42 HRS.

GODAWARI POWER AND ISPAT LIMITED  
SIGNATURE   
NAME: R.K.SHAKAR (Manager Electrical)

CSEB O&M  
SIGNATURE   
NAME: .....

CSEB MRT  
SIGNATURE   
NAME: .....  
AE (MRT-1)  
30/11/06

# POWER GENERATION GODAWARI POWER & ISPAT LIMITED

DATE: 30.12.2006

TIME: 15:45 HRS.

GENERATOR DETAILS	MAKE	SR. NO.	CAPACITY	CT PROVIDED	PT PROVIDED					
TG-NO.1	C.A. PARSON	3682	10 MW	800/1 AMP	11 KV/ 110 V					
TG-NO 2	C.A. PARSON	3806	10 MW	800/1 AMP	11 KV/ 110 V					
TG-NO 3	HITACHI	MP12428	10 MW	800/1 AMP	11 KV/ 110 V					
TG-NO 4	SHANDONG JINAN POWER EQUIPMENT FACTORY	30034	30MW	2500/1 AMP	11 KV/ 110 V					
1250 KVA DG SET (SID)	KERELA ELECT.	31005	1250kVA	2500/5 AMP	415V					
750 KVA DG SET-1	STAMFORD	4101508	750kVA	1200/5 AMP	415V					
750 KVA DG SET-2	STAMFORD	4081548	750kVA	1200/5 AMP	415V					
X'MER DETAILS										
AUX. TRANSFORMER-1	VOLTAMP	JN6021/1	2900kVA	150/1 AMP	11 KV/ 110 V					
AUX. TRANSFORMER-2	EMCO	1923	2500kVA	400/1 AMP	11 KV/ 110 V					
METER DETAILS	MAKE	SR. NO.	CTR	PTR	PRESENT RDG	PREVIOUS RDG	DIFF	M.F	UNIT GENERATED	
TG-NO 1	SEMS	MSE64365	800/1A	11KV/ 110V	2576.9	1245.2	1331.7	1000	1331700	
TG-NO 2	SEMS	MSE64364	800/1A	11KV/ 110V	4456.5	3606.0	850.5	1000	850500	
TG-NO 3	SEMS	MSE64366	800/1A	11KV/ 110V	12790.2	10628.5	2161.7	1000	2161700	
TG-NO 4	SEMS	MSE64369	2500/1A	11KV/ 110V	18084.0	55.0	18029.0	800	14423200	
1250 KVA DG SET (SID)	HPL SOCOMEC	1K047405	— /5 AMP	415V	19.5	16.0	3.5	500	1750	
750 KVA DG SET-1	HPL SOCOMEC	1K048829	— /5 AMP	415V	15.4	15.1	0.3	240	72	
750 KVA DG SET-2	HPL SOCOMEC	1K048825	— /5 AMP	415V	11.9	11.4	0.5	240	120	
UNIT CONSUMED										
AUX. TRANSFORMER-1	SEMS	MSE64368	150/1 AMP	11 KV/ 110 V	3090.7	1959.8	1130.9	750	848175	
AUX. TRANSFORMER-2	SEMS	MSE64367	400/1 AMP	11 KV/ 110 V	1058.6	531.1	527.5	2000	1055000	
TOTAL UNIT GENERATED (TG-1+2-3+4)+(DG-1+2+3)		<b>18769042</b>		TOTAL AUX. CONSUMPN. (AUX. X'MER-1+2) + (DG-2+3)		<b>1903367</b>		TOTAL UNIT FOR CESS (Gen. - Aux.Con.)		<b>16865675</b>

GODAWARI POWER AND ISPAT LIMITED

SIGNATURE 

NAME: R.K.SHAKAR (Manager Electrical)

CSEB O&M

SIGNATURE

NAME: .....

CSEB MRT

SIGNATURE 

NAME: ..... 30/12/06