CDM project activity issuance review form		
(By submitting this form, a Party involved (through the designated national authority) or an Executive Board member may request that a review is undertaken)		
Designated national authority/Executive Board member submitting this form (Name in print)		
Title of the proposed CDM project activity for which issuance is requested	gases from Blast	of Electricity through combustion of waste furnace and Corex units at JSW Steel it 1), at Torangallu
DOE that requested for issuance and date of request	DNV 14/05/08	
Please indicate, in accordance with paragraphs 65 of the CDM modalities and procedures, for which reason(s) you request review. (Place a cross (X) in front of the reason)		
Fraud Malfeasance _x Incompetence		
Please indicate reasons for the request for review and attach any supporting documentation to this request form. (if space is not sufficient please attach further reasons)		
form. (If space is not sufficient please attach further reasons) As verified by the DOE in page 6 of the Verification Report, .consideration of the project activity efficiency of 33.375% for the emission factor is deemed conservative However, 33.00% has been applied in the calculation of emission factor in the spreadsheet and this results in approximately 8,000 more CERs are being claimed for the project activity. Clarification is required on how the DOE has verified that this approach is conservative.		
Section below to be filled in by UNF	CCC secretariat	
Date received at UNFCCC secretariat		04.06.2008