



REVIEW OF THE PROJECT ACTIVITY

2.25 MW Rice Husk based cogeneration plant at Siddeshwari Industries Pvt Ltd (1004)

At its thirty-third meeting the Board agreed to register the project activity if the project participant and the DOE submit a revised PDD and corresponding revised validation report that presents baseline emission factors for the following options: continuation of the current energy supply system, importation of electricity from the grid, coal fired cogeneration and rice husk-fired cogeneration. In each case these emission factors should be calculated separately for the electrical and heat components. The baseline emission factor applied for the project activity should then be the most conservative of the calculated factors.

At its thirty-fifth meeting the Board could not register the project activity submitted for registration by the DOE (SGS), considering that the project participant and DOE failed to provide emission factors for each of the alternatives as requested by the Board following a review of the project activity, and the Board, therefore, could not assess the suitability or correctness of the baseline being established for this project.
