

CENTRAL UTILITY AND INFRASTRUCTURE - ARVIND MILLS LTD
ETP AND WATER TREATMENT PLANT


Internal Note

1st May, 2002

From: Mr. Sandeep Patel (Water treatment plant and ETP)

Dear Mr. Saraiya,

Our DM Water which is required for 13 TPH Biomass based FBC boiler is costing Rs. 15 Per m^3 . Considering approximate annual water consumption of 45540 m^3 for the 'Renewable Bio-mass Residue base Steam Generation' project, DM water cost per year worked out to be Rs.683100.


 Sandeep Patel
 Manager, ETP and Water Treatment Plant.
 The Arvind Mills Ltd., Santej
 Nr. Khetraj, Dist. P. VADSAR Ta. Khetraj
 Pin 382725 P. No. 2764-21100/21101