

**JHARKHAND STATE ELECTRICITY BOARD**  
Singhbhura Area, Jamshedpur 1st floor Co-Op. Bank Bldg. Ristapur, Jamshedpur

Letter No. 22/13 / GM: SA: JSR: DATED: THE 9 / 9 / 2005

To,

M/s Kohinoor Steel (P) Ltd.  
Director-Shri Vijay Bothra  
S/o Shri R. K. Bothra  
At- Bulandih, Mouza- Dhunaburu P.O. Chandil  
Dist- Saraikela Kharsawan

Sub: Sanction of load of 1500KVA on 33KV of M/s Kohinoor Steel (P) Ltd. At Bulandih, Chandil


Ref: 1. Your appl. vide money receipt no. 714491 dated 11/05/05  
2. ESE, CBSA L.No. 1085 dt. 05.09.05

Having seen the documents and receipts, copies submitted by the ESE Electrical Circle, Chaibasa and above reference the undersigned is pleased to accord sanction of 1500 kVA load on 33KV (H) tariff to you at works at Bulandih, Mouza- Dhunaburu P.O. Chandil Dist: Saraikela Kharsawan with the terms and conditions as enumerated here under:

1. You shall have to execute an agreement in the prescribed form of the Board in the office of the ESE Electrical Supply Circle, Chaibasa on any working day.
2. The security amount as calculated and asked by the office of ESE, Chaibasa on 1500KVA load on tariff will have to be deposited by in the shape of Bank Draft / Bankers cheque in the office of Asst. Electric Supply Sub-Division Chandil on any working day.
3. The estimate for the construction of 33KV feeder (independent) and other works shall have to be deposited by you in the office of Asst. Elect. Engineer, Electric Supply Sub-Division, Chandil on any working day.
4. You shall have to procure power transformer with ISI Mark for installation in your premises. The total capacity of power transformer and auxiliary transfer if any shall not exceed more of the sanctioned load. If the capacity of the transformer was found to be more than 150% of the sanctioned load i.e. 2250KVA power shall not be supplied to your plant.
5. Suitable metering arrangement for installation of CT, PT, units etc shall have to be submitted to the office of ESE, Chaibasa.
6. You shall have to install shunt capacitor of Adequate Capacity of ISI mark so as to maintain the power factor of minimum 0.85.
7. You shall have to obtain and submit statutory clearance from electricity Department, Jharkhand, Ranchi in respect of your Electrical Installation and equipments for which you shall have to apply before Electrical Inspector, Govt. of Jharkhand Ranchi.
8. You shall have to clear all outstanding dues, if any, against the sanctioned supply agreement.
9. You shall have to abide by Board's Tariff as applicable to your class of load.

10. You shall have to submit a copy of the purchase document with invoice and test report of the equipments like transformers panels and protective devices before execution of agreement.
11. Metering unit of appropriate capacity and specification will have to be arranged by you if the same is not available in Board's stores.
12. Further conditions if so required will be communicated to you.
13. All the above mentioned formalities are required to be completed within three months from the date of issue of this letter failing which this load sanction shall automatically stand cancelled.

Yours faithfully

  
(C.D. Kumar)

General Manager-cum-Chief Engineer