

भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)



Bharat Heavy Electricals Limited

(A Govt. of India Undertaking)

Power Sector - Southern Region

474, Anna Salai, Nandanam, Chennai-600 035.

Phone : 4330015 (10 lines)

Telex : 041-23089 Grams : BHELPOWER

BHE:TSX:SR:BASL-201

Dt: 11.12.2000

↗
DGM/Technical
Bannari Amman Sugars Ltd.,
Alaganchi Village
Nanjangud Taluk,
Karnataka-571119

Sir,

Sub : 1x16 MW Bannari Amman Sugars Ltd.
Load limitation experienced

Our Engineer, Shri K. Raghuraman visited your power plant on 4th & 5th December in connection with the complaint made by you. The study has revealed that the rise in first stage pressure is due to the salting of flow path of the turbine as a consequence of abnormal water chemistry.

To overcome this problem, it requires steam washing and if required to open the machine and go in for sand blasting for removing the deposition of salts.

At present there is a provision available for steam washing as illustrated in O&M Manual. You may kindly make this arrangement in consultation with BHEL/Hyderabad.

Thanking you and assuring of our best services at all times.

PPH
S. M. A.

4/11/01

(P.K. Thiruvengadam)
AGM/TSX

