



Bannari Amman Sugars Limited,
Unit-II, Nanjangud.
Phone: 08221 - 24707
Fax: 08221 - 24777

~~DPM~~

Mr. Mahalingam
28/11/2000

Fax Message

From:	Dy. General Manager - Tech.	For the Attention of	Mr S MAHALINGAM Dy GM-PROJECTS
Ref.No	BAS / K / Engg / 5064/2000	Company:	BHEL-PSSR, CHENNAI
Date:	28.11.2000	Fax No:	044 - 4323757
Ref:	Your Fax message ref:		

Subject: 1 X 16 MW STG

Dear Sir,

WHILE THE SET IS OPERATED AT HIGHER LOADS, THE FOLLOWING PROBLEMS ARE OBSERVED.

1. HP WHEEL CHAMBER PRESSURE:

AT 80 TPH INLET STEAM FLOW TO TURBINE, THE HP WHEEL CHAMBER PRESSURE WAS FOUND TO BE GOING UP TO 43 KG/CM² AS AGAINST THE DESIGNED PRESSURE OF 35 KG/CM². THIS WAS OBSERVED ON 27.11.2000. WE ARE FORCED TO REDUCE THE LOAD AND THE SET IS OPERATED AT 12-13 MW ONLY.

2. LOADING TO 16 MW:

AT 80 TPH INLET STEAM FLOW AND WITH BOTH EXTRACTION FLOWS BELOW THE DESIGNED VALUES, THE LOAD ON TG SET IS NOT GOING BEYOND 13.5 MW.

WE ARE ENCLOSING THE LOG SHEETS OF 27.11.2000 FOR YOUR READY REFERENCE.

PLEASE ARRANGE TO DEPUTE YOUR SERVICE /COMMISSIONING ENGINEERS TO SITE IMMEDIATELY TO STUDY THE PROBLEM AND TO RECTIFY THE SAME.

Thanking You,

Yours Faithfully,
For Bannari Amman Sugars Ltd.,

S. Tharaman
28/11
Dy. General Manager - Tech.

Copy to: Sr. Vice President, Unit-II

Dy. General Manager - Purchase.

Mr. P N Reddy, GM (CM), BHEL, HYD (FAX 040-3020215)

Mr. Thiruveadam, AGM-COMMISSIONING, BHEL-PSSR. (FAX 044-4323757)

Mr. Ashok Varma, Dy GM- PPE, BHEL-HYD (FAX 040-3021930)

Mr. PN Krishna, Site Incharge, BHEL-PSSR

Bow
28/11