



**CLEAN DEVELOPMENT MECHANISM
PROJECT DESIGN DOCUMENT FORM (CDM-PDD)
Version 03 - in effect as of: 28 July 2006**

CONTENTS

- A. General description of project activity
- B. Application of a baseline and monitoring methodology
- C. Duration of the project activity / crediting period
- D. Environmental impacts
- E. Stakeholders' comments

Annexes

- Annex 1: Contact information on participants in the project activity
- Annex 2: Information regarding public funding
- Annex 3: Baseline information
- Annex 4: Monitoring plan
- Annex 5: Stakeholder Consultation
- Annex 6: Capacity tests
- Annex 7: Request for clarification modification
- Annex 8: Fuel price comparison and NPV calculations
- Annex 9: Environmental Impact Assessment

**SECTION A. General description of project activity****A.1 Title of the project activity:**

Fuel Switching Project of the Aqaba Thermal Power Station (ATPS)

PDD Version Number **65**

~~18th February~~ **August**, 2008

A.2. Description of the project activity:

The Fuel Switching Project of the Aqaba Thermal Power Station (hereafter, the “Project”) developed by Central Electricity Generating Company, CEGCO (hereafter referred to as the “Project Developer”) is a project to switch from oil to gas at the Aqaba Thermal Power Station (ATPS) in Aqaba, Jordan (hereafter referred to as the “Host Country”).

CEGCO was created in 1998, following the governmental decision to restructure the power sector towards privatization by unbundling of the National Electric Power Company (NEPCO) into 3 companies for the generation, transmission, and distribution of electricity in Jordan.

ATPS is a 650 MW power station comprised of five 130 MW units (each unit is made up of 1 boiler, 1 turbine, and 1 generator). ATPS is the largest power plant in Jordan. The fuel switch is from Heavy Fuel Oil (HFO) to Natural Gas (NG), and the capacity of the plant is unchanged as a result of the fuel switch. The modifications necessitated by the fuel switch are to boiler components, and constitute: Addition of NG burners; testing of boilers; and fuel delivery system only. The modified units were synchronised with the national grid between August '03 and April '04.

The project activity reduces CO₂ emissions by switching from a more carbon-intensive baseline fuel (HFO) to a less carbon-intensive project fuel (NG). As per ACM0011, the annual emission reductions are calculated as the amount of net electricity produced annually in the project, capped at the historic level (4,695,800 MWh/yr) and multiplied by the difference in emission factors of electricity production in the project, compared to historically. The Project is estimated to reduce an average annual amount of 397,163 tCO₂e/year over a 10-year crediting period.

ATPS initiated this fuel switch because of the plant's negative environmental impacts, which are mostly gaseous and a result of HFO combustion for electrical power generation, and because of the Jordan's ratification of the Kyoto Protocol and potential CDM benefits, which were considered from the beginning of the project, to make it financially viable (despite unfavourable relative fuel prices). The fact that ATPS has converted to a cleaner-burning fuel, from HFO to NG, has resulted in significantly reduced pollution, which is particularly important in this region, due to ATPS's proximity to a populated tourist destination (the city of Aqaba to the north), and the Saudi Arabian border to the south.

The fuel switch will benefit the environment, and contribute to sustainable development as follows:

- Reduction of CO₂, SO₂, NO_x, and suspended particulate matter with their associated aromas;



CDM – Executive Board

page 3

- Reduction of odour nuisance from H₂S, since high sulphur content HFO is substituted by NG;
- Support of the local economy, which is dominated by tourism and therefore benefits greatly from reduced pollution;
- Elimination of visual pollution, since smokestack output is no longer coloured;
- Acts as a clean technology demonstration project;
- Reduction of shipping/trucking of HFO, with reduction of related traffic and pollution (NG will be imported from Egypt via a submarine pipeline in the Gulf of Aqaba);
- Reduction of GHG emissions, and diversification of Jordan's electricity production with a leaning towards "cleaner" power.

A.3. Project participants:

Name of party involved (*) (host) indicates a host party)	Private and/or public entity(ies) Project participants (*) (as applicable)	Kindly indicate if the party involved wishes to be considered as project participant (Yes/No)
The Hashemite Kingdom of Jordan (host)	Central Electricity Generation Company (CEGCO)	No
United Kingdom of Great Britain and Northern Ireland	EcoSecurities Group Plc	No

(*) In accordance with the CDM modalities and procedures, at the time of making the CDM-PDD public at the stage of validation, a Party involved may or may not have provided its approval. At the time requesting registration, the approval by the Party(ies) involved is required.

A.4. Technical description of the project activity:**A.4.1. Location of the project activity:**

Aqaba Thermal Power Station (ATPS), Aqaba, the Hashemite Kingdom of Jordan.

A.4.1.1. Host Party(ies):

The Hashemite Kingdom of Jordan (the "Host Country")

A.4.1.2. Region/State/Province etc.:

Aqaba Special Economic Zone Authority (ASEZA)

A.4.1.3. City/Town/Community etc:



Approximately 16 kms south of the resort/port city of Aqaba, in an unpopulated zone, though within the administrative jurisdiction of the city of Aqaba.

A.4.1.4. Detail of physical location, including information allowing the unique identification of this project activity (maximum one page):

Aqaba Thermal Power Station (ATPS):

GPS coordinates 29° 22' 42.59'' North and 34° 58' 30.10'' East;
Approximately 35m above sea level;
16 km South of the town of Aqaba, Jordan; and
2.5 km North of the Jordan-Saudi Arabia border (on the Gulf of Aqaba).

A.4.2. Category(ies) of project activity:

According to Annex A of the Kyoto Protocol, this project fits in Sectoral Category 1, Energy industries (renewable - / non-renewable sources)

A.4.3. Technology to be employed by the project activity:

ATPS is a thermal type power station with a total capacity of 650 MW consisting of 5 discrete units (5 boilers, 5 turbines, and 5 generators in total) each with a capacity of 130 MW. Units 1 and 2 have been in service since 1986, and Units 3, 4, and 5 have been in service since 1998. There is a small hydro component, whereby cooling water is pumped up from the Gulf of Aqaba, used to condense boiler steam, and allowed to return to the Gulf while turning 2 turbines (the power generated is approximately 60% of that consumed in the pumps, the balance coming from the plant itself).

The project involves the conversion of the five ATPS boiler units from HFO firing to dual NG/HFO firing. Following the fuel switch, NG is the primary fuel, and HFO is the standby fuel, used in the event of NG supply shortages. Prior to conversion to dual firing, the 5 units ran on HFO Type #6 (with sulphur content of approximately 3.6%). All 5 units implement tandem compound 2-cylinder steam-condensing turbines, and are cooled by seawater. The boilers are tangentially fired, with sliding pressure operation. Since conversion, the five units have been operating predominantly on NG (the base fuel)¹ – see “Table 1” below (as compiled from CEGCO Annual Reports '03 – '05). HFO is the standby fuel and strategic reserve.

Table 1: HFO and NG consumption at ATPS – note the pronounced shift towards NG as the primary fuel

2003		2004		2005	
HFO (t)	NG (mmBTU)	HFO (t)	NG (mmBTU)	HFO (t)	NG (mmBTU)
708,997	8,698,571	135,478	38,843,331	33,621	47,822,176

¹ 2005 CEGCO Annual Report, Power Plants Fuel Consumption in 2005, Table (5), p.21



Prior to the fuel switch, the heat within the boilers was generated by the combustion of HFO. Following the fuel switch, NG is combusted to generate the heat that is used to create the steam. Therefore, the only modifications to the plant are modifications within the fuel delivery system, control systems and the burners. The fuel switch technology adopted and installed at ATPS is proven and tested, though not in Jordan. It is essentially a small modification in a complex fossil fuel burning power plant.

The synchronisation of the boilers, once converted to NG firing, was performed progressively between August 2003 and April 2004, according to the following schedule²:

- Unit 3 – 14/08/03
- Unit 4 – 15/09/03
- Unit 5 – 16/10/03
- Unit 1 – 16/02/04
- Unit 2 – 22/04/04

The conversion to dual firing includes:

- The design, supply, installation, commissioning, and testing of NG pipelines from the station boundary to the burners of the 5 boilers, including pressure reduction stations for the pipeline-supplied NG, gas temperature adjustment stations, gas quality analysers, and control units.
- Testing of boilers' maximum continuous capacity at design operating ratings (pressure and temperature), and efficiency.
- Since the boilers themselves were initially designed to accept HFO only, the fuel delivery stage within the boilers had to be modified. This means that the burners and their auxiliary hardware (pipes/valves) were changed to accommodate both types of fuels. No change to the boilers was necessary, as their geometrical design is suitable for burning HFO and NG.

The fuel switch did not require any modifications to:

- Boilers (except burners and their auxiliaries)
- Turbines
- Generators
- Electricity distribution systems

The fuel switch does not affect the total capacity or the maximum electricity generation capacity of ATPS. Power output (theoretical and actual) of the plant remains unchanged at 650 MW, however there has been a slight reduction in efficiency with NG use as specified in B.4.

In the context of the fuel switch that was performed at ATPS, the technology that was implemented was and remains cutting edge. CEGCO and ATPS are satisfied with the fuel switch and are not considering a


² 2005 folding brochure: The Hashemite Kingdom of Jordan/CEGCO/Aqaba Thermal Power Station - Summarized Description of Aqaba Thermal Power Station, "Natural Gas Conversion Project" section, inside, middle page



move to more advanced technology in the future, or indeed during the lifetime of the power station, because what they have remains state-of-the-art. The additions/modifications within the CDM project boundary were only regarding NG delivery and the fuel burners, and as such lack real potential for further improvement given that these are relatively straightforward and unsophisticated.

The technical set-up of ATPS is illustrated on figure A.4.3.1 below (all 5 units are of the same general arrangement):

Figure A.4.3.1: ATPS Schematic Cycle Diagram (for one unit)



**Table 2:** Main technical parameters of ATPS

	Before Fuel Switch	After Fuel Switch
Capacity (MW)	5 x 130 = 650	Same
Type of Turbines Units I & II	Franco Tosi TVW 2OR/2 130 MW	Same
Type of Turbines Units III, IV, & V	ABB PGL DKY2-2063 130 MW	Same
Type of Generator Turbines Unit I & II	Ercole Marelli SGTHC-244402 160 MVA/15 KV	Same
Type of Generator Turbines Unit III, IV, & V	ABB PGL WX212-092LLT 160 MVA/15 KV	Same
Type/numbers of burners	20 HFO burners	20 HFO burners + 20 NG burners
HFO fuel tank capacity	7 x 37,000 tons	2 x 37,000 tons (strategic reserve)

A.4.4 Estimated amount of emission reductions over the chosen crediting period:

The project activity reduces CO₂ emissions by switching from a more carbon-intensive baseline fuel (HFO) to a less carbon-intensive project fuel (NG). The estimated emission reductions during the 10-year crediting period are shown in the table below:

Table 3: Estimated emissions reductions from the project

Year	Annual estimation of emission reductions (tCO ₂ e)
2008	431,698
2009	431,698
2010	431,698
2011	431,698
2012	431,698
2013	431,698
2014	431,698
2015	431,698
2016	259,019
2017	259,019
Total estimated reductions (tCO₂e)	3,971,626
Total number of crediting years	10
Annual average of estimated reductions over the crediting period (tCO₂e)	397,163



A.4.5. Public funding of the project activity:

The project did not and does not receive any public funding from Parties included in Annex I of the UNFCCC.



**SECTION B. Application of a baseline and monitoring methodology****B.1. Title and reference of the approved baseline and monitoring methodology applied to the project activity:**

The project uses approved methodology ACM0011 (“Consolidated baseline methodology for fuel switching from coal and/or petroleum fuels to natural gas in existing power plants for electricity generation”), Version 01, approved at EB 32.

For determination of a baseline scenario and additionality, ACM0011 refers to the “Combined tool to identify the baseline scenario and demonstrate additionality”, Version 02.1, approved at EB 28.

For further demonstration of additionality, ACM0011 refers to the “Tool for the demonstration and assessment of additionality”, Version 03, approved at EB 29.

B.2 Justification of the choice of the methodology and why it is applicable to the project activity:

ACM0011 is applicable to project activities that switch fuel from petroleum fuels to NG in an existing power plant for electricity generation. This project meets all the applicability criteria as stated in the methodology:

- The PAPP either supplies electricity to the electricity grid or to a captive consumer³;
 - ATPS supplies electricity to the national Jordanian power grid. All power plants in the system are dispatched by a dispatch centre.
- Prior to the implementation of the project activity, only petroleum fuels (but not NG) were used in the PAPP to generate electricity;
 - Before the fuel switch, no NG was used in the PAPP. In addition, before the fuel switch, no NG equipment, and no gas supply infrastructure was in place at ATPS to utilize NG for electricity production.
- Petroleum fuel is available in the country/region for electricity generation;
 - Though Jordan does not have any natural oil resources, HFO is available in the country. HFO can either be imported via the port of Aqaba, but more importantly, Jordan produces HFO in its Zarqa Refinery (350 kms to the North) from imported crude oil, which is abundantly available in the region.
- Regulations/laws and programs do not restrain the facility from using the fossil fuels used prior to implementing the project activity, and do not require the use of NG or a specified fuel to generate electricity;

³ The electricity grid is an electricity supply system to which many consumers and many power plants are connected, as defined in ACM0002. The power plants connected to the electricity grid are dispatched by a dispatch center.



- In Jordan, there are neither laws/regulations restricting ATPS from using HFO for electricity production, nor any laws/regulations forcing them to use NG.
- The electricity grid to which the PAPP generated electricity is sold, is not restrained by laws/regulations to purchase electricity generated from different type of fuels, i.e. the electricity grid is not prohibited from purchasing electricity generated using a higher GHG intensity fuel during the crediting period of the project activity.
 - There are no laws/regulations in place restricting the grid from buying electricity produced from HFO at ATPS in Jordan.
- The project activity does not involve major retrofits/modifications of the power plant other than the fuel switch, for instance, the removal of existing technology and installation of new technology, such as new gas turbines, new combined cycle gas power generation etc.;
 - All major installations for electricity production (boilers, turbines, generators etc.) have not been changed, removed, or modified due to the fuel switch. Only small modifications directly necessary for the fuel switch (burners, gas supply infrastructure etc.) have been made (see section A.4.3).
- The project activity does not result in a significant change in the capacity, i.e. not more than +/-5% of the installed capacity before the implementation of the project activity;
 - The installed capacity of ATPS does not change due to the fuel switch. The turbines and generators are not affected by the fuel switch. The designed capacity of each unit therefore remains at 130 MW, and the total capacity is still 650 MW.
The fuel switch only elicits effects on the steam generating capacity of the boilers, which determines the theoretical capacity of the plant.
The capacity of the boilers was tested before and after the modifications for the fuel switch were implemented. These tests were performed by Alstom in 2003 and 2004.
The results, as demonstrated in the table below, show that the average superheater steam flow at maximum continuous running for all 5 units changes by a maximum of 2.01%

5 Units' steam flow before boiler modifications, running on HFO (t/h)	416.358	Source: Alstom Boiler Tests results for ATPS Units 1-5, 2003 – 2004.
5 Units' steam flow after boiler modifications, running on NG (t/h)	424.746	
Change in maximum steam output	-2.01%	

It is therefore clearly demonstrated that the implementation of the fuel switch does not result in a significant change of ATPS' installed capacity. Please see Annex 6 for the test results for each unit.

- The project activity does not result in an increase of the lifetime of the PAPP during the crediting period. If the lifetime of the PAPP is increased due to the project activity, the crediting period shall be limited to the estimated remaining lifetime of the power plant, i.e. the time when the existing power plant would have needed to be replaced in the absence of the project activity;
 - Seeing as the plant lifetime is determined by the boiler lifetime, and the boilers remain unchanged, the plant lifetime remains unchanged. The designed lifetime of the boilers is 30



years, and therefore the lifetime of units 1 and 2 is until 2016, and for units 3, 4, and 5, until 2028⁴.

Units	Start of operation	Designed lifetime	End of designed lifetime
1 & 2 (Stage 1)	March & July, 1986	30 yrs	2016
3, 4, & 5 (Stage 2)	April, July, & December, 1998	30 yrs	2028

The 10-year crediting period begins in 2008, and therefore ends in 2018. For units 1 and 2, emission reductions will only be claimed until the end of the designed lifetime of the respective boilers. The emission reduction estimates in the PDD are adapted accordingly. For simplification, the total amount of emission reductions estimations in the PDD are calculated by multiplying the total emission reductions by 3/5 (the remaining 3 units of the 5 original units) after 2016, since all units have the same capacity.

- This methodology is only applicable if the most plausible baseline scenario is the continuation of the use of high carbon intensive fuels like coal and/or petroleum fuels for electricity generation in the PAPP.
 - The most plausible baseline scenario, as demonstrated in B.4, is the continuation of HFO use as fuel.

The project is not a greenfield power plant, does not involve cogeneration, and is not an energy efficiency project.

The project therefore meets all applicability criteria as set out in the methodology.


⁴ Merz and McClellan Consulting Engineers: Aqaba Thermal Power Station Stage II Units 3 and 4 Environmental Impact Assessment, Volume I, October 1995, Section 6, p.1

**B.3. Description of the sources and gases included in the project boundary**

According to ACM0011 the project boundary encompasses the PAPP. Emissions sources and gases are listed in Table B.3.1 and the project boundary is described in Figure B.3.2.

Table B.3.1: Emissions sources included in or excluded from the project boundary

	Source	Gas	Included?	Justification/Explanation
Baseline	Emissions due to combustion of the baseline fuel (petroleum fuels) for electricity production in the PAPP	CO ₂	Yes	Main emission source
		CH ₄	No	Minor source
		N ₂ O	No	Minor source
Project Activity	Emissions due to combustion of natural gas for electricity production in the PAPP	CO ₂	Yes	Main emission source
		CH ₄	No	Minor source
		N ₂ O	No	Minor source
	Emissions due to use of energy (auxiliary fuel, purchased electricity etc.) for the operation of the PAPP	CO ₂	Yes	Main emission source
		CH ₄	No	Minor source
		N ₂ O	No	Minor source

Figure B.3.2: Project boundary

**B.4. Description of how the baseline scenario is identified and description of the identified baseline scenario:**

According to the latest version of ACM0011, the most plausible baseline scenario is identified through the application of the following steps:

*STEP 1: Identification of alternative scenarios**Step 1a. Identify all realistic and credible alternatives to the project activity:*

For the purpose of identifying relevant alternative scenarios, technologies and practices used for power generation in Jordan have been analysed. For an overview of all electricity production practices, please refer to the common practice analysis in section B.5.

Outcome of Step 1a: List of all plausible alternative scenarios to the project activity

- Alternative 1: The proposed project activity undertaken without being registered as a CDM project activity
- Alternative 2: Power generation using HFO, but technology measures other than what were used at ATPS before the fuel switch that could reduce the emissions intensity of electricity generation
- Alternative 3: Power generation using energy sources other than that used in the project activity
- Alternative 4: Power generation using HFO at ATPS i.e. the current practice before the fuel switch
- Alternative 5: The “proposed project activity undertaken without being registered as a CDM project activity” undertaken at a later point in time

Step 1b. Consistency with applicable laws and regulations:

All alternatives are in line with all mandatory applicable legal and regulatory requirements of Jordan. In particular, no laws/regulations are in place restricting ATPS from using HFO for electricity production, and there are no laws/regulations forcing them to use NG in Jordan.

Outcome of Step 1b. List of alternative scenarios to the project activity that are in compliance with mandatory legislation and regulations taking into account enforcement in the region or country and EB decisions on national and/or sectoral policies and regulations.

- Alternative 1: The proposed project activity undertaken without being registered as a CDM project activity
- Alternative 2: Power generation using HFO, but technology measures other than what were used at ATPS before the fuel switch that could reduce the emissions intensity of electricity generation
- Alternative 3: Power generation using energy sources other than that used in the project activity
- Alternative 4: Power generation using HFO at ATPS i.e. the current practice before the fuel switch
- Alternative 5: The “proposed project activity undertaken without being registered as a CDM project activity” undertaken at a later point in time

*STEP 2: Eliminate alternatives that face prohibitive barriers:*

In order to eliminate alternatives that face prohibitive barriers “Step 2 – Barrier analysis” of the “Combined tool for identification of baseline scenario and demonstration of additionality Version 02.1” is applied:

*Sub-step 2a. Identify barriers that would prevent the implementation of alternative scenarios:***Investment barriers:****1. Barriers to investment in efficiency improvement measures at ATPS:**

The efficiency of ATPS before the fuel switch was 37.44%⁵, which is comparable to the efficiencies of similar plants in industrialized countries⁶. Investments in technology which would increase efficiency, and thus reduce the emission intensity of electricity generation are expensive to implement, and would have only a limited effect on greenhouse gas emission intensity, given the already high plant efficiency.

2. Barriers due to fuel prices:

Jordan has no significant oil resources of its own, and must rely on imported oil for all of its needs (approximately 3.8 million tonnes in 2001 were imported from Iraq⁷). Prior to the Gulf War in 2003, Jordan was receiving supplies of crude oil from Iraq - \$300,000,000 worth per year for free, and the balance at half of the world market price⁸. This made power stations running on HFO highly competitive, and there was therefore no economic incentive to switch to NG.

Because of the war, these preferential terms were no longer available, and Jordan was forced to import oil at world market prices. From that point, Kuwait and Saudi Arabia have been the main suppliers to Jordan, and as refinery products are still being supplied to the end consumers at subsidised prices, this is a heavy burden on Jordan's national budget⁹.

Jordan has one refinery, at Zarqa, with an approximate capacity of 100,000 bbl/d. The facility is in need of major upgrades, and its owner, the Jordan Petroleum Refining Corporation (JPRC) is studying its options. The facility was designed to create a product mix skewed toward black (or “heavy”) products, such as High Sulphur content HFO and asphalt, to make best use of the cheap Iraqi oil¹⁰.

⁵ Monthly average of “sent out” power efficiencies (bottom of 10th column), from 2002 CEGCO Technical Planning Department/Power Plant Directorate Annual Report, ATPS section, table p.88

⁶ <http://www.abb.co.uk/cawp/seitp202/f95b7920b6f64682c1256f8d0055b672.aspx> or <http://www.e8.org/index.jsp?numPage=138>

⁷ Master Plan for the Energy Sector in Jordan, Executive Summary, Transborder and Nexant, Feb. 2002, p.5

⁸ <http://arabic.peopledaily.com.cn/31659/2561697.html>

⁹ GTZ: Producing Electricity from Renewable Electricity Sources: Energy Sector Framework in 15 Countries in Asia, Africa and Latin America, Eschborn, 2002 p. 116 (<http://www.gtz.de/de/dokumente/en-windenergy-jordan-study-2002.pdf>)

¹⁰ Master Plan for the Energy Sector in Jordan, Executive Summary, Transborder and Nexant, Feb. 2002, p.6



CDM – Executive Board

page 15

At the time of the decision to perform the fuel switch in 2002, and when the project was actually implemented in 2003, HFO prices were lower than NG prices, and this was projected to continue. The “Master Plan for the Energy Sector of Jordan, Interim Report”, which was written in May 2001, and presented to the “Arab Bank Centre for Scientific Research” shortly thereafter, by Transborder and Nexant, predicted fuel prices, including those for HS (high sulphur content) Fuel Oil for Jordan. These price predictions were determined using 2 different methods (“Mediterranean Export Pricing” and “European Netback Pricing”) to yield results for HS HFO delivered to Aqaba. Though the numbers vary slightly from one method to the next (European Netback Prices are approximately \$20/t less throughout the projection), the trend of HS HFO prices is clear – they decline steadily into the future, through 2020, and this can be seen in the tables below:

Table B.4.1: Aqaba Crude and Product Prices (Med Export Pricing) from “Appendix D” of “Master Plan for the Energy Sector of Jordan”, by Transborder and Nexant, as presented to the “Arab Centre for Scientific Research”, in May 2001.

Aqaba Crude and Product Prices (Based upon Med Export Pricing). All Prices in US \$ / Tonne (2001)

Export from Med	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
Arab Light	196	165	147	142	138	136	135	133	132	131	130	128	127	126	125	123	122	121	120	118
LPG	345	311	290	284	282	276	274	273	272	269	267	264	262	259	257	254	251	249	246	244
Premium Gasoline	319	287	268	262	259	257	255	254	253	251	249	247	245	242	240	238	236	234	231	229
Regular Gasoline	293	260	241	236	233	230	228	227	226	224	222	220	218	216	214	212	210	208	206	204
ATF/Kerosene	294	262	243	238	236	233	231	230	229	227	225	223	221	219	217	215	213	211	209	207
LS Diesel	287	256	238	232	229	226	224	223	222	220	218	216	214	212	210	208	207	205	203	201
LS Fuel Oil	176	151	136	128	121	117	115	113	112	111	110	109	108	107	106	105	104	104	104	103
HS Fuel Oil	146	121	106	98	91	87	85	83	82	81	80	80	79	78	77	76	75	74	74	73
Asphalt	139	115	101	93	87	82	81	79	78	77	76	76	75	74	73	72	71	71	70	69
Sulphur	37	37	37	37	37	37	37	37	37	37	37	37	37	37	37	37	37	37	37	37

Table B.4.2: Aqaba Crude and Product Prices (Europe Netback Pricing) from “Appendix D” of “Master Plan for the Energy Sector of Jordan”, by Transborder and Nexant, as presented to the “Arab Centre for Scientific Research”, in May 2001.

Aqaba Crude and Product Prices (Based upon Europe Netback Pricing – Import Parity). All Prices in US \$ / Tonne (2001)

Med Netback	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
Arab Light	196	165	147	142	138	136	135	133	132	131	130	128	127	126	125	123	122	121	120	118
LPG	345	311	290	284	282	276	274	273	272	269	267	264	262	259	257	254	251	249	246	244
Premium Gasoline	298	266	247	241	238	236	234	233	232	230	228	226	224	221	219	217	215	213	210	208
Regular Gasoline	272	239	220	215	212	209	207	206	205	203	201	199	197	195	193	191	189	187	185	183
ATF/Kerosene	273	241	222	217	215	212	210	209	208	206	204	202	200	198	196	194	192	190	188	186
LS Diesel	266	235	217	211	208	205	203	202	201	199	197	195	193	191	189	187	186	184	182	180
LS Fuel Oil	155	130	115	107	100	96	94	92	91	90	89	89	88	87	86	85	84	83	83	82
HS Fuel Oil	125	100	85	77	70	66	64	62	61	60	59	58	57	56	55	54	53	53	53	52
Asphalt	119	95	81	73	67	62	61	59	58	57	56	56	55	54	53	52	52	51	50	49
Sulphur	37	37	37	37	37	37	37	37	37	37	37	37	37	37	37	37	37	37	37	37

The table below shows the average predicted HFO prices calculated from table B.4.1 and B.4.2 above

**Table B.4.3:** Average¹¹ predicted price (through 2020) of High Sulphur content Heavy Fuel Oil for Jordan¹² (US \$/Tonne)

2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
135.5	110.5	95.5	87.5	80.5	76.5	74.5	72.5	71.5	70.5	69.5	69.5	68.5	67.5	66.5	65.5	64.5	63.5	63.5	62.5

The arrival of the Iraq Invasion of March 2003 caused major disruptions to Jordan's energy supply situation and rendered these price predictions obsolete. The export of free and subsidized HFO from Iraq to Jordan was drastically reduced, and eventually cut off. The country had to seek alternative sources of supply, with Kuwait and Saudi Arabia emerging as Jordan's main oil suppliers. Press reports¹³ indicate that at least some of this oil was sold at discounted prices through the end of 2004, and that Jordan paid full market prices in 2005¹⁴. In effect, and due to global happenings which were beyond any Jordanian influence, the reality was that HFO prices increased (contrary to pre-2003 predictions).

This in no way discounts the fact that CEGCO was committed to paying more for NG as a fuel for ATPS, and decided to go ahead with the project in 2001 and 2002, when none of these future events could be foreseen. The decision was motivated by the expected environmental and social benefits of the project (reduced local air pollution from burning gas rather than HFO, and a reduction of GHG emissions), and the potential of CDM revenues (see end of section B.5, paragraph "CDM consideration"). Today, the second largest power plant in Jordan, the Hussein Power Plant, still runs on HFO (see step 4 of section B.5).

Other barriers:

3. Non availability of other fuels:

ATPS has an installed capacity of 650 MW, and the electricity produced is crucial to a reliable electricity supply in Jordan. Therefore large quantities of fuel must be available and the supply must be dependable. Only HFO and NG are available in sufficient quantities at Aqaba, and these are the only fuels which can be utilised at the plant. As such, HFO and NG are the only feasible fuels for ATPS. Coal may also be available, but cannot be burned at ATPS without major technical modifications.

In the medium term, the main renewable energy resources (Hydro, Wind, Biomass, and Solar) are also not available in sufficient quantities to replace the 650 MW generation capacity.

¹¹ The calculated average is that of "European Netback Pricing" and "Mediterranean Export Pricing"

¹² Appendix D of "Master Plan for the Energy sector of Jordan" Interim Report, by Transborder and Nexant, May 2001, as presented to the "Arab Bank Centre for Scientific Research"

¹³ <http://www.aljazeera.net/NR/exeres/19015F66-A5F7-414E-AC69-CA2FC1F7B85A.htm> & <http://arabic.peopledaily.com.cn/31659/2561697.html>

¹⁴ Alexander's Oil & Gas Connections - News & Trends: Middle East, Volume 10, issue #18, 28/09/'05 (<http://www.gasandoil.com/goc/news/ntm53959.htm>)

*Sub-step 2b: Eliminate alternative scenarios which are prevented by the identified barriers*

<u>Alternative 1:</u> The proposed project activity undertaken without being registered as a CDM project activity	Hindered by barrier 2 (barrier due to fuel prices). → Nevertheless retained for further analysis, to exclude it definitively.
<u>Alternative 2:</u> Power generation using HFO, but technological measures other than those used at ATPS before the fuel switch that could reduce the emissions intensity of electricity generation	Prevented by barrier 1 (Barriers to investment in efficiency improvement measures at ATPS). This alternative is prevented by the disproportionate investment necessary to further increase the energy efficiency of the plant. Even if efficiency could be further increased it could only result in a limited amount of emission reductions compared to a fuel switch to NG. The installation of filters, and/or the use of fuel additives to reduce sulphur content, would reduce pollutants but would not reduce the greenhouse gas emission intensity of the plant. → Excluded from further analysis
<u>Alternative 3:</u> Power generation using energy sources other than that used in the project activity	This alternative is prevented by the non-availability of other fuels (barrier 3). → Excluded from further analysis
<u>Alternative 4:</u> Power generation using HFO, i.e. the current practice before the fuel switch	Not prevented by any of identified barriers. → Retained for further analysis
<u>Alternative 5:</u> The “proposed project activity undertaken without being registered as a CDM project activity” undertaken at a later point in time	The decision to perform the fuel switch at ATPS was made in 2002, and was implemented in 2003. As demonstrated in section B.4., the fuel price predictions at that time clearly illustrate that HFO was the most economically attractive fuel, and that HFO would be the most attractive fuel for the foreseeable future. In Step 3 below it is demonstrated that the implementation of the proposed project without CDM is not economically attractive. The basic economic parameters do not differ substantially over time: -The analysis of the fuel costs for electricity production (US\$/MWh) for HFO and NG show that NG is at no time cheaper than HFO in the analysis period (2003 - 2025) (see Table 8.1, in Annex 8) Consequently there would be no incentive to delay the fuel switch (i.e. to implement the proposed project without CDM, at a later point of time). -There is no reason to believe that the investment costs to perform the fuel switch at ATPS would decrease over time. Therefore barrier 2 hinders alternative 5 in the same way it prevents alternative 1.



	→ Hindered by barrier 2. The further analysis of alternative 1 also excludes alternative 5, as the basic economic parameters do not change over time.
--	--

Therefore only Alternative 1 (The proposed project activity undertaken without being registered as a CDM project activity), and Alternative 4 (Power generation using HFO, i.e. the current practice before the fuel switch) remain. These will be further analysed in Step 3, *Investment Analysis*.

STEP 3: Investment analysis

According to ACM0011, the “Combined tool to identify the baseline scenario and demonstrate additionality” should be applied to compare the economic attractiveness without revenues from CERs for the remaining alternatives.

The economic investment analysis shall use the net present value (NPV) analysis, and will include the parameters listed in Table B.4.4 below:



Table B.4.4: Economic parameters

<u>Parameter</u>	<u>Unit</u>	<u>Value applied</u> <u>(Alternative 1, stay on</u> <u>HFO)</u>	<u>Source</u>	<u>Value applied (Alternative 2,</u> <u>switch to NG)</u>	<u>Source</u>
Investment requirements;	US \$	0	N/A	Alstom/Mac contract: Total: US\$ 18,845,528.4 \$ * Unit 1: 3,215,598 Unit 2: 3,200,107 Unit 3: 3,127,544 Unit 4: 3,141,404 Unit 5: 3,169,940 NG Purif. Plant: 4,966,815 Other Sp. Parts: 693,177 Press. Red. St. total: US\$ 390,000 P.R.S. Sp. Parts: 8,552 # TOTAL: US \$ 21,828,990	Cost breakdown of fuel switch at ATPS; CEGCO 09/10/2005 (see Annex 8 for a detailed cost breakdown) * Letter of Award to Alstom/MAG from CEGCO's Chairman, dated 9/1/2002 # Letter from East Gas Company to CEGCO dated 21/12/2003¹⁵
A discount rate appropriate to the country and sector (use government bond rates, increased by a suitable risk premium to reflect private investment in fuel switching projects, as substantiated by an independent financial expert);	%	N/A	N/A	4.5% 2002 discount rate + 3.5% risk premium = 8%	Jordinvest Jordan Capital Markets Day Report 01/02/'07, Jordan Macro- economic Indicators table, p.16 & http://www.ssiu.gov.jo/

¹⁵ Please note that the cost for the gas pressure reduction station was not considered at time of decision, as the need for such a station was not known in 2002 when CEGCO still assumed that the gas would be delivered to ATPS at a suitable pressure. We have excluded the cost of the NG pressure reduction station in the NPV analysis for conservativeness, as including it will only increase the NPV of the NG scenario.



					Investment/Investment Strategy/InvestmentStrategy2/tabid/89/locale/en-US/Default.aspx
Current price and expected future price (variable costs) of each fuel. Estimates of the future prices have to be substantiated by a public and official publication from a governmental body or an intergovernmental institution. If such publications are not available, highlight the key logical assumptions and quantitative factors for determining the development of costs of each fuel (e.g. international market price, transport costs, level of taxes/subsidies, local price). State clearly which assumptions and factors have significant uncertainty associated with them, and include these uncertainties in the sensitivity analysis in "Step 3 – investment analysis";	US \$/MWh	Variable	Appendix D of the “Master “Plan for the Energy Sector of Jordan, Interim Report”, May 2001, by Transborder and Nexant. Note that an average of the 2 HS HFO price predictions methods is used (as per table B.4.3).	\$2.15 2.4 /MMBTU= \$19.44 21.70 / MWh	2006 CEGCO Annual Report, p.27 The expected price of natural gas at the time of decision making was confidential. Using the only publicly available data, the most conservative real tariff from 2002-2006 (from the CEGCO 2006 Annual Report p.27) has been used. A letter from the MEMR confirming the confidentiality of the actual price paid, and the reasonableness of the price we have used in our NPV calculations



Operating costs for each fuel (especially handling/treatment costs for coal);	US \$/MWh	0	Included in fuel costs/MWh	0	Included in fuel costs/MWh
Lifetime of the project, equal to the remaining lifetime of the existing electricity generation facility;	Years	30	Merz and McLellan Consulting Engineers Aqaba Thermal Power Station Environmental Impact Assessment, Volume 1, Section 6, p.1, October 1995.	30	According to ACM0011, this is the lifetime of the power plant before the fuel switch.
Other operation and maintenance costs, e.g. slag and ash disposal, environmental pollution fees etc.	US \$	0	N/A	0	N/A
Residual value of the new equipment at the end of the lifetime of the project activity.	US \$	N/A	N/A	0	Assumption (see below)



Some further assumptions for NPV calculation are explained below:

- Residual value of the new equipment at the end of the lifetime of the project activity = 0:
 - Due to the long-term time horizon for the NPV calculations (24 years), it is assumed that the residual value in 2027 is 0. The new equipment is predominantly composed of gas pipelines, gas pressure and temperature adjustment stations, and the gas burners themselves. The value of the equipment will be as scrap and the exact value is difficult to quantify. Therefore it is assumed to be 0. If argued that this is “non-conservative”, it is further illustrated that the impact of the “zero scrap value” assumption on the outcome of the NPV is negligible. This is demonstrated below, in sensitivity analysis scenario 11 (10% of the total investment added to the total revenue in the last year of the NPV analysis).
- Expected future prices for NG: Gas price is fixed.
 - In 2006, CEGCO paid \$2.15/MMBTU of NG. The price is dependent on a confidential long-term agreement between the governments of Jordan and Egypt. Given world market trends, this price is likely to rise over time. As an increase in prices could not be substantiated by public and official documentation, a fixed price is assumed, taking the lowest gas price CEGCO has paid between 2004 and 2006 (i.e. \$2.15/MMBTU). Such an approach is conservative as it increases the economic attractiveness of the NG scenario.
- Efficiency of each element process for HFO and NG. This is included in fuel costs per produced MWh.
 - Due to the fuel switch, the efficiency of ATPS decreased by approximately 3.04%¹⁶. For the NPV calculations, fuel costs are included as cost/MWh produced. Efficiency losses are therefore factored into the NPV calculations, since efficiency losses mean that more fuel is required to produce the same amount of electricity.

Outcome of Step 3:

The results of the NPV analysis for Alternative 1 (“The proposed project activity undertaken without being registered as a CDM project activity”) [called NG scenario], and Alternative 4 (Power generation using HFO, i.e. the current practice before the fuel switch) [called HFO scenario] are shown below:

Net Present Value (\$)	Until end of designed lifetime (01/01/2028)
NG scenario	579,168,861 563,424,122
HFO scenario	737,698,942

The NPV analysis clearly illustrates that Alternative 1 (the NG scenario) is less economically attractive (i.e. has a lower NPV) when compared with Alternative 4 (the HFO scenario). A sensitivity analysis was performed to confirm these results. The table below summarises the parameters that were varied and their respective impacts on the relative NPVs of the two scenarios.

¹⁶ 2002 and 2005 CEGCO Technical Planning Department Power Plant Directorate Annual Reports: Efficiency 2002 37.44% (p. 88) and efficiency 2005 34.40% (p. 84).



Sensitivity Analysis (at end of plant lifetime 01/01/2028)
Net Present Value (\$) with % change

1	Investment costs -10%		
	NG scenario	580,913,817	0.301%
	HFO scenario	737,698,942	0.000%
2	Investment costs +10%		
	NG scenario	577,423,905	-0.301%
	HFO scenario	737,698,942	0.000%
3	Fuel Costs/MWh increase 10% (NG and HFO)		
	NG scenario	500,278,797	-13.621%
	HFO scenario	672,916,930	-8.782%
4	Fuel Costs/MWh decrease 10% (NG and HFO)		
	NG scenario	658,058,925	13.621%
	HFO scenario	802,480,954	8.782%
5	Fuel Costs/MWh increase 10% (NG only)		
	NG scenario	500,278,797	-13.621%
	HFO scenario	737,698,942	0.000%
6	Fuel Costs/MWh decrease 10% (NG only)		
	NG scenario	658,058,925	13.621%
	HFO scenario	737,698,942	0.000%
7	Fuel Costs/MWh increase 10% (HFO only)		
	NG scenario	579,168,861	0.000%
	HFO scenario	672,916,930	-8.782%
8	Fuel Costs/MWh decrease 10% (HFO only)		
	NG scenario	579,168,861	0.000%
	HFO scenario	802,480,954	8.782%



9	Fuel Cost/MWh decrease 10% NG and increase 10% HFO		
	NG scenario	658,058,925	13.621%
	HFO scenario	672,916,930	-8.782%

10	Fuel Cost/MWh increase 10% NG and decrease 10% HFO		
	NG scenario	500,278,797	-13.621%
	HFO scenario	802,480,954	8.782%

11	Residual Value 10% of total investment in 2027		
	NG scenario	579,444,039	0.048%
	HFO scenario	737,698,942	0.000%

The results of the sensitivity analysis show that the NPV for the NG scenario is always lower than the NPV for the HFO scenario, even in the most favourable scenario for the proposed project activity (Scenario 9: Decrease of NG fuel costs of 10%, and increase of HFO fuel costs of 10%).

The sensitivity analysis is therefore conclusive, and confirms the result of the investment comparison analysis. According to ACM0011 Version 1, the most financially attractive alternative scenario is considered as the baseline scenario (i.e. Alternative 4 (Power generation using HFO, i.e. the current practice before the fuel switch) is the baseline scenario for the proposed CDM project activity). This baseline scenario will be valid for the whole 10-year crediting period for units 3, 4, and 5. For units 1 and 2, it will be valid until 2016, which is the end of their designed lifetime, after which date no more emission reductions will be claimed for these 2 units (see section B.2).

**B.5. Description of how the anthropogenic emissions of GHG by sources are reduced below those that would have occurred in the absence of the registered CDM project activity (assessment and demonstration of additionality):**

The additionality of the project is assessed according to the latest version of the “Tool for the demonstration and assessment of additionality”, Version 03, approved at EB 29.

STEP 1: Identification of alternatives to the project activity consistent with current laws and regulations – please refer to section B.4, where this has already been done. Five alternatives were identified which are all consistent with mandatory laws and regulations.

STEP 2: Investment Analysis – please refer to section B.4 where the following steps were followed:

- Sub-step 2a. Determine appropriate analysis method.
 - An investment comparison analysis (option II) is used, according to ACM0011 procedure for baseline selection
- Sub-step 2b. Option II. Apply investment comparison analysis.
 - The financial indicator most suitable for the project is the Net Present Value (NPV), as required by ACM0011
- Sub-step 2c. Calculation and comparison of financial indicators (only applicable to options II and III)
 - The NPVs (without revenues from CERs) of both alternative scenarios have been calculated, with all the sources and assumptions clearly explained
- Sub-step 2d. Sensitivity Analysis (only applicable to options II and III)
 - A sensitivity analysis has been performed by variation of 10% of the key financial parameters of the project.

As a result of this 4-step investment analysis, it is demonstrated that Alternative 4 (Power generation using HFO, i.e. the current practice before the fuel switch) is the most economically attractive alternative.

STEP 3: Barrier Analysis – please refer to section B.4 where this has been performed. Three barriers were identified, and these prevented the implementation of all alternatives except one (Alternative 4 – continuation of the current practice). However, in order to illustrate quantitatively the impact of these barriers on the project activity, two alternatives were retained for investment analysis:

Alternative 1: The proposed project activity undertaken without being registered as a CDM project activity
Alternative 4: Power generation using HFO at ATPS, i.e. the current practice before the fuel switch

STEP 4: Common Practice Analysis.

Sub-step 4a - Analyze other activities similar to the proposed project activity.

As per ACM0011 requirements (Step 1a of the baseline selection procedure), the relevant geographical area considered for similar activities to the proposed project activity is the Host Country, Jordan. A region within Jordan is not selected because framework conditions are similar throughout the country. Furthermore, Jordan contains the required minimum of ten power generation facilities, none of which are registered under the CDM. At the time of the decision to make the fuel switch at ATPS, the Fuel Switching



Project of the Aqaba Thermal Power Station (ATPS) was the first and only one of its kind in Jordan (i.e. fuel switch project from HFO to NG at a thermal steam power station) – there are no activities similar to the project activity in the region, as demonstrated in Table B.5.1 below.

Table B.5.1: Power stations connected to the National Grid in Jordan.

Name	Energy source 2002 (time of decision for fuel switch to NG at ATPS)	Energy source 2005 (one year after fuel switch was performed)	Capacity (MW)	Source
ATPS	HFO	NG	650	CEGCO Annual Reports 2002 & 2005
Hussein	HFO	HFO	396	CEGCO Annual Reports 2002 & 2005
Rehab	Diesel	Diesel	60	CEGCO Annual Reports 2002 & 2005
Rehab/Combined cycle	Diesel	Diesel	297	CEGCO Annual Report 2005
Al-Risha	NG	NG	120	CEGCO Annual Reports 2002 & 2005
Marka	Diesel	Diesel	100	CEGCO Annual Reports 2002 & 2005
Amman South	Diesel	Diesel	60	CEGCO Annual Reports 2002 & 2005
Karak	Diesel	Diesel	24.5	CEGCO Annual Reports 2002 & 2005
Aqaba Central	Diesel	Diesel	10.5	CEGCO Annual Reports 2002 & 2005
Tafila	Diesel	Shut down	1.5	CEGCO Annual Reports 2002
Ma'an & Remote Villages	Diesel	Shut down	2	CEGCO Annual Reports 2002
Ibrahimiyyeh	Wind	Wind	0.3 (2002), 3.2 (2005)	CEGCO Annual Reports 2002 & 2005
Hofa	Wind	Wind	1.125	CEGCO Annual Reports 2002 & 2005
King Talal Dam	Hydro	Hydro	6	CEGCO Annual Reports 2002 & 2005
South Cement Factory	Diesel	Diesel	9	CEGCO Annual Report 2002 & oral communication with CEGCO
Refinery Co.	Diesel/HFO	Diesel/HFO	23.5	CEGCO Annual Report 2002 & oral communication with CEGCO



Arab Potash Co.	Diesel/HFO	Diesel/HFO	23	CEGCO Annual Report 2002 & oral communication with CEGCO
Fertilizer Co.	HFO	HFO	44	CEGCO Annual Report 2002 & oral communication with CEGCO
Indo Jordan Company	HFO	HFO	12	CEGCO Annual Report 2002 & oral communication with CEGCO
Jordan United Iron Industry Co.	Diesel	Diesel	26	CEGCO Annual Report 2002 & oral communication with CEGCO
Others (2002)	Diesel	Diesel	8.5	CEGCO Annual Report 2002 & oral communication with CEGCO
Samra Power Station	NG primary/Diesel secondary	NG	100	CEGCO Annual Report 2005
Jordan Bio Gas Company	Landfill gas	Bio Gas	1	CEGCO Annual Report 2005
Others (2005)	Diesel	Diesel	44	CEGCO Annual Report 2005

Note that in 2006, Rehab Power Plant completed its conversion from Simple Cycle to Combined Cycle along with a conversion to dual firing (NG and diesel). Clearly, this is a different technology and a different fuel switch, and cannot be compared to ATPS, and it was completed 3 years later.

Sub-step 4b - Discuss any similar options that are occurring.

In 2003 ATPS was the first and only power station in Jordan which had performed a fuel switch from HFO to NG, which shows that such switches were not common practice in the region during the period 2002 - 2005. Even today, with higher oil prices, the second largest power station in Jordan, the Hussein Thermal Power Station (HTPS), still runs on HFO (see Table B.5.1 above).

Furthermore, only three other power stations run on NG in Jordan, including two (the Rehab CCGT and the Samra power stations) that were built after the ATPS fuel switch. This suggests that:

- even for new plants, oil was the fuel of choice prior to 2002
- even today, NG is used almost exclusively in new plants (i.e. built after the change in fuel prices)

In conclusion, no other similar options were and are occurring in the region, and the project cannot be considered common practice.

*CDM consideration*

The CO₂ reduction potential by switching from HFO to NG, and the possible benefits due to CDM, were taken into consideration from the very beginning of the decision-making process for a potential fuel switch at ATPS.

The decision making process for the fuel switch and the CDM consideration are as follows:

- 1995: CEGCO reached an agreement with the e7 group to assess and improve the efficiency of the existing ATPS running on HFO. This occurred within the E7 Project 82 as “an initiative to reduce greenhouse gases”¹⁷. When the opportunity arose to perform a fuel switch to improve the air quality of the Aqaba region, the e7 group assessed the GHG reduction potentials of a fuel switch, and quantified the potential benefits from carbon revenue for CEGCO.
- 2001: CEGCO commissioned a Feasibility Study to assess the financial viability of a possible fuel switch. The results of this Feasibility Study showed that a fuel switch under current 2001 market conditions was not financially attractive¹⁸.
- At the end of 2001, Ontario Power Generation, on behalf of the e7 group, provided a study to CEGCO demonstrating the winning conditions under the CDM for a fuel switch at ATPS¹⁹. As a follow up, members of senior management of CEGCO attended a closed workshop organised by the e7 group on the CDM, in Paris, in December 2001. This followed a long-term relationship between CEGCO and the e7 group with the purpose of improving the power plant efficiency, and reducing environmental impacts (including the reduction of GHG emissions).
- As a result, the e7 group started developing a first draft PDD, which was delivered to CEGCO in May 2002.
- January 2002: CEGCO’s Board of Management made the decision to perform the fuel switch at ATPS, and awarded the contract to perform the technical modifications at ATPS to the executing company.
- February 2002: CEGCO informed the Environmental Protection Agency of their intention to perform a fuel switch at ATPS, highlighting not only the potential for the reduction of obvious pollutants (particularly SO₂ and H₂S emissions), but also the large CO₂ reduction potential of the fuel switch.
Possible benefits from emission reductions due to a fuel switch are also mentioned in the “Master Plan for the Energy Sector of Jordan”, published in February 2002²⁰.

¹⁷ See http://www.e8.org/upload/File/E7_Project_efficiencyemprovement_Report.pdf (p. 2)

¹⁸ Arthur D. Little: Cost Benefit Analysis of Converting Aqaba Power Plant to Gas, January 2001.

¹⁹ Ontario Power Generation: Winning Conditions for Electricity Projects under the Clean Development Mechanism – Recommendations by the e7 (November 2001), and communication between Ontario Power Generation and CEGCO about the CDM potential of a fuel switch at ATPS (27th December, 2001).

²⁰ Transborder and Nexant: Master Plan for the Energy Sector of Jordan, Executive Summary, February 2002, p.10



CEGCO proceeded to include the CDM in the conversion of ATPS from HFO to NG, but the CDM process was delayed until 2007 for numerous reasons:

- Jordan only ratified the Kyoto Protocol in 2003
- Even after ratification, non Annex I countries under the Kyoto Protocol have to fulfil certain responsibilities to be able to successfully host CDM projects. Most important among these is the formal set-up of a Designated National Authority (DNA), responsible for assessing the sustainable integrity of CDM projects in the host country. Only the DNA is authorised to issue the host country approval for CDM projects. The Jordanian DNA was eventually established in 2004 as part of the Ministry of Environment. In September 2005, the DNA issued the first provisional approvals for CDM projects in Jordan, including the ATPS fuel switch project²¹.
- Further delays in the development of the CDM project were a result of the non-availability of an applicable methodology (until EB32), and a lack of internal CDM capacity at CEGCO to develop a new methodology. In June 2007, at EB32, an applicable methodology (ACM0011) was approved by the EB²² and the completion of the final PDD commenced immediately.
- ATPS is the first project in Jordan applying for registration as a CDM project²³

In the conclusion of section B.5, the project has successfully passed all the steps of the “Tool for the demonstration and assessment of additionality”, and as such is additional.

²¹ Letter from Ministry of Environment to Minister of Planning, regarding the approval of several projects as CDM, 13/09/2005, Amman, Jordan.

²² See EB 32, Annex 5: http://cdm.unfccc.int/EB/032/eb32_repan05.pdf. 22 June 07

²³ See: <http://cdm.unfccc.int/>

**B.6 Emission reductions****B.6.1. Explanation of methodological choices:**

According to the ACM0011 Baseline emissions, Project Emissions and Leakage are calculated as follows:

Baseline emissions are calculated as:

$$BE_y = EL_{BL,y} \cdot EF_{elec,BL} \quad (1)$$

$BE_{elec,y}$ Baseline emissions due to the generation of electricity supplied to electricity grid in year y of the crediting period (tCO₂).

$EL_{BL,y}$ Electricity supplied to the electricity grid in year y of the crediting period, not exceeding the supply in absence of the project activity (MWh).

$EF_{elec,BL}$ Emission factor for the baseline source of electricity supplied to the captive consumer/electricity (tCO₂/MWh).

$$EL_{BL,y} = \begin{cases} EL_{PR,y} & \text{if } EL_{PR,y} < EL_{his} \\ EL_{his} & \text{if } EL_{PR,y} \geq EL_{his} \end{cases} \quad (2)$$

$EL_{PR,y}$ Total electricity supplied to the electricity grid by PAPP in the project case in year y of the crediting period (MWh).

EL_{his} The maximum historic annual amount of electricity over three most recent years prior to implementation of project activity

$$EF_{elec,BL} = \frac{44}{12} \cdot \frac{3.6}{1000} \cdot \frac{EF_{FF,BL}}{NCV_{FF,BL} \cdot \eta_{BL}} \quad (3)$$

$EF_{FF,BL}$ CO₂ emission factor for the petroleum fuel used in the PAPP prior to implementation of the project activity (tC/t).

$NCV_{FF,BL}$ Net calorific value of fossil fuel used in the PAPP prior to implementation of the project activity (TJ/t).

η_{BL} Efficiency of the PAPP prior to implementation of the project activity.



The baseline fuel is determined to be HFO, as Diesel was only used for maintenance/cleaning but not for regular electricity production²⁴.

The energy efficiency (η_{BL}) was measured by the project participant during operation. To set the baseline emission level, the 2002 figure was used. Efficiency was measured for all 5 units separately, and for the whole plant in total.

According to ACM0011, η_{BL} shall be fixed throughout the crediting period.

Project emissions are calculated as follows:

$$PE_y = PE_{NG,y} + PE_{aux,y} \quad (4)$$

$PE_{NG,y}$ Emissions due to the combustion of NG for the production of electricity in year y of the crediting period (in tCO₂).

$PE_{aux,y}$ Emission due to the use of energy (not NG or electricity) in year y of the crediting period (in tCO₂).

Emissions due to the combustion of NG for the production of electricity are calculated as:

$$PE_{NG,y} = \frac{44}{12} \cdot NG_y \cdot EF_{NG,y}$$

NG_y Total amount of NG used in the project power plant in year y of the crediting period (in t).

$EF_{NG,y}$ CO₂ emission factor of NG (tC/t).

Small amounts of other fossil fuels (ATPS may use small amounts of HFO and Diesel) and/or grid electricity may be used in the project activity to serve auxiliary and back-up loads

$$PE_{aux,y} = \frac{44}{12} \cdot \sum_i (FF_{aux,i,y} \cdot EF_i) + EL_{aux,grid,y} \cdot EF_{elec,y} \quad (6)$$

$FF_{aux,i,y}$ Total amount of fossil fuel i used in the project power plant to serve auxiliary and back-up loads in year y of the crediting period (mass or volume units).

EF_i CO₂ emission factor of fossil fuel i (tC/mass or volume unit)

$EL_{aux,grid,y}$ Electricity used in the project power plant to serve auxiliary and back-loads that is obtained from the grid, in any year y (MWh).

$EF_{elec,y}$ A conservative default value of 1.3 tCO₂/MWh is used.

²⁴ In 2002 only 909.5 cubic meters of Diesel was used at ATPS, compared to over 1 million tonnes of HFO (see 2002 CEGCO Annual Report p.23)

**Leakage:**

Leakage may result from fuel extraction, processing, transportation, and distribution of NG outside the project boundary (there is no liquefaction/re-gasification step as the NG comes directly from the field in gaseous form). According to ACM0011, the following leakage emission sources shall be considered:

- Fugitive CH₄ emissions associated with fuel extraction, processing, transportation, and distribution of NG used in the project plant, and fossil fuels used in the grid in the absence of the project activity.
- No LNG is used in the project power plant.

Thus, leakage emissions are calculated as follows:

$$LE_y = LE_{CH_4, y} \quad (7)$$

LE_y Leakage emissions during year y (tCO₂).

$LE_{CH_4, y}$ Leakage emissions due to fugitive upstream CH₄ emissions in year y (tCO₂).

Gas is supplied directly from Egypt to Jordan by pipeline. Therefore no Annex I countries are involved.

For the purpose of determining fugitive methane emissions associated with the production, transportation, and distribution of the fuels, the quantity of NG consumed in the project power plant should be multiplied by a methane emission factor for these upstream emissions, and subtract for all fuel types i which would be used in the absence of the project activity, the fuel quantities multiplied with respective methane emission factors, as follows:

$$LE_{CH_4, y} = \left[NG_y \cdot NCV_{NG, y} \cdot EF_{NG, upstream, CH_4} - \frac{EL_{BL, y}}{\eta_{BL}} \cdot NCV_{FF, y} \cdot EF_{FF, upstream, CH_4} \right] GWP_{CH_4} \quad (8)$$

$L_{CH_4, y}$ Leakage emissions due to upstream fugitive CH₄ emissions in year y (tCO₂).

NG_y Total amount of NG used in the PAPP in year y of the crediting period (t)

$NCV_{NG, y}$ Net calorific value of NG, referred to under the same physical conditions (pressure and temperature) as NG_y (TJ/t).

$EF_{NG, upstream, CH_4}$ Emission factor for upstream fugitive methane emissions from production, transportation, and distribution of NG (tCH₄/TJ).

$EL_{elec, BL, y}$ Electricity supplied to the electricity grid in year y of the crediting period, up to the level of baseline supply (MWh).

$\eta_{BL, y}$ Efficiency of the power plant in the baseline, as a function of the load factor of the PAPP in year y of the crediting period.

$NCV_{i, y}$ Net calorific value of fossil fuel i (TJ/t).

$EF_{i, upstream, CH_4}$ Emission factor for upstream fugitive methane, valid for the relevant commitment period

GWP_{CH_4} Global warming potential of methane, valid for the relevant commitment period.



As no reliable and accurate national data on fugitive CH₄ emissions²⁵ (associated with the production, transportation, and distribution of the fuels is available) is available, the default values provided in table 2 of ACM0011 Version 1 are used.

As the gas production, processing, and transmission system is of recent vintage, and built and operated to international standards, the US/Canada default value (160 tCH₄/PJ) is used.

The fuel that would be used in the absence of the project activity is HFO, and the emission factor of fugitive CH₄ upstream emissions from oil (4.1 tCH₄/PJ) will be used.

Emission reductions are therefore calculated as follows:

$$ER_y = BE_y - PE_y - LE_y \quad (10)$$

ER_y	Emission reduction during year y (tCO ₂ /yr)
BE_y	Baseline emission during year y (tCO ₂ /yr)
PE_y	Project emission during year y (tCO ₂ /yr)
LE_y	Leakage emission during year y (tCO ₂ /yr)

B.6.2. Data and parameters that are available at validation:

Data / Parameter:	EL _{his}			
Data unit:	MWh			
Description:	Electricity supplied to the electricity grid in the absence of the project activity.			
Source of data used:	Electricity meters at the project site.			
Value applied:	4,695,800			
Justification of the choice of data or description of measurement methods and procedures actually applied:	Electricity meters at the project site.			
	Year	2000	2001	2002
	ATPS (GWh sold)	3,933.2	4,022.6	4,695.8
	2005 CECGO Annual Report, p. 20			
Any comment:	Defined as the maximum historic annual electricity supplied to the grid over the three most recent years prior to implementation of project activity.			

Data / Parameter:	η_{BL}
Data unit:	%

²⁵ In particular, Jordan's first and last communication to the UNFCCC from 1997 did not include any information on pipelines, as there were none at this time.



Description:	Efficiency of the PAPP prior to the implementation of the project activity.
Source of data used:	Based on option I, as specified in ACM0011: (i) Measurement of efficiency of the PAPP;
Value applied:	37.44
Justification of the choice of data or description of measurement methods and procedures actually applied:	The energy efficiency (η_{BL}) was measured by the project participant during operation. To determine the baseline emission level, 2002 measurements are used. The efficiency was measured for all 5 units separately, and for the whole plant in total. The values for the whole plant are used to establish the baseline efficiency.
Any comment:	Source: Report # PE1R04_RP01, 2002 CEGCO Technical Planning Department, Annual Report, Power Plant Directorate, p. 88.

Data / Parameter:	$EF_{HFO,BL}$
Data unit:	tC/t
Description:	CO ₂ emission factor of the HFO used in the PAPP prior to the implementation of the project activity.
Source of data used:	As option a) (values provided by the fuel supplier in invoices) is not available, option b) as outlined in ACM0011 is used: Measurements by the project participant. The measurement is carried out in the Chemical section's Laboratory.
Value applied:	0.847
Justification of the choice of data, or description of measurement methods and procedures actually applied:	Measurements are undertaken in line with international standard ASTM-D-2382 in the Chemical section's accredited Laboratory. A full year (2002) of monthly data analyses is used to calculate the average value. The samples were taken from the HFO storage tanks at ATPS.
Any comment:	See calculation spreadsheet for detailed calculations

Data / Parameter:	$NCV_{HFO, BL}$
Data unit:	GJ/t
Description:	Net calorific value of HFO used in the PAPP prior to implementation of the project activity.
Source of data used:	As option a) (values provided by the fuel supplier in invoices) is not available, option b) as outlined in ACM0011 is used: Measurements by the project participant.



Value applied:	0.0402
Justification of the choice of data or description of measurement methods and procedures actually applied:	Measurements are undertaken in line with international standard ASTM-D-2382. The value is expressed in kcal/Kg in the report, and is then converted in GJ/t. A full year (2002) of monthly data analysis is used to calculate the average value. The samples were taken from the HFO storage tanks at ATPS.
Any comment:	For the above value, 12 consecutive monthly HFO Lab Analysis reports from 2002, from CEGCO's ATPS Chemical Laboratory, were used.

Data / Parameter:	$EF_{HFO,upstream,CH_4}$
Data unit:	tCH ₄ /TJ
Description:	Emission factor for upstream fugitive methane emissions from production of the HFO used in PAPP prior to project implementation.
Source of data used:	As no reliable and accurate national data on fugitive CH ₄ emissions associated with the production is available, the default value as provided in Table 2 of ACM0011 is used
Value applied:	4.1
Justification of the choice of data, or description of measurement methods and procedures actually applied :	According to ACM0011.
Any comment:	

Data / Parameter:	$EF_{NG,upstream,CH_4}$
Data unit:	tCH ₄ /TJ
Description:	Emission factor for upstream fugitive methane emissions from production, transportation and distribution of NG.
Source of data used:	As no reliable and accurate national data on fugitive CH ₄ emissions associated with the production is available, the default value as provided in Table 2 of ACM0011 is used
Value applied:	160
Justification of the choice of data, or description of measurement methods and procedures actually applied :	As the gas production, processing, and transmission system is of recent vintage, was built and is operated to international standards, the US/Canada default value is used.
Any comment:	See: AL FAJR pipeline documentation



Data / Parameter:	GWP_{CH_4}
Data unit:	tCO ₂ e/tCH ₄
Description:	Global warming potential of methane, valid for the relevant commitment period.
Source of data used:	IPCC
Value applied:	21 (for the first commitment period of the Kyoto protocol).
Justification of the choice of data or description of measurement methods and procedures actually applied:	According to ACM0011.
Any comment:	

B.6.3 Ex-ante calculation of emission reductions:

$$ER_y = BE_y - PE_y - LE_y \quad (10)$$

ER_y Emission reduction during year y (tCO₂/yr)

BE_y Baseline emission during year y (tCO₂/yr)

PE_y Project emission during year y (tCO₂/yr)

LE_y Leakage emission during year y (tCO₂/yr)

Therefore:

Baseline Emissions (tCO ₂ /yr)	3,480,325
Project Emissions (tCO ₂ /yr)	2,922,608
Leakage Emissions (tCO ₂ /yr)	126,019
Emission Reductions (tCO₂/yr)	431,698

In the last two years (2016 and 2017), emission reductions are not claimed for units 1 and 2 because they will have reached the end of their lifetime. The calculated values in the table above are based on years through 2015.

**B.6.4 Summary of the ex-ante estimation of emission reductions:**

Year	Estimation of project activity emissions (tonnes of CO ₂ equivalent, tCO ₂ e)	Estimation of baseline emissions (tCO ₂ e)	Estimation of leakage (tCO ₂ e)	Estimation of overall emission reductions (tCO ₂ e)
2008	2,922,608	3,480,325	126,019	431,698
2009	2,922,608	3,480,325	126,019	431,698
2010	2,922,608	3,480,325	126,019	431,698
2011	2,922,608	3,480,325	126,019	431,698
2012	2,922,608	3,480,325	126,019	431,698
2013	2,922,608	3,480,325	126,019	431,698
2014	2,922,608	3,480,325	126,019	431,698
2015	2,922,608	3,480,325	126,019	431,698
2016	1,753,565	2,088,195	75,611	259,019
2017	1,753,565	2,088,195	75,611	259,019
Total (tCO₂e)	26,887,992	32,018,994	1,159,376	3,971,626

B.7 Application of the monitoring methodology and description of the monitoring plan:**B.7.1. Data and parameters monitored:**

Data / Parameter:	Installed capacity ²⁶
Data unit:	MW
Description:	Installed capacity
Source of data to be used:	Project site
Value of data applied for the purpose of calculating expected emission reductions in section B.5	650
Description of measurement methods and	The installed capacity of the power plant before and after the fuel switch activity is tested using internationally approved standard methods available with the help of reputed players or manufacturers in the market. The test report

²⁶ This table has been adapted to cover installed capacity only, following guidance from the Methodology Panel on request for clarification AM_CLA_0058 (see Annex 7)



procedures to be applied:	before the fuel switch will be submitted to the validating DOE, and the verifying DOE will assure that the equipment remains at the same capacity within a tolerance of +/-5% once every crediting period every year. -
QA/QC procedures to be applied:	-
Any comment:	(see section B.2. for details)

Data / Parameter:	$EL_{aux,grid,y}$
Data unit:	MWh
Description:	Electricity used in the project power plant to serve auxiliary and back-loads that is obtained from the grid, if any.
Source of data to be used:	Electricity meters at the project site.
Value of data applied for the purpose of calculating expected emission reductions in section B.5	0
Description of measurement methods and procedures to be applied:	Cumulative power meters are read. Their summation yields a result for power imported from the grid for auxiliary internal consumption at ATPS, if any.
QA/QC procedures to be applied:	Meters are calibrated as per electricity meter handbooks (by NEPCO). This power value is cross-checked against invoices for imported power (from the grid) sent from NEPCO to CEGCO. The ATPS shift operator reads and records if power is imported from the grid. (During the crediting period the QA/QC procedures may be adapted or changed)
Any comment:	Electricity for auxiliary consumption is only imported in the very rare case that all units are shut down at the same time. Under normal conditions all auxiliary electricity needs are served internally.

Data / Parameter:	$EL_{PR,y}$
Data unit:	MWh
Description:	Electricity supplied to the electricity grid in year y of the crediting period.
Source of data to be used:	Electricity export meters at the project site.
Value of data applied for the purpose of calculating expected	4,928,000



emission reductions in section B.5	
Description of measurement methods and procedures to be applied:	All relevant readings for this parameter are taken from cumulative power meters (3 at Units 3, 4, & 5; 2 at Units 1 & 2). (over the lifetime of ATPS, meters may be changed or replaced with other types of meters, or the metering methods may change)
QA/QC procedures to be applied:	Meters are calibrated as per individual meter handbooks. The shift operator reads and records the power generated and exported from ATPS daily. Additionally, each month a CEGCO/NEPCO 3 rd party reading by Acomette Company is taken. (During the crediting period the QA/QC procedures may be adapted or changed)
Any comment:	The above value used for estimation is taken from 2005 CEGCO Annual Report, Table 4, p. 20, and is the value for sold electrical energy from ATPS in 2005. See Annex 4, Documents 1 & 3.

Data / Parameter:	$FF_{aux., diesel, y}$
Data unit:	Tonnes
Description:	Total amount of diesel used in the project power plant to serve auxiliary and back-up loads in year y of the crediting period.
Source of data to be used:	Tank level difference
Value of data applied for the purpose of calculating expected emission reductions in section B.5	14
Description of measurement methods and procedures to be applied:	The level in the diesel tanks is measured by a level measurement gauge monthly. The volume is obtained by multiplying the tank level by the tank cross-sectional area. The mass is calculated by multiplying the resulting volume by the density value of 0.84Kg/l from Oak Ridge National Laboratory (http://bioenergy.ornl.gov/papers/misc/energy_conv.html).
QA/QC procedures to be applied:	The value is cross-checked monthly against invoices.
Any comment:	The above amount used for estimation is taken from the 2005 CEGCO Annual Report, Table 5, p. 21 multiplied by a density of 0.84t/m ³ from Oak Ridge National Laboratory to convert to tonnes. Diesel at ATPS is used for other purposes than power generation such as fuel for plant vehicles, fire-extinguisher pumps, as a solvent/cleaner for parts so the method of measurement is conservative.



Data / Parameter:	$FF_{aux, HFO, y}$
Data unit:	Tonnes
Description:	Total amount of HFO used in the project power plant to serve auxiliary and back-up loads in year y of the crediting period.
Source of data to be used:	Tank level difference.
Value of data applied for the purpose of calculating expected emission reductions in section B.5	33,621
Description of measurement methods and procedures to be applied:	The level in the diesel tanks is measured monthly by a level measurement gauge. The volume is obtained by multiplying the tank level by the tank cross-sectional area. The mass is calculated by multiplying the resulting volume by the density value of 0.99Kg/l from Engineer's Edge (http://www.engineersedge.com/fluid_flow/fluid_data.htm)
QA/QC procedures to be applied:	The value is cross-checked monthly against invoices.
Any comment:	The above value, used for estimation purposes, is taken from the 2005 CEGCO Annual Report, Table 5, p. 21. Post fuel switch, very little, if any HFO is used.

Data / Parameter:	$EF_{elec, y}$
Data unit:	tCO ₂ /MWh
Description:	Emission factor for the grid in year y
Source of data to be used:	A conservative default value of 1.3 tCO ₂ /MWh is used, according to ACM0011.
Value of data applied for the purpose of calculating expected emission reductions in section B.5	1.3
Description of measurement methods and procedures to be applied:	Not applicable
QA/QC procedures to	



be applied:	Not applicable
Any comment:	

Data / Parameter:	$EF_{NG,y}$
Data unit:	tC/m ³
Description:	Carbon emission factor of the NG used in the PAPP in year y
Source of data to be used:	The Methodology gives 4 options for a source of this value. The value used is the preferred source, e), i.e. the values provided by the fuel supplier in invoices.
Value of data applied for the purpose of calculating expected emission reductions in section B.5	0.0005424
Description of measurement methods and procedures to be applied:	<p>The NG composition is issued automatically every day by Al Fajr Pipeline company by their gas chromatograph up to a precision of C9 (n-Nonane gas).</p> <p>The density at Standard Conditions²⁷ and EF in tC/t are calculated from the composition measured daily, and EF in tC/m³ is hence expressed (a calculation spreadsheet is used for these steps).</p> <p>The yearly value is calculated from a weighted average using the daily consumption. It is then divided by the yearly consumption to obtain the weighted average annual emission factor.</p>
QA/QC procedures to be applied:	The chromatograph is calibrated as per its individual handbook to ISO6976 standards.
Any comment:	<p>See calculation spreadsheet for detailed calculations.</p> <p>The value used for ex-ante calculations is an average from April to December 2007</p>

Data / Parameter:	$EF_{diesel,y}$
Data unit:	tC/t _{diesel}
Description:	Carbon emission factor of diesel used in the PAPP to serve auxiliary and back-up loads in year y.
Source of data to be	The Methodology gives 4 options for a source of this value. The first option

²⁷ In this project, Standard Conditions are 15°C and 1 Atmosphere.



used:	“e”) cannot be used because the Diesel invoices do not include an EF value. Therefore, option, “h”) as outlined in ACM0011 is used: IPCC default values at the upper limit of the uncertainty at a 95% confidence interval, as provided in table 1.4 of Chapter 1 of 2006 IPCC Guidelines on National GHG Inventories.
Value of data applied for the purpose of calculating expected emission reductions in section B.5	0.865
Description of measurement methods and procedures to be applied:	EF in tC/t is calculated with the help of the IPCC default values: $NCV_{\text{Diesel}} * CO_2 \text{ emission factor (IPCC default values at the upper limit of the uncertainty at a 95\% confidence interval, as provided in table 1.4 of Chapter 1 of 2006 IPCC Guidelines on National GHG Inventories) / (44/12)}$
QA/QC procedures to be applied:	IPCC default values at a 95% confidence interval
Any comment:	

Data / Parameter:	$EF_{HFO,y}$
Data unit:	tC/t _{HFO}
Description:	CO ₂ emission factor of HFO used in the PAPP to serve auxiliary and back-up loads in year y.
Source of data to be used:	The Methodology gives 4 options for a source of this value. The first option “e”) cannot be used because the HFO invoices do not include an EF value. Therefore, option, “h”) as outlined in ACM0011 is used: IPCC default values at the upper limit of the uncertainty at a 95% confidence interval, as provided in table 1.4 of Chapter 1 of IPCC 2006 Guidelines on National GHG Inventories
Value of data applied for the purpose of calculating expected emission reductions in section B.5	0.865
Description of measurement methods and procedures to be applied:	EF in tC/t is calculated with the help of the IPCC default values: $NCV_{\text{HFO}} * CO_2 \text{ emission factor (IPCC default values at the upper limit of the uncertainty at a 95\% confidence interval, as provided in table 1.4 of Chapter 1 of 2006 IPCC Guidelines on National GHG Inventories) / (44/12)}$
QA/QC procedures to be applied:	IPCC default values at a 95% confidence interval
Any comment:	



Data / Parameter:	$NCV_{NG,y}$
Data unit:	GJ/m ³
Description:	Weighted average of net calorific value of NG in year y
Source of data to be used:	The Methodology gives 4 options for a source of this value. The first source (called “e”) (sic)) (provided by supplier), is used.
Value of data applied for the purpose of calculating expected emission reductions in section B.5	0.035633
Description of measurement methods and procedures to be applied:	The gross calorific value GCV is provided by Al Fajr Pipeline Company in BTU/SCF, from the gas analysis performed automatically by their gas chromatograph. The NCV is then calculated from the amount of hydrogen atoms in each component of the natural gas. The value is then converted to GJ/m ³ .
QA/QC procedures to be applied:	The chromatograph is calibrated as per its individual handbook to ISO6976 standards.
Any comment:	Source for estimated value: Gas Delivery report from Al Fajr Pipeline Company, average value from January to November 2007. Only for the value used for ex-ante calculations, an approximate ratio value of 90% was used for NCV/GCV. For monitoring values the ratio obtained from measurement is used.

Data / Parameter:	NG_y
Data unit:	m ³
Description:	Total amount of NG used in the project power plant in year y of the crediting period. The flow is measured continuously by the Al Fajr’s ultrasonic flow meter in Standard Cubic Meters (SCM ²⁸). The gas quantity delivered by Al Fajr Pipeline Company to ATPS is recorded daily (Over the lifetime of ATPS, the installed equipment may be exchanged or replaced, and this may affect the metering method).
Source of data to be used:	Data logs at the project site from ultrasonic on-line flow meter.
Value of data applied for the purpose of calculating expected emission reductions in	1,415,982,226

²⁸ In this project Standard Conditions are 15°C and 1 Atmosphere.



section B.5	
Description of measurement methods and procedures to be applied:	<p>NG_y is the sum of daily report values of the NG used in the plant, for a year. A monthly summary report is provided to CEGCO by Al Fajr Pipeline Company. The daily values are automatically printed out from the ultrasonic flow meter and signed by 2 members of staff (1 representative of Al Fajr, the NG provider, and 1 representative of CEGCO).</p> <p>The value is expressed in MMBTU in the reports, and the monitored $NCV_{NG,y}$ is used to obtain a volume of Natural Gas (in m^3).</p> <p>The above value (NG_{2005}) is used for estimation of future emission reductions.</p>
QA/QC procedures to be applied:	Meters are calibrated as per their individual handbooks to international standards.
Any comment:	Source for estimated value: 2005 CEGCO Annual Report, Table 5 p. 21. The value (in MMBTU) is converted using the conversion factor of $1055TJ/MMBTU$, and the NCV of $3.563 \times 10^{-5} TJ/m^3$ (NCV obtained from a January to November 2007 average of Al Fajr Company analysis) to obtain consumption in m^3 .

B.7.2 Description of the monitoring plan:

This section details the steps taken to monitor, on a regular basis, the GHG emissions reductions from the ATPS fuel switch project, as required by methodology ACM0011, Version 01, approved at EB 28:

The Monitoring Plan for this project has been developed to ensure that, from the start, the project is well organised in terms of the collection and archiving of complete and reliable data. The site is ISO9001 certified.

Data collection and record keeping arrangements:

Monitored data will be measured and collected as detailed in section B.7.1. That is,

- EF_{NG} , NCV_{NG} and NG_y are recorded daily in a CDM spreadsheet by a designated ATPS member of staff from the Operations Department.
- $EL_{aux,grid,y}$ and $EL_{PR,y}$ are recorded monthly in a CDM spreadsheet by a designated ATPS member of staff from the Operations Department.
- FF_{HFO} and FF_{Diesel} are recorded monthly in a CDM spreadsheet by a designated ATPS member of staff from the Operations Department.
- Installed Capacity will be verified ~~once every crediting period~~ **every year**.

All data required for verification and issuance will be backed-up and kept for at least two years after the end of the crediting period or the last issuance of CERs of this project, whichever occurs later. The data is archived at ATPS.



Data collected by the Operations Department will be compiled in a CDM workbook. The CDM workbook will then be sent to the Manager of the Operations Department before being sent to CEGCO's headquarters. EcoSecurities will receive this workbook from headquarters on a monthly basis.

Data Quality Control and Quality Assurance

All data collected by the Operations Department will be checked and cross-checked (e.g. internally, with invoices) before being compiled in a CDM workbook. The Manager of the Operations Department will check the completeness and quality of the data before sending it on to CEGCO headquarters.

EcoSecurities will perform a regular final check of the data and analyse project performance prior to any verification. Moreover, regular internal audits will be conducted to assure that the project is in compliance with operational and CDM requirements.

Procedures will be developed to deal with possible monitoring data adjustments and uncertainties as well as emergencies.

Maintenance and Calibration of monitoring equipment

All equipment will be maintained and calibrated in line with manufacturer's recommendations and according to a pre-set schedule. This will ensure that the equipment operates at the stated level of accuracy.

Staff training

Training is conducted on site at regular intervals to ensure that staff are capable of perform their designated tasks to high standards. This will include CDM specific training to confirm that they understand the importance of complete and accurate data and records for CDM monitoring.

CDM monitoring organisation and management

Prior to the start of the crediting period, the organisation of the monitoring team will be finalised. Clear roles and responsibilities will be assigned to all staff involved in the CDM project. The Project Developer will have a designated CDM Monitoring Coordinator on site, who will be responsible for monitoring emissions reductions of the project activity. All staff involved in the collection of data and records will be coordinated by this Coordinator.

N.B. The plant is owned and operated by Central Electricity Generating Company (CEGCO) of Jordan. The authority of project management at the project site therefore lies with the ATPS plant management.

**B.8 Date of completion of the application of the baseline study and monitoring methodology and the name of the responsible person(s)/entity(ies)**

The baseline study and the monitoring methodology were concluded on 24/10/2007. The entity determining the baseline study and the monitoring methodology, and participating in the project as the Carbon Advisor is EcoSecurities, with contacts:

Mark.Ghorayeb@ecosecurities.com, Steve.Anzarouth@ecosecurities.com or
Xaver.Kitzinger@ecosecurities.com

SECTION C. Duration of the project activity / crediting period**C.1 Duration of the project activity:****C.1.1. Starting date of the project activity:**

28/2/2002 (time of decision making)

C.1.2. Expected operational lifetime of the project activity:

21 years (see table with the design lifetime in section B.2: The last units should reach end of their lifetime in 2028)

C.2 Choice of the crediting period and related information:**C.2.1. Renewable crediting period****C.2.1.1. Starting date of the first crediting period:**

‘Not applicable’

C.2.1.2. Length of the first crediting period:

‘Not applicable’

C.2.2. Fixed crediting period:**C.2.2.1. Starting date:**

~~1/4~~26/09/2008 or date of registration, whichever is later

C.2.2.2. Length:

10 years

**SECTION D. Environmental impacts****D.1. Documentation on the analysis of the environmental impacts, including transboundary impacts:**

The only negative environmental impact resulting from the Project is as a result of the construction of the NG supply pipeline from Egypt. This Arabian Gas Pipeline has been constructed, maintained, and operated to the highest American/Canadian standards and consequently has little/no negative environmental impact, both visually and in practice. Furthermore the pipeline is part of a network and is not built purely for providing NG to ATPS. Any impacts of the gas pipeline are therefore not a direct result of the fuel switch at ATPS.

On the other hand, the environmental benefits gained are substantial and are relisted here:

- Reduced CO₂, SO₂, NO_x emissions, and suspended particulate matter with associated aromas;
- Reduced “rotten egg” aroma from H₂S, since high sulphur content HFO is substituted by NG;
- Smokestack output is no longer coloured, but transparent – no more visual pollution;
- Reduced shipping/trucking of HFO, with reduced related traffic and pollution;
- GHG reductions and diversification of Jordan’s electricity production with a leaning towards “cleaner” power.

In summary:

Visual differences: Since the project involved predominantly internal boiler modifications, in addition to the fuel delivery and control systems, there are no noticeable differences at or near the plant except for the positive effects of reduced trucking and shipping of HFO, and the relative elimination of smokestack plumes.

Noise: There will be a marked reduction in noise at or near the site associated with reduced trucking of HFO. The impacts are likely to be substantial given the quantity of HFO previously consumed.

Air Quality: Following the fuel switch to NG, there are marked improvements in the air quality surrounding ATPS. This is a result of reductions of SO₂, NO_x, H₂S, suspended particulate matter and the associated aromas of all these. H₂S has a particularly pungent “rotten egg” aroma which was a result of the high sulphur content of the HFO previously used. Furthermore, under NG conditions, smokestack output is no longer coloured, but transparent. On a secondary level, the NG fuel delivery system by pipeline from Egypt has resulted in a drastic reduction of pollution from the HFO delivery vehicles previously necessary.

Safety: The practical safety-related ramifications of the fuel switch to NG are minor, the most noteworthy of which result from the gross reductions in trucking. As with any pressurised gas delivery system, safety is a priority. Given that the fuel switch is of recent vintage, safety measures and precautions are well in place. Furthermore, given that HFO is only used as a back-up fuel, the preheating technology necessitated by HFO’s high viscosity is also avoided.



D.2. If environmental impacts are considered significant by the project participants or the host Party, please provide conclusions and all references to support documentation of an environmental impact assessment undertaken in accordance with the procedures as required by the host Party:

Because of the nature of the relatively “minor” modifications required for the fuel switch project, and given that an Environmental Impact Assessment was performed for the addition of Units 3 & 4 in 1995²⁹, Jordanian authorities did not require an EIA for the fuel switch project. Along with mitigation controls that were planned as part of the project design, construction and operation, and the contribution made to sustainable development at the local and national scale, the project is expected to have an overall positive impact on the local and global environment. All negative environmental impacts are subject to mitigation measures as described above.

An EIA was performed regarding the transmission of NG from the Aqaba shoreline to the plant³⁰.

SECTION E. Stakeholders’ comments

E.1. Brief description how comments by local stakeholders have been invited and compiled:

The stakeholder consultation for the Fuel Switching Project of the Aqaba Thermal Power Station is comprised of 2 parts:

1. The solicitation of stakeholder concerns and comments by advertising in a widely circulated Jordanian daily newspaper (called “Al Ghad”, meaning “tomorrow”) on 04/09/2007; and
2. The circulation by e-mail or fax of a similar letter to key Jordanian stakeholders, also on 04/09/2007.

The former was published in Arabic on the prominent third page of the newspaper, whereas the latter was sent in English by e-mail or fax (receipts are available). Both documents summarised the project’s basic technical issues from a CDM perspective; they included:

- A brief description of the project
- Climate change and how this project is mitigating climate change through the Clean Development Mechanism of the Kyoto Protocol
- Review of the country’s climate change and CDM activities by the Host Country’s DNA
- Presentation of technical details of the Project
- Analysis of the CDM Project and carbon benefits

All stakeholders were invited to send comments and concerns by 19/09/2007 to EcoSecurities, JCCCC (EcoSecurities’ Jordanian partner), and to cc. CEGCO.

Participants to the consultation included:

- Local authority representatives
- Local community associations

²⁹ Merz & McLellan Aqaba Thermal Power Station Stage II Units 3 and 4 Environmental Impact assessment, October 1995.

³⁰ See Royal Scientific Society Summary of Phase 1 EIA



- Non Governmental Organisations
- Academics
- Government officials
- Project staff and management
- Environmental authorities
- Industry association representatives

All participants were catalogued appropriately – see Annex 5.

Included in Annex 5 are:

- Scan of the Arabic “Al Ghad” newspaper stakeholder solicitation advertisement from 05/09/2007;
- An English translation of the above;
- A template of the English letter sent (via e-mail or fax) to key Jordanian stakeholders;

A table detailing the key stakeholders’ details,, to which letters were sent is made available to the validating DOE.

E.2. Summary of the comments received:

2 comments were received and addressed (one within the comment deadline of 19/09/2007, and one past the comment deadline). Both were addressed to the satisfaction of the enquirers, as documented below:

Comment #1 (19/09/2007):

Mr. Mohammad Nashwan
Jordan Climate Change Consultancy Company
Amman-Jordan

19 September 2007

Subject: Stakeholder Consultation for the Fuel Switching Project of the Aqaba Thermal Power Station Project

Dear Sir,

Reference is made to your letter dated 04 Sept. 07 with the above mentioned subject. The Aqaba Special Economic Zone Authority (ASEZA) here confirms that the fuel switch, for the power station boilers from heavy fuel oil to Natural Gas, have reduced the emissions load to the atmosphere at the industrial area and the environmental impacts of the facility. Furthermore, ASEZA supported the project from the early stages and is encouraging other industries in the Zone to convert to Natural gas and contribute to the protection of the environment and the improvement of the air quality.

Should you need further information, please feel free to contact us.

Regards,

Aiman Soleiman



Aiman Soleiman, Ph.D.

Head, Environmental Studies & Monitoring Division
ASEZA Program Coordinator: The European Project

Aqaba Special Economic Zone Authority (ASEZA)

Response to comment #1 (19/09/2007):

Dear Mr. Soleiman,

We thank you for your positive comments, and are happy the fuel switch has a positive effect on the area. It is also good to hear that you are making an effort to convert other facilities to cleaner burning Natural Gas in the interests of the environment.

Should you or your colleagues and fellow stakeholders have further comments (either positive or negative) regarding the ATPS fuel switch, we welcome them, and ask that they be submitted by the specified deadline.

Thanks and regards,

Mark I. Ghorayeb
Implementation Team - Middle East
EcoSecurities Middle East DMCC

Mob: +971 50 253 9571

Off.: +971 4 427 0309

Fax: +971 4 427 0308

mail: Mark.Ghorayeb@EcoSecurities.com

www.EcoSecurities.com

Skype: "Mr. Ghorayeb"

Comment #2 (20/09/2007):

From: lana Al - zu'bi

Sent: Thursday, September 20, 2007 1:11 PM

To: mnashwan@jordanclimate.com

Cc: odaour@cegco.com.jo

Subject:

Dear Mohammad,



Please find hereunder our comments and enquiries regarding the "Fuel switching project of the Aqaba thermal power station project". I know the deadline has passed but hopefully these comments will Be taken into account.

1. Coastal power stations generally use seawater as cooling water and thus release seawater with elevated temperature into near shore environments. In addition, anti fouling chemicals are injected into intake seawater to prevent the growth of fouling organisms on the surface of the cooling systems. Chlorination of seawater is mostly employed by coastal power stations and thereby causes formation of chlorination by-products which might potentially inhibit microbes. During the passage through cooling systems, intake seawater containing natural microbes is thus exposed to both high temperature (rarely exceeding 40°C) and anti fouling chemicals for a short time (e.g. about 10 to 30 min). At the outfalls, thermal effluents become mixed with receiving seawater, and elevated temperature and chlorination by-products are always observed near the discharge area. Therefore, thermal discharges from a coastal power station have 2 main components of pollution to coastal waters, i.e. high temperature and chemicals formed during anti fouling procedures. Micro-organisms are numerically abundant in coastal waters and carry out many ecologically important roles in coastal ecosystems. Changes in microbial activities caused by changes in environmental conditions will thus confer significant impacts on functions of coastal ecosystems. What is the temperature of the water discharged to the sea and is any chlorination applied? What are the mitigation measures to prevent this kind of pollution?

2. What are the alternatives if any deficit occurred in the quantity of the available natural gas? The elevated use of the natural gas could probably increase its prices, what is the strategy to cope with such an event?

3. What are the mitigation measures that have been done to reduce the impact of any accident that might happen to the submarine pipeline that comes from Egypt?

Lana Al-Zu'bi
Hala Nobani
Greater Amman Municipality
Environment and Health Monitoring Unit

Response to comment #2 (20/09/2007):

Dear Lana,

Referring to our call this morning and your E mail about your comments about our project, Fuel Switch for ATPS I would like to thank you for your valuable comments. As I mentioned in our phone call, the Ecosystem in Aqaba Gulf will not be affected because of fuel switch project.

And I hope that you are satisfied with my comments which I mentioned by phone.

For any further information, please don't hesitate to contact me

Best regards,
Mohammad Nashwan
Technical Director



Jordan Climate Change Consultancy Company

No further comments were received by Ms. Lana Al-Zu'bi

E.3. Report on how due account was taken of any comments received:

The questions and comments raised as a result of the stakeholder consultation were addressed to the satisfaction of the individual making the comment(s).

With regard to the phone conversation between Ms. Lana Al-Zu'bi and Mohammad Nashwan, her concerns were addressed as such:

1. It was clarified that there were no major changes in the ATPS cooling system (involving water introduced from the Gulf of Aqaba) because of the fuel switch. There was a cooling system before the switch, and one after, so the fuel switch itself didn't influence the cooling system. Ms. Al-Zu'bi was reassured that because of the fragile nature of the Gulf and its importance as an ecological, touristic, and marine destination, every effort was being made to keep the impact of ATPS as small as possible.
2. With regard to NG fuel shortages, Mr. Nashwan explained to Ms. Al-Zu'bi that there is a 15-year agreement between the governments of Egypt and Jordan regarding NG supply and pricing. This is preferable to the HFO scenario which was disrupted with the '03 Gulf War. With respect to short-term interruptions in NG supply, the plant continues to have HFO firing ability along with a strategic reserve of 2 x 37,000 tons to ensure uninterrupted power supply.
3. Mr. Nashwan explained to Ms. Al Zu'bi that the Arabian Gas Pipeline was recently built to very high standards (of operation and safety). In the rare event of a leak, sections of pipeline showing faults can be isolated and repaired with little/no effect on the Gulf above. A Scada (Supervisory Control & Data Acquisition) System is in place to handle any leaks, in addition to flare systems.

Ms. Al Zu'bi was satisfied with the responses/explanations given her by Mr. Nashwan.

**Annex 1****CONTACT INFORMATION ON PARTICIPANTS IN THE PROJECT ACTIVITY**

Organization:	Central Electricity Generating Company (CEGCO)
Street/P.O.Box:	P. O. Box 2564
Building:	CEGCO Headquarters
City:	Amman
State/Region:	Khalda
Postfix/ZIP:	11953
Country:	Jordan
Telephone:	+962 6 534 0008
FAX:	+962 6 534 0800
E-Mail:	cegco@cegco.com.jo
URL:	http://www.cegco.com.jo/
Represented by:	Abdel Fattah Al Nsour
Title:	Managing Director
Salutation:	Engineer
Last Name:	Al Nsour
Middle Name:	
First Name:	Abdel Fattah
Department:	Executive Management
Mobile:	+962 795 528 575
Direct FAX:	+962 6 535 6958
Direct tel:	+962 6 534 7991
Personal E-Mail:	ansour@cegco.com.jo



Project Annex 1 participant

Organization:	EcoSecurities Group Plc.
Street/P.O.Box:	40 Dawson Street
Building:	
City:	Dublin
State/Region:	
Postfix/ZIP:	02
Country:	Ireland
Telephone:	+353 1613 9814
FAX:	+353 1672 4716
E-Mail:	cdm@ecosecurities.com
URL:	www.ecosecurities.com
Represented by:	
Title:	Compliance and Contract Manager
Salutation:	
Last Name:	Wobbe
Middle Name:	
First Name:	Robin
Mobile:	
Direct FAX:	
Direct tel:	+353 1613 9814
Personal E-Mail:	cdm@ecosecurities.com



Annex 2

INFORMATION REGARDING PUBLIC FUNDING

This project will not receive any public funding from Annex 1 parties.



Annex 3

BASELINE INFORMATION

Please see the detailed baseline calculations that are provided in addition to the PDD.




	Unit	Value	Source
EF HFO_PR	EF HFO (tC/t)	0.865	IPCC (2006)
EF HFO_BL	EF HFO (tC/t)	0.847	CEGCO analysis 2002
NCV HFO	Kcal/Kg	9,623	CEGCO analysis 2002
	NCV HFO (TJ/t)	4.029E-02	
EF NG	kg CO ₂ /Kg _{NG}	2.743	AI FAJR analysis - Average April to Dec 2007
	EF NG (tC/m ³)	5.424E-04	
CV NG	BTU/SCF (Gross)	1063	AI FAJR analysis - Average Jan to Nov 2007
	NCV NG (TJ/m ³)	3.563E-05	
EF Diesel	EF Diesel (tC/t)	0.865	IPCC (2006)
NCV Diesel (not required by ACM0011 v1)	NCV Diesel (TJ/t)	4.330E-02	IPCC (2006)
Grid Electricity Emission Factor	EF elec (tCO ₂ /MWh)	1.3	Default ACM0011
Baseline Efficiency	n baseline	37.44%	CEGCO Technical Planning Department Annual Report Power Plant Directorate 2002

Emission factor for upstream fugitive emissions NG	EF NG upstream (tCH ₄ /TJ)	0.16	ACM0011 (160 tCH ₄ /PJ)(America)
Emission factor for upstream fugitive emissions HFO	EF HFO upstream (tCH ₄ /TJ)	0.0041	ACM0011 Version 1, Table 2 (4.1 tCH ₄ /PJ)
GWP CH ₄	GWP	21	Default ACM0011
Diesel Density	Kg/l	0.84	Source: Oak Ridge National Laboratory http://bioenergy.ornl.gov/papers/misc/energy_conv.html
NG Density	Kg/m ³	0.725	AI FAJR analysis - Average April-Dec 2007
Conversion factor	TJ/BTU	1.0551E-09	
Conversion factor	m ³ /SCF	0.02832	
Conversion factor	Kcal/TJ	2.388E+08	

Annex 4**Additional information for Monitoring**



Diagram 4.1: ATPS single line diagram indicating destinations of 400KV, 132KV, and 6.6KV power, transformers etc.



Annex 5

STAKEHOLDER CONSULTATION

Picture 5.1: “Al Ghad” newspaper stakeholder solicitation advertisement, published 04/09/2007



Eco SECURITIES **CEGCO** Central Electricity Generating Company

دعوة للتشاور مع المهتمين والمعتنين بمشروع استبدال الوقود في مشروع محطة كهرباء العقبة الحرارية وذلك بتحويل محطة العقبة لحرق الغاز الطبيعي

لقد قامت شركة توليد الكهرباء المركزية بإنجاز مشروع تحويل الوقود في محطة كهرباء العقبة الحرارية إلى الغاز الطبيعي في العام ٢٠٠٤ وهو مشروع تم إدراجه ضمن مشاريع الطاقة النظيفة في المملكة الأردنية الهاشمية تقع محطة كهرباء العقبة الحرارية على بعد نحو ١٦ كم إلى الجنوب من مدينة العقبة.

تم في هذا المشروع استخدام إضافة المعدات اللازمة لمحطة العقبة لتحويلها لحرق وقود الغاز في مراحل بخارية لأغراض إنتاج الطاقة الكهربائية، وعلى الرغم من أن تكنولوجيا تحويل نوع الوقود منتشرة ومعتمدة في جميع أنحاء العالم إلا أنه يتم تطبيقها لأول مرة في الأردن والجديد فيها هو استخدام الغاز للمحطات البخارية حيث تم تنفيذ مشروع التحويل للغاز باستخدام الغاز الطبيعي المستورد من مصر عبر خط أنابيب مغمور تحت خليج العقبة.

أن من الأسباب الرئيسية لتحويل الوقود هو الحد من التلوث خاصة بسبب ارتفاع محتوى الكبريت في الوقود الثقيل (حوالي ٢,٦ %) وما تشمله أكاسيد الكبريت من مضار بيئية على المناطق المحيطة بالمحطة. الفوائد البيئية لمشروع تحويل الوقود هي:

- * خفض انبعاث ثاني أكسيد الكربون، وثاني أكسيد الكبريت، وأكاسيد النيتروجين والجسيمات العالقة المرتبطة بالغازات المنبعثة.
- * خفض وإزالة روائج الغازات وخاصة أكاسيد الكبريت.
- * لم يعد هناك تلوث بصري بسبب الغازات المنبعثة من المداخل حيث أنها لم تعد داكنة كما كانت سابقاً بل شفافة وغير مرئية.
- * هذا المشروع يعد ضمن مشاريع التكنولوجيا النظيفة.
- * خفض تكاليف شحن ونقل الوقود الثقيل بالصهاريج مما يقلل أيضاً من التلوث الناتج عن حركة النقل والأزدحام في الشاحنات كذلك يقلل احتمالات حوادث السير.
- * سيعتبر هذا المشروع أحد مشاريع التخفيف من ظاهرة تغير المناخ بسبب خفض ثاني أكسيد الكربون والغازات الأخرى.

وبما أن الجزء الأساسي من أي مشروع آلية تنمية نظيفة المدرج تحت الاتفاقية الإطارية للتغير المناخي يشمل التشاور مع الجمهور، لذا فإننا ندعوكم إلى مشاركتنا بأرائكم وتعليقاتكم عبر البريد الإلكتروني بشأن هذا المشروع للعنوان التالي،

mark.ghorayeb@ecosecurities.com
mnashwan@jordanclimate.com أو
odaour@cegco.com.jo
fhamed@cegco.com.jo

على أن يتم نسخ مشاركتكم إلى شركة توليد الكهرباء المركزية عبر البريد الإلكتروني أيضاً على العنوان التالي،

إذا كان لديك أية آراء أو استفسارات بشأن هذا المشروع، يرجى الاستفسار خلال أسبوعين من تاريخ الإعلان، علماً بأن آخر موعد لتقديم الاقتراحات هو ٢٠٠٧/٩/١٩

نقدر مشاركتكم. وستؤخذ تعليقاتكم وأرائكم بعين الاعتبار لضمان أن مشروع استبدال الوقود من محطة كهرباء العقبة الحرارية يحقق أهدافه في التنمية المستدامة.



Box 5.1: Translation of “Al Ghad” newspaper advertisement (of 04/09/2007) for stakeholder comments/concerns

Stakeholder Consultation for the Fuel Switching Project of the Aqaba Thermal Power Station

The Fuel Switching Project of the Aqaba Thermal Power Station Project, developed by Central Electricity Generating Company (CEGCO) is an energy industries (renewable/non-renewable sources under the Kyoto Protocol) project in Aqaba, the Hashemite Kingdom of Jordan.

The project has been set up at Aqaba Thermal Power Station (ATPS), which is approximately 16 km south of Aqaba. The project has implemented a fuel switch for the power station boilers from Heavy Fuel Oil (HFO) to Natural Gas (NG). The fuel is burned to create steam that drives turbines that rotate magnets within generators, creating electrical energy. This is common technology throughout the world, but relatively new to Jordan. The fuel switch was completed in 2004, and ATPS has been running on NG imported via a submarine pipeline (under the Gulf of Aqaba) from Egypt. The primary reason for the fuel switch was to reduce pollution. Due to the high sulphur content of HFO, the “rotten egg” aroma common before the fuel switch has since been averted.

The environmental benefits of the fuel switch project are:

- Reduced CO₂, SO₂, NO_x, and suspended particulate matter with associated aromas;
- Reduced “rotten egg” aroma (H₂S), since high sulphur content (3.6%) HFO is only used as a back-up fuel;
- Smokestack output is no longer coloured, but transparent – no more visual pollution;
- Acts as a clean technology demonstration project;
- Reduced impact on Gulf of Aqaba, since the Gulf’s water that is used for cooling is now cycled back at a reduced temperature – ATPS runs cooler after the fuel switch;
- Good publicity and setting of an example in the region;
- Reduced shipping/trucking of HFO (with related traffic and pollution);
- Mitigation of climate change due to the reduction of CO₂.

A fundamental part of such a Clean Development Mechanism (CDM) project under the United Nations Framework Committee on Climate Change includes a Public Consultation. We invite you to e-mail comments regarding the Fuel Switching Project of the Aqaba Thermal Power Station to:

**mark.ghorayeb@ecosecurities.com OR mnashwan@jordancclimatechange.com
and ask that you cc CEGCO at:
fhamid@cegco.com.jo OR odaour@cegco.com.jo**

Should you have any concerns or queries regarding this project, please e-mail them by 19/09/’07.

We value your participation, as your opinions and comments will be taken into account to ensure that the Fuel Switching Project of the Aqaba Thermal Power Station achieves its sustainable development objectives.





Box 5.2: Stakeholder consultation letter (of 04/09/2007) for stakeholder comments/concerns e-mailed OR faxed to key Jordanian stakeholders



CEGCO
Central Electricity Generating Company



Stakeholder name

04/09/2007

Stakeholder address

Subject: Stakeholder Consultation for the Fuel Switching Project of the Aqaba Thermal Power Station Project

Dear XXXX,

The Fuel Switching Project of the Aqaba Thermal Power Station, developed by Central Electricity Generating Company, is an energy industries (renewable/non-renewable sources under the Kyoto Protocol) project in Aqaba, the Hashemite Kingdom of Jordan.

The project has been set up at Aqaba Thermal Power Station, approximately 16 kilometres south of Aqaba. The project has implemented a fuel switch for the power station boilers from Heavy Fuel Oil (HFO) to Natural Gas (NG). The fuel is burned to create steam that drives turbines that rotate magnets within generators, creating electrical energy. This fuel switch technology is common throughout the world, but relatively new to Jordan. The fuel switch was completed in 2004, and ATPS has been running on NG imported via a submarine pipeline (under the Gulf of Aqaba) from Egypt. The primary reason for the fuel switch was to reduce pollution. Due to the high sulphur content of HFO, a “rotten egg” aroma was common before the fuel switch, and has since been averted.

The environmental benefits of the fuel switch project are:

- Reduced CO₂, SO₂, NO_x, and suspended particulate matter with associated aromas;
- Reduced negative impact in the area since high sulphur content (3.6%) HFO is only used as a back-up fuel;
- Smokestack output is no longer coloured, but transparent – no more visual pollution;
- Acts as a clean technology demonstration project;
- Reduced impact on Gulf of Aqaba, since the Gulf’s water that is used for cooling is now cycled back at a reduced temperature;
- Good publicity and setting of an example in the region;
- Reduced shipping/trucking of HFO (with related traffic and pollution);
- Mitigation of climate change due to the reduction of CO₂ emissions.



A fundamental part of such a Clean Development Mechanism (CDM) project under the United Nations Framework Committee on Climate Change (UNFCCC) consists of a Public Stakeholder Consultation. We extend to you an invitation to e-mail your comments and concerns regarding the Fuel Switching Project of the Aqaba Thermal Power Station to:

**mnashwan@jordanclimate.com OR mark.ghorayeb@ecosecurities.com
and to cc:
odaour@cegco.com.jo OR fhamed@cegco.com.jo**

Please send your e-mails by 19/09/'07.

We value your participation, as your opinions and comments will be taken into account to ensure that the Fuel Switching Project of the Aqaba Thermal Power Station achieves its sustainable development objectives.

Our contact details are:

Mark Ghorayeb
mark.ghorayeb@ecosecurities.com
+971 4 427 0309
EcoSecurities Middle East DMCC
Saba Tower 1 – Office 506
Jumeirah Lake Towers
P.O.Box 346002
Dubai, United Arab Emirates, and

Mohammad Nashwan
mnashwan@jordanclimate.com
+962 6565 9432
Jordan Climate Change Consultancy Company
P.O Box 4823 Amman 11953
Amman, Jordan

Many thanks,

Mark Ghorayeb
Dubai, UAE, and

Mohammad Nashwan
Amman, Jordan



**Annex 6****CAPACITY TESTS**

MCRt steam / h
before boiler modifications
after boiler modifications


1		2		3		4		5		average	
NG	HFO	NG	HFO	NG	HFO	NG	HFO	NG	HFO	NG	HFO
	410		411.25		413.3		424.58		422.66	-2.01%	416.358
408.2	413.7	417	418.75	433.29	433.52	427.79	426.96	437.45	429.99	424.746	424.584
	0.89%		1.79%		4.66%		0.56%		1.70%		1.94%

Note: MCR denotes “Maximum Continuous Rating”, and is a term used specifying that the boiler is operating at 105%. This is generally only done during testing.

Annex 7

Request for clarification on ACM0011 Version 1

F-CDM-AM-Clar_Resp_ver 01.1 - AM_CLA_0058

 <p style="text-align: center;">CDM: Response form for request for clarification on Approved Methodologies (version 01.1)</p>	
Date of Meth Panel meeting:	Address as per fast clearance process
Title and number of request for clarification	Clarification on applicability condition: change in capacity / AM_CLA_0058
<p>Summary of the query:</p> <p>Please use the space below to summarize the request for clarification on the related approved methodologies.</p> <p>The request is to clarify the following:</p> <p>(i) Whether, as required in the version 01 applicability condition, after the project implementation the capacity alone should not change more than $\pm 5\%$ or as per monitoring tables both the capacity as well as electricity generation should not change more than $\pm 5\%$.</p> <p>(ii) Whether the installed capacity of the project activity power plant has to be monitored even before and after the implementation of the project activity or not.</p>	
<p>Recommendation by the Meth Panel:</p> <p>Please use the space below to provide an answer to the queries (in your expert view, if necessary).</p> <p>The panel would like to clarify that in version 1 the following applies:</p> <p>(i) The installed capacity of the project activity power plant should not change more than $\pm 5\%$ after the implementation of the project activity. The electricity generation of project activity power plant may increase beyond the installed capacity.</p> <p>(ii) The installed capacity of the project activity power plant should be monitored even before the implementation of the project activity. The data required for the same to be submitted to EB during the validation. The installed capacity of the project activity power plant should be annually tested after the implementation of the project activity. The data required for the same to be submitted to EB during the validation to check that the installed capacity of the project activity power plant is within $\pm 5\%$ of the installed capacity of the power plant prior to implementation of the project activity.</p>	
<p>Answer to authors of the request for clarification by the Meth Panel:</p> <p>Please use the space below to provide an answer to the authors of the above query</p>	

Annex 8

Fuel Price Comparison and NPV calculations

Table 8.1: Fuel Price comparison NG and HFO[illegible]

HFO															
Unit	Fuel Costs (according to average of '01 "Nexant & Transborder" official fuel price predictions)		2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015
\$/t	Average of '01 "Nexant & Transborder" official fuel price predictions	110.5	95.5	87.5	80.5	76.5	74.5	72.5	71.5	70.5	69.5	69.5	68.5	67.5	66.5
t/MWh	Calculated from historic fuel consumption and electricity generation levels in 2002		0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221
\$/MWh	Calculated (C=A*B)		21.11	19.34	17.79	16.91	16.47	16.02	15.80	15.58	15.36	15.36	15.14	14.92	14.70

[illegible][illegible]



Input Source: Appendix D of “Master Plan for the Energy sector of Jordan Interim Report”, by Transborder and Nexant, May 2001, as presented to the “Arab Bank Centre for Scientific Research”

Table 8.2: Cost Breakdown of boiler Fuel Switch to NG in Jordanian Dinars and US \$

Description	Installation	Hardware (incl. delivery)	Spare Parts	Admin. Exp.	Exch. Rate Losses	Tech. Support	Tech. Eval.	Concrete Foundation	Total	Total US\$
Unit 1	402,383	1,849,082		18,573	25,395	1,695	9,945		2,307,073	3,215,598.08
Unit 2	391,398	1,849,082		18,493	25,395	1,688	9,903		2,295,959	3,200,107.15
Unit 3	339,944	1,849,082		18,120	25,395	1,654	9,703		2,243,897	3,127,544.10
Unit 4	349,772	1,849,082		18,191	25,395	1,660	9,741		2,253,841	3,141,404.03
Unit 5	370,007	1,849,082		18,338	25,395	1,674	9,820		2,274,315	3,169,940.10
NG Purification Plant	1,606,607	1,886,064		27,621	25,903	2,521	14,791		3,563,507	4,966,815.48
Other Spare Parts			484,068	4,081	6,621	372	2,185		497,329	693,176.68
Pressure Reduction Station		205,190		1,485		136	795	11,832	219,438	305,852.35
Pressure Reduction Station Spare Parts			6,064	44		4	24		6,136	8,552.19
Total (JD)	3,460,111	11,336,664	490,133	124,946	159,499	11,403	66,907	11,832	15,661,494	
Total (\$)	4,822,702	15,801,043	683,147	174,150	222,309	15,893	93,255	16,491	21,828,990	

Source: Cost breakdown of fuel switch at Aqaba, CEGCO 09/10/2005



Annex 9

Environmental Impact Assessment

Document 9.1: Royal Jordanian Society EIA Summary for Phase I

SUMMARY

This project was initiated by an agreement between the governments of Jordan and Egypt to supply Aqaba Thermal Power Station in the first phase with natural gas via a pipeline. The pipeline will supply other electric power stations in Jordan in a second phase. In the future other countries such as Syria and Lebanon will be supplied with the natural gas.

This study will only address phase I, which aims at providing the required quantities of natural gas to Aqaba Thermal Power Station to substitute the heavy fuel oil as a source of energy for electric power generation. The project facilities of phase I covered in this study include the receiving unit, the metering unit and the pipe connection from Aqaba shoreline to Aqaba Thermal Power Station.

To identify and analyze the potential impacts of the proposed project, an environmental impact assessment (EIA) was prepared by the Royal Scientific Society (RSS) according to the scope of work as shown in Volume (3). The scoping phase involved consultations with representatives from local communities, non-governmental organizations and regulatory authorities in a major scoping session held on the 7th of January 2003 in Aqaba. The following valued environmental components were identified:

- Water Resources.
- Public Health.
- Socio-Economic Conditions.
- Biodiversity.
- Marine Environment.
- Archeology.

To determine baseline data and to facilitate impact assessment a number of different studies were carried out including:

- Water Resources.
- Air Quality.
- Noise.



- Socio-Economic Conditions.
- Biodiversity
- Marine Environment.
- Archeological Survey.

Major Findings

1. Water Resources

The study area is covered by light brown dry deposits composed of loose to medium dense, fine to medium grained sand mixed with gravel and cobbles of granite. A loose sand material is deposited at the top of the area in the eastern, northern and southern parts of the study area.

The study area is located in the Southern Wadi Araba catchment area. This catchment area receives annual rainfall of about 26.3 mm and around 26.0 mm evaporate. The rainfall occurs accidentally in short duration (normally lasting less than three hours) which generates flash floods along the wadis coming from eastern highlands. As the project is located downstream of the wadis flow, any possible occurrence of flash floods carrying sediments may negatively impact the project. Therefore, dykes should be constructed around the project area to prevent any impact of sediments and floods on the project.

The main source of water supply for the project area is Disi wells, from which water is pumped for municipal and industrial uses in Aqaba. Average water extraction from Disi wells is regulated by ASEZA policy to 17.5 MCM per year. The workers and employees demand of fresh water can be estimated at about 8 m³/day (construction phase) and 3 m³/day (operation phase). Therefore, the project uses of fresh water will not influence the water demand significantly.

Groundwater is found in the study area, where the water table depths range from 2.75 m at the western part near the seashore to 9.75 m at the eastern part. Because of the location of the site at the shore, it is anticipated that groundwater quality is considered as seawater. The sedimentary deposits cover the study area has a high permeability that may cause groundwater (seawater) pollution. The estimated time for



pollutant spill to reach groundwater table at the shore, at the depth of 2.75 m, is 21 minutes. This indicates that the potential of groundwater (seawater) contamination is very high.

In order to avoid any groundwater (seawater) contamination, waste oil should be collected in sealed drums and regularly sent to Jordan Petroleum Refinery Company according to its established requirements. The domestic wastewater will be collected in a sealed concrete pit that should be located in the upper part of the project area, and the domestic wastewater should be disposed to Aqaba domestic wastewater treatment plant by using vacuum tankers in cooperation with ASEZA. Domestic (non-hazardous) solid waste should be collected in closed containers and disposed according to ASEZA regulations to the solid waste landfill.

2. Public Health

Air Quality Study

Relevant information of air pollution (SO_2 and NO_x) was collected for various industrial stacks emissions to describe the existing conditions in the project area.

An air pollution model was used to project the potential improvement in ambient air quality due to the use of natural gas instead of fuel oil in Aqaba Thermal Power Station. The results of the mathematical calculation showed that an improvement of about 99.9% in SO_2 stack emissions from the power station is expected by using natural gas. The model also showed that the reduction in SO_2 ground level concentration is expected to be between 60 – 63% and between 19 – 30% for NO_x .

Noise Study

Short term monitoring program for environmental noise was conducted for two sites during 5 days. The results of the noise survey showed that current ambient day and night noise levels are within the applicable Jordanian noise regulations.



Due to the nature of the project in concern (receiving, metering and gas transmission) the project will not contribute in any increase in ambient noise levels.

Fire and Natural Incidents Hazard

EGC should implement the recommendations of the HAZOP study concerning associated safety requirements such as fire protection and emergency plans.

EGC should coordinate with the Civil Defense Unit at the Jordan Phosphate Mines Company and / or the unit at Dorra area (Jordan- Saudi Arabia Border). EGC should also perform the required inspections and maintenance on the gas facilities and pipeline.

3. Socio-Economic Conditions

The study concluded that there will be a saving of 34 million dollars annually in addition to the improvement in environmental health and associated health benefits due to the tremendous improvement in air quality.

EGC has established agreements with the companies that might be affected due to excavation works (Aqaba Thermal Power Station, Jordan Phosphate Mines Company and the Telecommunication Company). Action plans have been approved by all concerned parties on the methodology for excavation to protect their own underground utilities.

The project will create 15 jobs during the operation phase and will employ 40 workers during the construction phase. In this case, the project will not make a significant change in employment in Aqaba area. However, local service providers (business enterprises) will benefit from the project

The study also revealed that any interruption in gas supply due to any reason regardless of the time of interruption would not affect the power



supply in Aqaba region. The power lines network in Jordan is designed to supplement any shutdown in any power station.

4. Biodiversity

The study showed that the project site has already been leveled and used. Two types of plants were identified on the site; ornamental trees and few native bushes of tamarisk.

The native plants will not be affected by the project due to their location. Some of the fast growing ornamental trees may be removed for construction purposes. These types of trees can be planted easily. Removal of trees shall be restricted to the unavoidable one, a permit from the Ministry of Agriculture shall be obtained for removal of trees.

5. Marine Environment

With respect to marine environment, this study concerned on the activities occurred on land that could have impact on marine environment.

Due to the close distance of the project facility (receiving and metering station) to the sea, any type of waste generated from the project may have negative impact on the marine environment if not managed well. To minimize dust generation during construction works and its impact on sea, EGC could spray water on the soil. All waste oil generated should be collected in closed drums / tanks and sent to Jordan Petroleum Refinery Company according to its requirements. The domestic wastewater should be constructed at the eastern part of the project area where sea depth ranges between 7.50 to 9.75 meters. Dust, debris, gas residues in the pipeline and other associated decommissioning issues should be dealt with according to the applicable regulations during the time of decommissioning.

6. Archeology

Aqaba Antiquities Office survey concluded that the site does not have any obvious archeological features or any other archeological remains.



EGC shall inform Aqaba Antiquities Office about the time and date for their site preparation and excavation so that a representative of the office will be present, taking into consideration that the Antiquities Law requires that any discovery of archeological items or remains should be reported to the Antiquities Department or to the nearest police station immediately.