

GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D, Mirza Galib Street, Kolkata - 700 016.

Memo. No. : WBFES/9308/06/Bidhan-IT/297/04 (344/04)

Date : 25/09/06

From : Director,
West Bengal Fire & Emergency Services.

To : Mr. S.K. Bhowmick,
Phoenix Software Limited,
4/1, Red Cross,
3rd Floor,
Kolkata - 700 001.

Sub : N.O.C for occupancy of B+G + XV Storied Business Building, G+II Storied Service Building at Premises No. - I.T. Park, Plot No.-4, Block-BP, Sector-V, Salt Lake City, Kolkata - 700 091.

Sir,

This is in reference to your letter dated 04.07.2006 regarding the N.O.C for occupancy of B+G + XV Storied Business Building, G+II Storied Service Building at Premises No. - I.T. Park, Plot No.-4, Block-BP, Sector-V, Salt Lake City, Kolkata - 700 091.

The performance of the Fire Fighting & Alarm System as incorporated in the aforesaid building were tested and found satisfactorily working condition. On the basis of that this office is issuing the 'No Objection Certificate' for occupancy of the said business building.

However to upkeep the Fire Safety measure the following Safety measures need to be incorporated.

1. Drive way should be free any type of obstruction for easy movement of Fire Appliances.
2. The Interior finish decoration of entire building should be made with low flame spread material confirming to the I.S. Specification.
3. To eliminate Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
4. Fire Check Door shall have to be provided properly.
5. Electrical Duct shall be sealed and segregated as recommended by this office.
6. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable of the Building.