

Maharashtra State Electricity Distribution Company Limited
Circle Office: Sangli

No. SE/SC/T

Date:

28 MAR 2006

To, **2142**
M/s, Taurian Iron & Steel Company Pvt Ltd.,
302, A Poonam Chamber, A Wings, 3rd Floor,
Dr. Ami Besant Road, Worali, Mumbai - 400 018.

Subject: - Commissioning of 3 Nos. 1250 KW Wind Turbine Generator in respect of
M/s, Taurian Iron & Steel Co. Pvt Ltd at Village- Waiphale Tq. Tasgaon Dist.
Sangli.

Reference: -

- 1) Dlr (O) Suzlon-32557 Dated 06.10.2005
- 2) Your Letter No. WFP/ Taurian Iron / NP/2.5MW / 05-06 / 1816 dated 22.03.2006

Three No. of 1250 KW Wind Turbine Generator in respect of M/s Taurian Iron & Steel Co.
Pvt Ltd Survey No 1707, 1713 & 1713 of At Village- Waiphale Tal. Tasgaon Dist. Sangli. is
commissioned on 25.03.2006 in the presence of the undersigned, Executive Engineer (O & M)
and Dy. Executive Engineer -Testing unit - Sangli representative of MEDA and the
representative of M/s Suzlon Energy Ltd.

The above said machine at location No.G-373, G-374 & G-375 are commissioned and started
supplying power to MSEDCL Grid with a common metering point at 33/11 KV Savlaj Substation.

The details of 33kV O/H line and the other Metering equipment charged is as detailed here
under:-

33kV Over Head Line: - 19.65 kms. With isolator and Circuit Breaker.

33kV Current Transformer: - For Metering [Main and Check Meter]

Main and Check Meter:-

<u>Check Meter</u>		<u>Main Meter</u>	
CT Ratio: 400/5 Amp.		CT Ratio: 400/5 Amp.	
Sr. No. :	R = 32251004	Sr. No. :	R = 32251001
	Y = 32251005		Y = 32251002
	B = 32251006		B = 32251003
Cl. Accu:	0.2		
Burden:	10 VA.		
Ownership:	Consumer		

33kV Voltage Transformer for Metering [Main and Check Meter]:-

<u>Check Meter</u>		<u>Main Meter</u>	
Sr. No. -	R = 42252004	Sr. No. -	R = 42252001
	Y = 42252005		Y = 42252002
	B = 42252006		B = 42252003

PT Ratio: 33 Kv//3/110Volts//3

Burden/Phase = 100 VA.

Cl Accu. = 0.2

Ownership = Consumer

Maharashtra State Electricity Distribution Company Limited.
Circle Office: Sangli

No. SE/SC/T

No 2144

Date:

22 JAN 2006

To,
M/s, Taurian Iron & Steel Company Pvt Ltd.,
302, A Poonam Chamber, A Wings, 3rd Floor,
Dr. Ani Besant Road, Worali, Mumbai - 400 018.

Subject: - Commissioning of 1 Nos. 1250 KW Wind Turbine Generator in respect of
M/s, Taurian Iron & Steel Co. Pvt Ltd at Village- Tasangi Tq. Rawathe Mahakal
Dist. Sangli.

Reference: -

- 1) Dir (O) Suzlon-32557 Dated 06.10.2005
- 2) Your Letter No. WFP/ Taurian Iron / NP/2.5MW / 05-06 / 1816 dated 22.03.2006

One No. of 1250 KW Wind Turbine Generator in respect of M/s Taurian Iron & Steel Co. Pvt Ltd Survey No 336 of At Village- Tisangi Tal. Kawathe Mahakal Dist. Sangli. is commissioned on 25.03.2006 in the presence of the undersigned, Executive Engineer (O & M) and Dy. Executive Engineer -Testing unit - Sangli representative of MEDA and the representative of M/s Suzlon Energy Ltd.

The above said machine at location No.G-332 are commissioned and started supplying power to MSEDCL Grid with a common metering point at 33/11 KV Savlaj Substation.

The details of 33KV O/H line and the other Metering equipment charged is as detailed here under:-

33KV Over Head Line: - 19.65 kms. With isolator and Circuit Breaker.

33KV Current Transformer: - For Metering [Main and Check Meter]

Main and Check Meter:-

<u>Check Meter</u>		<u>Main Meter</u>	
CT Ratio: 400/5 Amp.		CT Ratio: 400/5 Amp.	
Sr. No. :	R = 32251004	Sr. No. :	R = 32251001
	Y = 32251005		Y = 32251002
	B = 32251006		B = 32251003
Cl. Accu:	0.2		
Burden:	10 VA.		
Ownership:	Consumer		

33KV Voltage Transformer for Metering [Main and Check Meter]:-

<u>Check Meter</u>		<u>Main Meter</u>	
Sr. No. -	R = 42252004		R = 42252001
	Y = 42252005		Y = 42252002
	B = 42252006		B = 42252003

PT Ratio: 33 Kv//3/110Volts//3
Burden/Phase = 100 VA.
Cl Accu. = 0.2
Ownership = Consumer