


| | |
|---|---|
|  CDM project activity issuance review form <i>(By submitting this form, a Party involved (through the designated national authority) or an Executive Board member may request that a review is undertaken)</i> | |
| Designated national authority/Executive Board member submitting this form (Name in print) | |
| Title of the proposed CDM project activity for which issuance is requested | 6.5 MW biomass based (rice husk) power generation by M/s Indian Acrylics Ltd. and replacement of electrical power being imported from state electricity grid/ surplus power supply to grid (0341) |
| DOE that requested for issuance and date of request | SGS-UKL |
| Please indicate, in accordance with paragraphs 65 of the CDM modalities and procedures, for which reason(s) you request review. (Place a cross (X) in front of the reason) | |
| <input type="checkbox"/> <i>Fraud</i> <input type="checkbox"/> <i>Malfeasance</i> <input checked="" type="checkbox"/> <i>Incompetence</i> | |
| Please indicate reasons for the request for review and attach any supporting documentation to this request form. (if space is not sufficient please attach further reasons) | |
| <p>Rice husk consumption is not measured. This parameter should be used for cross checking for steam quantity produced from rice husk. The Monitoring Report p.9 describes the monitoring procedure of biomass consumption as the quantity of biomass used by the project is estimated based on the efficiency of the project. Such monitoring procedure should not be accepted.</p> <p>Calorific value of rice husk, moisture content of rice husk and ash content of rice husk are mentioned in the Monitoring Report p.9 as “monitored on monthly basis”, but no results of this “monitoring” are mentioned in the Monitoring Report and no measuring instruments are described.</p> | |
| Section below to be filled in by UNFCCC secretariat | |
| Date received at UNFCCC secretariat | 04/06/06 |