

 CDM project activity issuance review form <i>(By submitting this form, a Party involved (through the designated national authority) or an Executive Board member may request that a review is undertaken)</i>	
Designated national authority/Executive Board member submitting this form (Name in print)	
Title of the proposed CDM project activity for which issuance is requested	0191 Monte Rosa Bagasse Cogeneration Project (MRBCP)
DOE that requested for issuance and date of request	DNV 27/02/08
Please indicate, in accordance with paragraphs 65 of the CDM modalities and procedures, for which reason(s) you request review. (Place a cross (X) in front of the reason)	
<input type="checkbox"/> <i>Fraud</i> <input type="checkbox"/> <i>Malfeasance</i> <input checked="" type="checkbox"/> <i>Incompetence</i>	
Please indicate reasons for the request for review and attach any supporting documentation to this request form. (if space is not sufficient please attach further reasons)	
<p>1. The PDD stipulates that the second phase of the project (comprising the installation of one 15 MW condensing turbine and 2x20 MW extraction turbines) would be done from 2004 over 5 year period and old generators would be retired. However the monitoring report and the verification report do not specify the status of the installation of these new turbines and the retirement of the old turbines to confirm the source of the electricity supplied to the grid.</p> <p>2. The verification report does not include an assessment of how the following requirements of the monitoring methodology AM0015 have been met:</p> <ul style="list-style-type: none"> - The bagasse to be used as the feedstock for cogeneration shall be supplied from the same facility where the project is implemented; - The implementation of the project shall not increase the bagasse production in the facility; - The bagasse at the project facility should not be stored for more than one year. 	
Section below to be filled in by UNFCCC secretariat	
Date received at UNFCCC secretariat	19/03/2008